

Contractual References :

IED: 2009/014/SREP Cambodge

Beneficiary:

Ministry of Industry, Mines and Energy (MIME)

Funded by:

**French Ministry of Economy, Industry and Labour, Direction Générale du Trésor,
FASEP Facility – Fonds d’Aide et de Soutien au Secteur Privé.**

Engineering firm:

IED Innovation Energie Développement

2 chemin de la Chauderaie

69340, Francheville, France

Tel. +33 (0) 4 72 59 13 20

Fax. +33 (0) 4 72 59 13 39

E-mail : ied@ied-sa.fr

Local partner

Cambodia Development and Engineering Company (CDEC)

91 Street 21

12301, Phnom Penh, Cambodia

Tel: +855 (0) 92 43 62 18

E-mail : admin@cdeccambodia.com

	Version 1	Version 2
Date	9/3/2011	16/3/2011
Written by	AJ	AJ
Reviewed by	AS/KCT	AS/KCT
Approved by	AS	AS
Distribution level	Internal,	Public for distribution

Disclaimer: This report was undertaken under and for the Ministry of Industry, Mines and Energy (MIME) of Cambodia, with funding from the French Government FASEP Facility of the French Direction Générale du Trésor. The study was undertaken in close collaboration with all relevant Cambodian parties and in particular the utility, EDC, the regulator, EAC and the REF Rural Electrification Fund. The study was undertaken by IED – Innovation Energy Development under the supervision of Anjali Shanker. All the results and conclusions presented here are the responsibility of IED and do not necessarily represent the official position of the Cambodian government, agencies and Ministries.

Table of Contents

1	SREP PROJECT CONTEXT.....	8
1.1	OBJECTIVES OF THE STUDY AND TARGETS OF THE ROYAL GOVERNMENT OF CAMBODIA	8
1.2	OUTPUTS.....	9
1.3	ACTIVITIES RELATED TO PROVINCIAL RURAL ELECTRIFICATION PLANS.....	10
2	METHODOLOGY AND APPROACH.....	12
2.1	NATIONAL CONTEXT.....	12
2.1.1	<i>Institutional context.....</i>	<i>12</i>
2.1.2	<i>Status of power sector and rural electrification.....</i>	<i>13</i>
2.1.3	<i>Focus on private rural electricity enterprises.....</i>	<i>18</i>
2.1.3.1	<i>Overall picture of the sector and trends.....</i>	<i>18</i>
2.1.3.2	<i>Market segmentation.....</i>	<i>20</i>
2.1.3.3	<i>Potential for efficiency gains.....</i>	<i>21</i>
2.1.4	<i>Status of renewable energy development.....</i>	<i>22</i>
2.2	OVERVIEW OF THE PLANNING APPROACH.....	25
2.2.1	<i>Rural and urban areas.....</i>	<i>25</i>
2.2.2	<i>Current Household and village connection rates.....</i>	<i>26</i>
2.2.3	<i>GEOSIM: priority to Development impact – selection of development poles.....</i>	<i>29</i>
2.3	THE THREE PLANNING SCENARII.....	33
2.4	REVIEW OF SURVEYS AND DATA COLLECTION.....	34
2.4.1	<i>Secondary data collection.....</i>	<i>34</i>
2.4.2	<i>Agro-industry and rural industry survey.....</i>	<i>34</i>
2.4.3	<i>Data collection from EDC.....</i>	<i>38</i>
3	DEMAND ASSESSMENT.....	39
3.1	DEMAND CATEGORIES.....	39
3.1.1	<i>Domestic market segmentation and demand.....</i>	<i>39</i>
3.1.2	<i>Social services.....</i>	<i>41</i>
3.1.3	<i>Productive uses and small businesses.....</i>	<i>41</i>
3.2	HYPOTHESES ON TRENDS.....	42
3.3	LARGE POWER USERS (SPECIAL DEMANDS).....	45
3.4	RESULTS.....	50
3.4.1	<i>Load forecast results per province.....</i>	<i>50</i>
3.4.2	<i>Family scale rice mills.....</i>	<i>53</i>
3.4.3	<i>Typical daily load curves.....</i>	<i>54</i>
3.4.4	<i>Discussion on ability to pay and issues for the tariff structure.....</i>	<i>54</i>
4	ASSESSMENT OF SUPPLY OPTIONS.....	56
4.1	NATIONAL GRID.....	56
4.2	OFF-GRID AREAS.....	60
4.3	MINI-GRID SUPPLY OPTIONS.....	62
4.3.1	<i>Principles.....</i>	<i>62</i>
4.3.2	<i>Mini Hydropower.....</i>	<i>63</i>
4.3.3	<i>Biomass mini grids options.....</i>	<i>67</i>
4.3.4	<i>Diesel mini grids.....</i>	<i>72</i>
4.3.5	<i>Hybrid PV/Diesel.....</i>	<i>73</i>

4.4	STAND-ALONE SYSTEMS.....	76
5	RESULTS OF THE THREE PLANNING SCENARI	78
5.1	REMINDER OF OBJECTIVES AND APPROACH, SENSITIVITY ANALYSIS.....	78
5.2	BASELINE SCENARIO	80
5.2.1	<i>Key results</i>	80
5.2.2	<i>Detailed analysis for grid expansion component</i>	87
5.2.3	<i>Detailed remarks for off grid areas</i>	89
5.3	SENSITIVITY ANALYSIS: INTERMEDIATE AND CONSERVATIVE SCENARIOS	91
5.3.1	<i>Village and household coverage trends and by technology</i>	91
5.3.2	<i>Regarding investment costs</i>	95
5.3.3	<i>Length of MV lines added per year</i>	96
5.3.4	<i>Investment costs per household and per village</i>	99
5.3.5	<i>Twice as many mini grid projects in the conservative scenario</i>	101
5.3.6	<i>Stand alone systems</i>	102
5.4	COMPARATIVE NATIONAL MAPS FOR ALL THREE SCENARIOS	105
6	SUMMARY PROVINCIAL RESULTS FOR THE BASELINE SCENARIO.....	113
6.1	INTRODUCTION.....	113
6.2	PROVINCIAL DISTRIBUTION OF INVESTMENTS UNTIL 2015.....	113
6.3	BANTEAY MEANCHEY	116
6.4	BATTAMBANG	118
6.5	KAMPONG CHAM	120
6.6	KAMPONG CHHNANG	122
6.7	KAMPONG SPEU	124
6.8	KAMPONG THOM.....	126
6.9	KAMPOT.....	128
6.10	KANDAL	130
6.11	KOH KONG.....	132
6.12	KRACHEH	134
6.13	MONDUL KIRI	136
6.14	PREAH VIHEAR.....	138
6.15	PREY VENG	140
6.16	PURSAT	142
6.17	RATTANAK KIRI	144
6.18	SIEM REAP	146
6.19	PREAH SIHANOUK	148
6.20	STUNG TRENG	150
6.21	SVAY RIENG.....	152
6.22	TAKEO.....	154
6.23	OTDAR MEANCHEY	156
6.24	KEP	158
6.25	PAILIN.....	160
7	CONCLUSIONS	162

LIST OF FIGURES

Figure 1: Current institutional structure of Cambodia energy sector.....	12
Figure 2: Energy mix for generation in EDC areas in 2009 (Source: EDC, 2010).....	13
Figure 3: Cambodia power system and short term hydropower and transmission plans (source: EAC & EDC, 2010).....	15
Figure 4: Forecasted evolution of energy mix in EDC areas (source: EDC 2010).....	16
Figure 5: Electrified villages in Cambodia in 2008. Brown are villages without electricity, yellow are villages with total or partial access to electricity (Source: Village Database 2008 from Ministry of Planning, elaborated by this study).....	17
Figure 6: Historical trend of total number of licensees.....	18
Figure 7: Historical trend of number of Consolidated and Distribution Licensees.....	19
Figure 8: Biomass gasifier in Anlong Tamey.....	23
Figure 9: Map of existing and ongoing biomass projects.....	24
Figure 10: Map of rural and urban communes.....	26
Figure 11: Electrification status of villages in 2010.....	28
Figure 12: GEOSIM planning process.....	29
Figure 13: Number of Development poles per province.....	31
Figure 14: Location and electrification status of Development Poles.....	32
Figure 15: Map of surveyed industries.....	37
Figure 16: Evolution of average household connection rates in rural areas, with the number of years since the EAC license has been granted.....	43
Figure 17: Map of special demands after screening.....	46
Figure 18: Seasonality of main special demands throughout the year.....	49
Figure 19: Province level demand.....	51
Figure 20: District level demand.....	51
Figure 21: Load forecast for villages of 1000 inhabitants in different provinces.....	52
Figure 22: Load forecast for average villages in different provinces, having the average village population in each corresponding province.....	52
Figure 23: Average consumption per customer for villages in different provinces with 1000 inhabitants.....	53
Figure 24: Comparison of consumptions for a village of 1000 inhabitants in Preah Vihear, with and without small rice mills.....	53
Figure 25: Comparison of peak demands for a village of 1000 inhabitants in Preah Vihear, with and without small rice mills.....	53
Figure 26: Average daily load curve in year 20 for a village of 1000 inhabitants.....	54
Figure 27: Average daily load curve in year 1 for a village of 1000 inhabitants.....	54
Figure 28: Map of existing 22kV lines.....	57
Figure 29: Proposed MV line extensions by EDC.....	58
Figure 30: Short term transmission and sub-transmission plans (source: EAC, EDC, MIME, 2010).....	59
Figure 31: Map of “grid” areas in 2010.....	61
Figure 32: Evolution of unit costs with installed capacity.....	65
Figure 33: Raw hydro project generation costs.....	65
Figure 34: Map of identified hydro potential projects.....	66
Figure 35: Workers shoveling rice husks coming out of a rice mill.....	67
Figure 36: Map of identified biomass projects (conservative scenario).....	71
Figure 37: Historical evolution of PV panel unit prices for the past decade.....	74
Figure 38: Location of possible picohydro projects.....	77
Figure 39: Rural demand grid connected villages – energy and peak load.....	79

Figure 40: Evolution of village coverage for different technologies	81
Figure 41: Map of grid extension by 2015, mini-grid projects and stand-alone candidates (baseline scenario)	83
Figure 42 : 2030 Map of grid extension (baseline scenario).....	84
Figure 43: Evolution of household connection rates for mini-grid technologies.....	86
Figure 44: Yearly investment for all technologies in rural areas	86
Figure 45 : Yearly investment for mini-grid and stand-alone technologies in rural areas.....	86
Figure 46: Total grid investment costs with detailed breakdown and comparison with EDC estimates (baseline scenario, in millions of USD)	87
Figure 47: Length of MV lines added (baseline scenario).....	88
Figure 48: Breakdown of MV line length added per province (baseline scenario)	88
Figure 49: Trend of village and household coverage rates to 2030, 3 scenarios	91
Figure 50: Share of national and off grid connections for HH to 2030, 3 scenarios.....	93
Figure 51: Evolution of village coverage for different technologies	94
Figure 52: Breakdown of investments by technology – 3 scenarios.....	96
Figure 53 : Breakdown of investments by technology – Details by scenario	97
Figure 54: Length of MV lines added	100
Figure 55: Number of mini grids projects, all scenarios	101
Figure 56: Number of standalone systems, all scenarios	103
Figure 57: Number of standalone systems, all scenarios	103
Figure 58: Map of grid extension (intermediate scenario).....	105
Figure 59: Map of grid extension (conservative scenario).....	106
Figure 60: 2030 Map of mini-grid projects (baseline scenario).....	107
Figure 61 : 2030 Map of mini-grid projects (intermediate scenario).....	108
Figure 62 : 2030 Map of mini-grid projects (conservative scenario).....	109
Figure 63: 2030 Map of candidates for stand-alone systems (baseline scenario).....	110
Figure 64: 2030 Map of candidates for stand-alone systems (intermediate scenario).....	111
Figure 65: 2030 Map of candidates for stand-alone systems (conservative scenario).....	112

LIST OF TABLES

Table 1: Consumption, villages and households covered by licensed REEs in 2009	19
Table 2: Market segmentation of REEs, by the number of clients	20
Table 3: Main characteristics (averages) of each market segment.....	21
Table 4: Electrification rates from 2008 General Census	26
Table 5: Electrification rates in 2010, updated from 2008 General Census	27
Table 6: Collected databases	35
Table 7: Number of surveyed industries	36
Table 8: Relative weight of classes in year 1	39
Table 9: Relative weight of classes in year 20	39
Table 10: Ownership of appliances (average number per household).....	40
Table 11: Nominal power rating of appliances	40
Table 12 : Specific demand of one household for each class.....	40
Table 13: Number social services per village for different population ranges – national average.....	41
Table 14: Specific demand of public services, not including distribution losses	41
Table 15: Number of productive uses per village for different population ranges	42
Table 16: Specific demand of productive uses, not including distribution losses	42
Table 17: Consumption in rural areas (calculated from EAC presentation to SREP kick-off)	43

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Table 18 : Nation-wide consumption figures (calculated from EAC annual reports)	44
Table 19: Growth hypotheses.....	44
Table 20: Number of activities for different types.....	45
Table 21: Peak demands of different categories of special demands.....	47
Table 22: Detailed characteristics of special demands.....	48
Table 23: Rural demand per province (GWh/year).....	50
Table 24: Ability to pay figures from UNDP/GERES study	55
Table 25: Cost of transformers.....	62
Table 26: Mini-hydro projects for each scenarii	64
Table 27: 4 main types of biomass projects	69
Table 28: Results of the SREP survey on small and medium rice mills.....	69
Table 29: Number of identified potential projects	69
Table 30: Cost of diesel gensets.....	72
Table 31: Diesel projects for each scenarii	72
Table 32: Diesel generation costs for different capacities of diesel gensets, and associated competitive PV/hybrid option	74
Table 33: Diesel generation costs and associated competitive PV/hybrid option with higher diesel price and lower PV unit costs	75
Table 34 : Investment costs for all technologies in rural areas (baseline scenario, in thousands of USD)	81
Table 35: Summary of results for grid extension in the baseline scenario	87
Table 36 : Household investment cost with detailed breakdown and comparison with EDC estimates (baseline scenario, in millions of USD/connection).....	88
Table 37 : Distance of proposed mini-grid projects to the national grid (baseline scenario) .	89
Table 38 : Mini grid investments: number, capacity and investment cost. (baseline scenario, in thousands of USD)	89
Table 39: Installed capacity and investment costs for hybrid PV/diesel in the baseline scenario (investment costs include panels, electronics and batteries only, diesel gensets are excluded).....	90
Table 40: Stand alone systems : Village coverage rates, number of systems and investment costs.....	90
Table 41: Household Coverage rates achieved by all technologies in rural areas only	92
Table 42: Installed capacity and investment costs for hybrid PV/diesel in three scenarios (investment costs include panels, electronics and batteries only, diesel gensets are excluded)	96
Table 43: Detailed grid & off grid investment costs, 3 periods & 3 scenarios (in '000 of USD).....	98
Table 44: Investment costs for grid extension per household and village, 3 periods & 3 scenarios	99
Table 45: Investment costs for all technologies per household, 3 periods & 3 scenarios (in USD per household)	99
Table 46: Number of mini-grids and capacity by technology for the 3 scenarios	101
Table 47: Investment costs for mini-grid technologies (in '000 of USD).....	102
Table 48: Number of standalone systems to install, all scenarios.....	104
Table 49: Breakdown of investments in standalone systems, all scenarios (in '000 USD)..	104
Table 50: Investment cost for the 2011-2015 phase by province and technology in the baseline scenario ('000 USD).....	113
Table 51: Classification of provinces into 4 groups by investment costs in each technology (1-green means highest investment, 4-red means lowest).....	114

LIST OF EQUATIONS

Equation 1 Net Present Value formula for grid extension optimisation 56
Equation 2 Hydro unit cost formula 64

1 SREP PROJECT CONTEXT

1.1 OBJECTIVES OF THE STUDY AND TARGETS OF THE ROYAL GOVERNMENT OF CAMBODIA

In 2009, MIME approached the French Embassy in Phnom Penh for support in capacity building at the Ministry on rural electrification planning. A work plan was discussed with IED, Innovation Energie Développement, comprising 3 components:

1. Elaboration of Sustainable Rural Electrification Plans, using the GEOSIM tool (www.geosim.fr) for different fund availability options, combining national grid expansion and mini grid options, as well as stand alone options. These results are presented in this report;
2. Training of team of MIME staff on the use of GEOSIM and transfer of the tool and methods to the Ministry, with a hands on approach;
3. Feasibility studies for 3 to 5 renewable energy based mini grids and exploring the possibility of mobilising investors for actual construction of the mini grids, in private public partnership approach.

Upon approval by the Minister of Energy, H.E Tun Lean, general director of Energy department, MIME, signed a Memorandum of Understanding (MoU) with IED on the Ministry's behalf. The MoU is effective since 29th January 2010.

The study was launched in a context of extremely ambitious political targets wherein the current policy objectives are:

- **By 2020, all villages should have access to electricity** of different forms. Electrification is defined here as a village where more than 50% of households receive some form of electricity supply, including from batteries with access to a battery charging system
- **By 2030, 70% of rural households should have access to grid quality service** (24-hour mini-grids or national grid) at acceptable price level and with minimum subsidy from the government. A recent document prepared by EAC has added new targets, which supplement the previous ones, while being slightly more ambitious:
- **By 2020, 80% of villages should have access to the national grid, and the remaining 20% should have access to mini-grids**
- **By 2030, 95% of villages should have access to the national grid**

Moreover, a recent commitment taken as part of the ASEAN aims at **reaching 15% of new and renewable energy by 2015** (every member country took the same commitment). This target does not include large hydro, which implies significant development of medium sized Renewable Energy projects, such as the ones suggested in this study.

In this context, MIME has entered into a collaboration with IED with support of the French Government (FASEP fund), in order to translate these broad and ambitious policy targets for rural electrification into concrete provincial investment plans, supported by maps showing the spatial arrangement of the proposed projects. These investment plans will strengthen the credibility of long term energy policies, and can be used as a tool in negotiations with international donor agencies.

Available financial resources will be matched with the requirements of the policy targets. In a context of constrained budget, the approach will provide insight on the way to prioritise projects: higher preference will be given to those which maximize the impact of social and economic development, i.e. projects supplying "Development Poles", or "Growth Centres" (cf. 2.2 for further details on the specificities of the approach).

Therefore, the present planning study comes as a downstream step of:

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

- The previous institutional, legal and regulatory projects by the World Bank, which put in place institutions (REF) and guidelines for responsibilities of the various actors (cf. “Rural Electrification Strategy and Implementation Plan”)
- The macro-level transmission and regional interconnection projects (e.g. “Power Sector Development Plan”), which left small-scale projects and medium voltage extension issues aside
- The renewable energy potential reviews (e.g. “Master for Rural Electrification from Renewable Energy”), which need to be updated and further detailed with sizing and prioritisation of projects

Moreover, because of uncertainties on forecast assumptions and rapid changes in the situation of the country (for example in the agro-industry sector or grid extension planning, as mentioned above), every planning exercise needs to be updated regularly. That is why the project goes beyond the mere production of a Master Plan document, and strives to transfer the planning tool to MIME. MIME will indeed play a key role in all activities, covering data collection and production of plans as part of Memorandum of Understanding between IED and MIME.

Finally, to better illustrate the transition from the planning exercise to project implementation, feasibility studies are carried out on a few interesting projects identified at planning stage, and possible investors and financing schemes will be sought.

The main components of the Rural Electrification Strategy in Cambodia are:

- Grid expansion from the existing network, with a priority to areas within 40km of the 24 provincial towns (where more than 80% of the population lives)
- Cross-border Power Supply from neighbouring countries (Thailand, Vietnam and Lao PDR)
- Mini-utility systems for remote areas, based on:
 - Diesel gensets (to be phased out in as much as feasible)
 - Decentralized renewable energy (solar, wind, mini-micro hydro, biomass, bio-fuel, etc...)
 - Stand-alone systems (PV, battery charging...) where demand is too low or too scattered
 - Rural Entrepreneurs, NGOs and woman’s groups shall be encouraged to participate in the management at the local level. Private participation is encouraged wherever electrification is profitable, otherwise EDC shall come in as public service provider in priority areas.

All these options will be combined in the study to suggest the optimal path to meet government targets. We provide hereafter a brief review of the activities in the work programme, and their current status.

1.2 OUTPUTS

The four main outputs of the project are:

- Concrete investment plans, with lists of projects in table and detailed report format allowing actual programming and prioritisation taking into account national and provincial level objectives, physical and financial constraints.
- Trained national MIME staff, which will train in turn provincial authorities on rural electrification planning, using the GEOSIM software tool. National team will be actively involved in all the steps of the planning process, from data collection, practical use of GEOSIM and feasibility studies.
- 2 to 5 feasibility studies for projects with capacities between 50kW and 2MW. Technologies considered are small hydro, bio-electricity (gasification, biogas or co-generation),

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

geothermal power and hybrid PV/diesel systems. These feasibility studies will be used in mobilisation of private sector to actually implement projects.

- Dissemination of information and mobilisation of private sector to implement projects through drafting of operational business models and organisation of regional events.

1.3 ACTIVITIES RELATED TO PROVINCIAL RURAL ELECTRIFICATION PLANS

Rural electrification plans have been made, and are presented in this report. Results at national level are discussed in the first chapters, and province level reports for all provinces, excluding Phnom Penh are provided separately.

Activities carried out include:

1. Creation of a comprehensive national Geographic Information System (GIS) database, to run the GEOSIM Rural Electrification planning model.

- Creation of a database, from secondary supplemented with additional data collection in close collaboration with MIME. The outcome of data collection activities is explained in more detail further.
- Data collection at national level.
- Socio-economic and multisector data (demography, health, education, commerce...), in order to update already available data and select priority localities with high potential for social and economic development (Development Poles). The Ministry of Planning database (former SEILA programme) with detailed socio-economic data from the General Population Census of 2008 has been the main input at this stage.
- Villages covered and MV lines of existing electricity providers, both REEs (Rural Electrification Enterprises) and EDC, have been collected from EAC and EDC.
- Final results of national grid extension plans have been collected from EDC for the national grid extension (HV and MV lines, substations) up to 2020.
- Large businesses, which could benefit from electrification, have been collected from Industry Department of MIME.
- Location of existing and planned bridges on national rivers have been taken from Ministry of Public Works and Transport (MPWT), important to plan grid network extension across the Mekong and Bassac rivers.
- Data collection at provincial level.
- Definition of 4 homogenous study areas (cf. Annexes), with a “regional kick-off workshop” held in each region, so as to explain to provincial authorities (PDIME) the whole approach, get some feedback from them on already collected data, assess the data collection needs and present the method and timeframe to collect remaining data.
- A nation-wide database of rural industries and agro-industries (about 20,000 businesses), has been established from databases collected from provincial authorities (PDIME). Then the most relevant industries have been selected for field surveys to gather additional data.
- MIME and PDIME staff have been trained on the survey, and then sent in teams throughout the country, to interview more than 150 industries.
- Other data collected from PDIME (through databases, workshops and phone interviews) include: validated Development Poles, updated socio-economic data, list of non licensed REEs, number of small businesses, ideas of additional potential hydro and biomass sites to further study.

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

2. Identification of Decentralised Renewable Energy potential for Rural Electrification, with installed capacities ranging from 50kW to 2MW¹.
 - Identification of hydro potential sites (micro and mini hydro) based on previous studies, analysis of maps and hydrology (rainfall and water flow) in 4 priority provinces².
 - Summary site visits to produce site identification profiles for planning purposes in the 4 provinces.
 - Identification of biomass to electricity potential sites, which implied detailed information collection on agro industries and their available biomass residues (cf. above).
 - Identification of opportunities for hybrid PV/diesel systems in areas where the hydro and biomass potentials are not sufficient.
3. Review of relevant past and ongoing studies, in order to:
 - Analyse data on end-use consumption.
 - Assess the rural electrification baseline (current situation of access to electricity in the country).
 - Supplement other sources regarding hydro and biomass potential.
4. Definition of planning scenarii.
 - In discussion with Cambodian authorities (EDC, EAC, MIME), 3 scenarii have been defined, corresponding to different level of grid extension over the next 20 years: from the “optimistic” targets of EDC extension plans, to more conservative scenarii.
 - Planning objectives and constraints have thus been reviewed – target connections and villages covered, time horizon, financial constraints, secured financial resources, overall strategy.
 - Development of scenarii with the GEOSIM software to produce operational investment plans for renewables and rural electrification, including programming of investments, maps, investment costing tables as well as GIS database.

¹ The 50kW threshold corresponds to village scale/community systems, and are beyond the scope of a planning exercise at national level. On the other hand, sites above 2MW are relatively large compared to the existing power system, and thus belong to grid generation expansion planning, rather than rural electrification planning.

² These 4 provinces have been given by MIME: Mondul Kiri, Rattanak Kiri, Pursat and Battambang.

2 METHODOLOGY AND APPROACH

2.1 NATIONAL CONTEXT

2.1.1 Institutional context


Article 3 of electricity law defines the responsibility between two main institutions: Ministry of Industry, Mines and Energy (MIME) and Electricity Authority of Cambodia (EAC), in the power sector. The roles of the two organisations as well as other institutional arrangements are shown in the following picture.

EDC is a state owned corporation under MIME, which owns and operates the Phnom Penh main generation, transmission and distribution assets, as well as in several provincial towns and accounts for approximately 90% of total electricity consumption of the country, if Independent Power Producers (IPPs) selling power to EDC are included. EDC has a non-exclusive responsibility for generation, transmission, distribution and retail of electricity throughout Cambodia. The remaining electricity consumption is supplied through rural electrification enterprises (REEs) and small generators.

Finally, the recently created Rural Electrification Fund (REF) aims at supporting financially and technically the decentralized rural electrification projects.

At provincial level, the Provincial Departments of Industry, Mines and Energy (PDIME) which depends on MIME and on Provincial authority, plays a key role in implementation of rural electrification programs, but not very actively participate in the formulation of policy and measures.

Figure 1: Current institutional structure of Cambodia energy sector



Note : PEU – public electricity utility; IPP – Independent power producer; PEC – Private electricity company (or REE – Rural Electricity Enterprise); EDC – Electricité du Cambodge

-▶ Ownership control of EDC
- ▶ Policy, strategies planning, development, technical, safety and environmental standards
- ▶ Regulations, issue licences, review the planned investments, finance & performance, enforce regulation, rules and standards
-◆ Provides subsidies and technical assistance for diesel REEs, mini and micro hydro projects and Solar Home Systems (SHS)

2.1.2 Status of power sector and rural electrification

The electric power system in Cambodia was reconstructed from the ruins since the 80's. It still consists of isolated systems with the biggest systems in Phnom Penh capital (67% of total energy generated in 2009) and several non-interconnected grid in provincial towns under EDC and many mini-grid systems provided by scattered rural electrification enterprises (REEs, private energy providers). These systems can be grouped into three categories

EDC supply systems (22 not interconnected supply areas in Phnom Penh and provinces). Of the 1100 GWh generated on these networks in 2009 (excluding imports), 89% have been ensured by Independent Power Producers (IPPs), operating mostly fossil fuel thermal power plants. In 2009, there were also 25 private distribution Rural Energy Enterprises (REE) purchasing bulk power from EDC and selling it to their customer,

“Consolidated” (generation and distribution) REEs. At the end of 2009, there were 197 such licensees, mostly mini-grid with diesel systems.


Non-licensed REE power supply systems unknown number, estimated several hundreds (cf. next chapter).

At the end of 2009, the total installed capacity in Cambodia (excluding imports) was about 395 MW, distributed between EDC (77 MW), IPPs (265) and small consolidated licensee (REE, 43 MW).

The electricity prices in Cambodia are currently the highest in the ASEAN region and even the world: up to 17 UScts/kWh for EDC customers, and up to 1 USD/kWh for customers of diesel-based REEs, which must bear significant production costs caused by inefficient second-hand gensets and poorly designed distribution mini-grids. That is why rechargeable car batteries are still commonly used throughout the country (92% of villages according to 2008 village database), even among electrified villages (78% of electrified villages).

The main reason for such high tariffs in EDC areas is the predominance of fossil fuels in the energy mix. National generation without imports is 95% thermal (mostly Heavy Fuel Oil - HFO) with a small share of hydro as shown in Figure 4. In terms of installed capacity, the proportions are the same, with 353 MW of Diesel/HFO, 13.4 MW of hydropower, 13 MW of coal power plant and about 5 MW of wood & biomass power plants.

Figure 2: Energy mix for generation in EDC areas in 2009 (Source: EDC, 2010)




SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

The current generation facilities are not only too expensive, but also insufficient to cope with the surging demand. Interconnection of isolated systems and import of electricity from neighbouring countries are thus considered an appropriate short and mid-term strategy to meet surging demand, while also keeping generation costs at reasonable levels (current imports from Vietnam and Thailand are at a price of 7 to 9 UScts per kWh). As shown in Figure 2, 40% of the 1,818 GWh generated in 2009 have been imported (EDC, 2010). Interconnections with neighbouring countries are happening at all voltages levels, from low voltage to high voltage. Recently commissioned high and medium voltages lines are:

- 115 kV line from Thailand to Banteay Meanchey, Siem Reap and Battambang
- 230 kV line from Vietnam to Phnom Penh
- 22 kV line from Laos to Stung Treng
- 35 kV line from Vietnam to Kampong Cham
- Upcoming import transmission lines are:
 - 35 kV lines from Vietnam to Mondul Kiri and Rattanak Kiri (2011)
 - 230 kV line from Vietnam to Kampong Cham and Phnom Penh (2012)
 - 230 kV line from Laos to Stung Treng and possibly Kratie (2013)

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 3: Cambodia power system and short term hydropower and transmission plans (source: EAC & EDC, 2010)



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans


As the power demand is expected to continue its growing trend in the near future, and considering current power shortages in nearby countries, the long term strategy relies on development of local low cost generation capacity, mostly large hydropower projects. Several such projects have indeed been undertaken recently under Chinese financing:

5 hydro projects totalling 900 MW are under construction in the Cardamoms Range (Pursat, Koh Kong and Kampot provinces) and planned for commissioning between 2011 and 2015

Another project of 420 MW is seriously under consideration in Stung Treng

Coal power is also considered to some extent, with a 200 MW coal power plant in Sihanoukville (first 100 MW to be commissioned by 2013).

Figure 4: Forecasted evolution of energy mix in EDC areas (source: EDC 2010)




In parallel to these generation expansion activities, interconnection of all major power systems is planned. However, some areas such as Kampong Thom and Preah Vihear will probably remain isolated from the rest of the country for at least 5 to 10 years.

In the medium-term, all these projects are expected to significantly reduce generation costs on the national grid (from a current average of about **12 UScts/kWh**), and thus the retail tariff to the end-user, allowing even provisions for cross-subsidisation of rural electrification.

However, the issue of actual access to the national grid remains, with only about **25%** of household having access to electricity nationwide, and only half of this from the national grid (the rest being isolated REEs). An ambitious medium voltage extension programme is led by EDC to tackle this issue, tapping resources from various donors (World Bank, ADB, Chinese Exim Bank, AusAid, KfW etc.), but this will take time and the corresponding financial resources are not yet secured. Therefore, off-grid renewable energy-based technologies are believed to have a role to play in the overall strategy to increase access to electricity in the short term.

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 5: Electrified villages in Cambodia in 2008. Brown are villages without electricity, yellow are villages with total or partial access to electricity (Source: Village Database 2008 from Ministry of Planning, elaborated by this study)



2.1.3 Focus on private rural electricity enterprises

This chapter aims at providing an overview of the REE sector, by combining and analysing data from the following main sources:

- EAC Annual Reports, and the last one in particular, covering the 2009 period
- The SREP database, including GIS data of REE licenses (last updated in October 2010) and GIS data of existing and planned MV lines by EDC


2.1.3.1 Overall picture of the sector and trends

According to the latest EAC Annual Report, at the end of 2009 there were a total of 249 licensed electricity operators, including:

- **25** Distribution Licensees (distributing power purchased from the national grid or another power supplier)
- **197** Consolidated Licensees (generating and distributing power in isolated mini-grid systems)
- The remaining licensees are mostly Generation Licensees (only generating power for one of the interconnected networks) and Transmission Licensees (operating one of the high voltage transmission lines)

Although the official policy of EAC is to try and reduce the number of licensees eventually (through mergers), the historical trend until now has been a steady increase:

Figure 6: Historical trend of total number of licensees




Accurate data for 2010 is missing, but provisional GIS data from October 2010 already shows a total of 267 licensees.

This increase in number of licensees does not necessarily mean they are all newly electrified areas, as there used to be a significant amount of unlicensed operators in the past, which have progressively acquired licenses. Therefore, we can reasonably expect a curb in the increase of new licensed REEs, at least in off-grid areas.

According to the SREP database, there are currently at least **815** villages electrified outside REE license zones, which would amount to about **200** non licensed REEs, assuming a ratio of 4 villages per REE (slightly lower than the average of 7 villages for Consolidated Licensees).

Although the number of Distribution Licensees remains modest, the number of both Distribution and Consolidated Licensees have increased at the same rate until, at 20% per year on average:

Figure 7: Historical trend of number of Consolidated and Distribution Licensees



Following the aggressive grid extension programme, it would seem that most of the licensed REEs will no more be isolated:

- The licensee zone of **96%** of current REEs will intersect with the national grid planned by EDC for 2020
- For Consolidated Licensees, which are not currently interconnected with the national grid, the average year of connection to the grid is **2013** (assuming grid extension happens as quickly as planned)

However, as EDC is not very much interested in taking on the responsibility of distribution and customer management, but interested in being a bulk supplier, the future configuration will probably that of REEs purchasing in bulk from the national grid. This will enable them to have much lower tariffs than currently, as the purchasing price from EDC will be much lower than the cost of diesel generation.

The current number of villages and clients supplied by REEs are given in the table below:

Table 1: Consumption, villages and households covered by licensed REEs in 2009

	Villages in license zone	Villages connected	Village coverage rate	Number of village per REE
Consolidated	3 267	1 183	36%	6,6
Distribution	1 479	623	42%	20,1

	Households in electrified villages	Actual connections	HH connection rate	Number of connection per REE
Consolidated	311 621	136 214	44%	765
Distribution	171 505	76 859	45%	2479

	Energy purchased and generated (GWh)	Energy sold (GWh)	Losses	Average consumption per connection (kWh/month)
Consolidated	53	42	21%	26
Distribution	195	177	10%	192

The above figures reveal that Distribution licensees are much larger on average than Consolidated ones, with 20 villages per licensee instead of 7, and about 2500 customers instead of 765. We can also notice that the connection rate in electrified villages is decent, at almost 50%. Finally, Consolidated licensees have much higher levels of distribution losses (21% against 10%),

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

and lower specific consumption of their customers, which is consistent with the situation in rural areas where Consolidated REEs operate.

The total capacity of consolidated licensees was about **37 MW** at the end of 2009 (calculated from the installed capacities), which is about 10% of the total installed capacity in the country.

2.1.3.2 Market segmentation


A database of REEs at the end of 2009 has been established (cf. annexes), by combining the different tables of the EAC reports, as well as GIS data from the SREP database. Among the 25 Distribution Licensees and 197 Consolidated Licensee mentioned in the 2009 EAC report, 13 are indicated as not operating and a few Consolidated Licensees seem to be operated as Distribution Licensees (only purchasing power and not generating). Therefore, the final breakdown of REEs suggested by this database is:

- **31** Distribution Licensees
- **178** Consolidated Licensees

From this database, the following market segmentation by number of clients is suggested (using a k-means statistical method):

Table 2: Market segmentation of REEs, by the number of clients

		Number of REE in class	Min number of clients	Max number of clients	Avg number of clients
Consolidated	Class 1	148	58	1 057	516
	Class 2	26	1 100	2 586	1 628
	Class 3	4	3 589	5 000	4 384
Distribution	Class 1	26	4	3 768	1 641
	Class 2	4	5 417	7 641	6 348
	Class 3	1	13 506	13 506	13 506



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Averages for the main characteristics of each segment are presented in the table below:

Table 3: Main characteristics (averages) of each market segment

		Electrified villages	HH conn. rate	Power purchase tariff (USD/kWh)	Retail tariff domestic (USD/kWh)	Installed capacity	Hours of service per day	Load factor while operating	Losses
Consolidated	Class 1	6	41%	N/A	0,66	180	16,9	15%	21,5%
	Class 2	11	58%	N/A	0,57	432	23,8	18%	21,8%
	Class 3	24	71%	N/A	0,38	588	24,0	36%	21,6%
Distribution	Class 1	18	51%	0,15	0,35	N/A	24,0	N/A	12,3%
	Class 2	34	47%	0,18	0,27	N/A	24,0	N/A	12,5%
	Class 3	31	48%	?	0,24	N/A	24,0	N/A	4,0%

As shown in this table, technical losses are much higher for Consolidated than Distribution licensees, although there is not any difference between different classes inside the two groups.

Smaller Consolidated REEs (class 1) tend to have non continuous service (less than 24h), lower connection rates, lower load factor, and probably much less efficient gensets (although no data can confirm this assumption). All these factors result in much higher retail tariffs for smaller licensees (66 UScts/kWh on average for class 1 Consolidated !).

Obviously, generation costs of Consolidated Licensees being much higher than the power purchase tariff from the grid for Distribution Licensees (15 UScts/kWh for Class 1, and 18 for Class 2), the retail tariff is much lower for Distribution than for Consolidated Licensees.

2.1.3.3 Potential for efficiency gains

Current REEs have very high levels of energy losses:

- At generation level: using old second-hand gensets
- At distribution level: few REEs are using Medium Voltage lines even if their license zone is very spread out, and many distribution mini-grids are poorly designed (unbalanced phases, wrong cable and transformer sizing etc.)

The case study of Chambak REE carried out by SREP (in view of installing a PV/Hybrid system) revealed an extraordinarily high level of distribution losses, at 40%, combined with a diesel specific consumption of 0.43 L/kWh. Following installation of MV lines, as well as improvements on the existing LV lines, distribution losses are expected to drop to 10%, which is the standard set by EAC. Moreover, replacing the existing gensets by efficient ones could lower the specific consumption to 0.3 L/kWh. All these actions would lower the total diesel consumption per kWh sold from 0.72 L to 0.33 L (~50% decrease) !

To assess the potential for efficiency gains at the national level, we can do the following assumptions:

- The current average diesel consumption for Consolidated Licensee can decrease from the current average of 0.35 L/kWh (conservative estimate, suggested by EAC) to 0.3 L/kWh. This would result in 12,000 L of diesel fuel savings per year (14 % of the current total consumption for Consolidated).
- Distribution losses can go down to a maximum of 10% for both Consolidated and Distribution Licensees, resulting in 10,500 MWh of electricity savings per year in total.

To assess the equivalent tons of avoided green house gases, we make the following assumptions:

- The emission factor of the national grid is 0.70 kgCO₂eq/kWh (Ministry of Environment, Feb 2011)

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

- The emission factor of the current Consolidated Licensees is 0.98 kgCO₂eq/kWh (corresponding to 0.35 L/kWh) and goes down to 0.84 kgCO₂eq/kWh (corresponding to 0.30 L/kWh)

The total corresponding emission reductions would be about 14,000 tCO₂eq per year, including 11,400 tCO₂eq for Consolidated Licensees and 2,600 tCO₂eq for Distribution Licensees.

2.1.4 Status of renewable energy development

The rationale for renewable energy as a rural electrification option may be presented in different ways, depending on the context:

On the national grid:

- Medium/large projects (hydro, biomass, and PV in the long term) can reduce overall grid generation costs
- Small/medium projects located close to demand, at the end of the lines, can reduce transmission losses

For mini-grids:

- Small renewable energy projects are usually competitive with current isolated diesel production costs under favourable financing conditions

For stand-alone systems:

- Various applications of solar PV and pico-hydro for remote areas: Battery Charging Stations, Solar Home Systems, bridge lighting, telecommunication systems, pumping...

However, until now the potential for renewable energy has been largely untapped, as revealed by the quick review below.

a) Hydro

Technical potential of hydropower in Cambodia is very high (more than 10000 MW for large hydropower and 300MW for small, mini and micro hydropower) but most of this potential has not been developed until now.

As of 2008, there are about 9 hydropower plants in operation in Cambodia with total capacity of 13.2 MW (Kirirom I and O Chum II alone amount to 13.0 MW) and representing about 3% of the total energy output of the country.

As explained in the previous chapters, several large hydropower projects are ongoing, with a combined installed capacity of about 900 MW.

However, excepting a few demonstration facilities powering remote provincial towns (such as Pailin and Sen Monorom), the situation for mini-hydro³ remains much less dynamic, despite several initiatives such as UNIDO and REF programmes to develop mini-hydro powerplants. In fact, and contrary to large hydropower projects, which can afford to build hundreds of km of high voltage lines to transmit power to demand centre, mini-hydro have to rely exclusively on local demand. Therefore, one of the main challenges for minihydropower development in Cambodia is the very low population density in the areas where there is minihydro potential (mostly mountains in Cardamoms Range and North-Eastern provinces), as highlighted in the planning results of this report.

b) Biomass

Biomass resources such as wood (rubber trees, acacia, eucalyptus...) and agricultural residues (mostly rice husk, but also cashew nut shells, peanut shells, palm oil residues, dung...) are

³ Between 50kW and 2MW

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

abundant in Cambodia. But similarly to hydropower, this theoretical potential has not been harnessed significantly until now.

Among the three main technologies considered (gasification, cogeneration and biogas), cogeneration and biogas usually require significant biomass input to be technically and economically feasible.

Until recently, few large scale agro-industries existed, and a large part of raw products have been exported to neighbouring countries for further transformation. A number of large existing agro-industries even went bankrupt.

Therefore, the most common biomass technology has been gasification of agricultural residues, either spontaneously (with imported and even locally manufactured equipments) or through international cooperation. A few examples of such projects:

A 200kW rice husk gasification project has been implemented in Battambang province, in a relatively large rice mill (2t rice processed per hour). Investment costs amounted to USUSD75,000 and the payback period was 3 years.

This pilot project has been followed by several other similar projects in rice mills, ice factories, brick factories and garment factories, only for their own consumption until now (about 40 projects commissioned between 150kW and 700kW). Some equipments are imported from India and distributed by a local company (SME Renewables), but there is now a market for locally manufactured gasifiers.

Some other projects tried to use the same technology for rural electrification purposes, such as the Anlong Ta Mei community energy project (9 kW woody biomass in Battambang, now closed because the grid has arrived in the area) and another similar ongoing project by FONDEM in Kampong Thom province. These initiatives rely on community managed fuel wood plantations.

Figure 8: Biomass gasifier in Anlong Tamey


(Source: JICA study of rural electrification by Renewable energy in Cambodia)



However, the situation is changing quickly, and should change even more in the coming years, as the agro-industry sector becomes more export-oriented (a recent government policy aims at increasing rice exports from its current level of 40,000t/year to 1 Million t/year, through improvement of rice standard and investment in large modern rice mills). Between 5 and 10 rice mills with processing capacities from 10t/h to more than 30t/h are planned, which represent opportunities for cogeneration projects. A first cogeneration power plant has been built in the recently opened Golden Rice mill in Kampong Speu (25 t/h processing capacity). Several large scale sugarcane (about 4) and palm oil plantations are also planned, as well as large pig farms (less than 5).

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 9: Map of existing and ongoing biomass projects



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Existing projects known to date (combining different technologies and biomass residues, as shown in the figure above) amount to a total of 10.7 MW, mostly for captive use.

Ongoing projects total 87.6 MW, but this time selling excess power is often part of the design for the larger projects, as the agro-industry itself cannot absorb all the power produced. However, many of these projects are still at the plantation stage, with the processing factory still to be built, therefore it is unsure when or even if all these projects will actually be implemented.

c) Solar

The data from the JICA master plan study of rural electrification by renewable energy in 2006 has shown an average radiation of 5.1 kWh/m²/day or equivalent of 1860 kWh/m²/y over the country.

According to MIME, as of 2004, more than 204 kWp of PV modules have been installed in the country. They are used to supply power for household lighting and small electric equipment of public and telecommunication facilities. These installations were mostly donation and/or demonstration research projects.

d) Wind

All available information indicates that mean wind speeds are low, in the order of 2m/s for much of the country.

The southern part of the great lake Tonle Sap, the mountainous districts in the southwest and the coastal regions have an annual average wind speed of 5m/s or greater; thus the introduction of wind power generation system in these areas is promising. However, to date only one large wind turbine has been installed in Sihanoukville (under Belgian financing).

2.2 OVERVIEW OF THE PLANNING APPROACH


Electrification in Cambodia is still nascent, policy objectives are very ambitious, with 2030 targets aiming at 95% village coverage by the grid and 70% rural households having grid quality service; much remains to be done both in terms of electricity access and renewable energy projects. Although regulatory and financial mechanisms are being created such as REF and EAC, they may lack a clear vision on the medium to long term perspectives to be fully efficient.

2.2.1 Rural and urban areas

All results in this report are about rural areas only, unless it is specifically mentioned to cover urban areas as well. The definition of “urban” and “rural” communes has been taken from the National Institute of Statistics (NIS):

- Population density >200 inh./km²
- Employment in agriculture <50%
- Total population of commune >2000 inh., see annexes for a detailed list of communes defined as “urban”.

Figure 10: Map of rural and urban communes



2.2.2 Current Household and village connection rates

Definition of electrification (according to RE strategy report and RGC policy):

- Electrified household: grid or mini-grid supplied
- Electrified village: at least 50% of households living in the village enjoy grid, mini-grid or other sources of electricity service such as Battery Charging Station (BCS) and PV

Baseline population and electrification figures have been taken from the village and commune database, stemming from 2008 General Population Census. Its results are summarized in the table below:

Table 4: Electrification rates from 2008 General Census⁴

	Total			Urban			Rural		
All households	2 736 236			406 761			2 329 475		
Supply source	Grid	Mini-grid	Total	Grid	Mini-grid	Total	Grid	Mini-grid	Total
Electrification rate	16.6%	4.2%	20.8%	74.3%	3.7%	78.0%	6.5%	4.3%	10.8%
Electrified households	453 539	114 452	567 991	302 208	15 190	317 398	151 331	99 262	250 593

⁴ There may be a few small difference in village and household number with General Census as not all villages could be found in our GIS database (about 100 villages).

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

There is a difference of 80 565 customers between the total number of electrified households given by the Census (567 991), and the number of customers given by EAC Annual Report 2008. This “error” of 14% may be explained by the following factors:

- Unlicensed REEs not recorded by EAC
- Several households considered as one customer from the point of view of the operator (unofficial connections)

The first explanation is supported by the difference of 78 593 customers (almost all “missing” customers), between the number of rural customers given here (250 593) and the one presented by EAC during the SREP kick-off meeting (172 000).

Figures from 2008 have then been adjusted to 2010:

- Using linear increase of household connection rate in already electrified villages as well as population increase
- Assuming no new village have been connected between 2008 and 2010, as a conservative assumption


The result is shown on the following map and table.

Table 5: Electrification rates in 2010, updated from 2008 General Census

	Total			Urban			Rural		
All households	2 822 713			425 435			2 397 278		
Supply source	Grid	Mini-grid	Total	Grid	Mini-grid	Total	Grid	Mini-grid	Total
Electrification rate	19.1%	6.1%	25.2%	80.9%	4.3%	85.2%	8.1%	6.4%	14.6%
Electrified households	539 418	172 474	711 892	344 250	18 300	362 550	195 168	154 174	349 342

The overall electrification rate of **25.2%** comes close to the estimate given by MIME during the SREP kick-off meeting (26%).

Figure 11: Electrification status of villages in 2010




2.2.3 GEOSIM: priority to Development impact – selection of development poles

Rational planning approaches using modern tool such as Geographic Information Systems can fill this gap and pave the way for adequate policies and project identification. GEOSIM is thus seen as a relevant answer to these challenges, as it allows planners to quickly simulate sophisticated rural electrification scenarios, harnessing local renewable energy sources and maximising the impact of socio-economic development.

The overall objective of the planning process is indeed to answer the following questions – see annexes for details:

- Which villages should be electrified first to optimise socio-economic development in electrified areas ? *GEOSIM Spatial Analyst®* helps with the identification of priority areas to electrify (Development Poles)
- What is and what will be energy consumption in provinces villages? *GEOSIM Demand Analyst®* assesses consumption growth over the planning period
- Which technical options would be the most appropriate to supply the electric clusters built on the Development Poles? *GEOSIM Network Options®* supports identification of supply options to fulfil various scenarios objectives (grid extension, hydro, biomass and diesel options)
- What solutions remain for the villages left without conventional means of access to electricity in the near future? *GEOSIM Distributed Energy®* helps the planner with sizing and costing of provisional solutions for remote areas (PV kits, battery charging, pico hydro etc.)

Figure 12: GEOSIM planning process



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Based on two main inputs from the planner:

- Data collection on grid network, renewable energy potential as well as socio-economic aspects (cf. chapter 2.2 below)
- Clear planning objectives, under different scenarios (cf. chapter 2.3)

The main outputs of the planning study are thus:

- Grid extension strategies and costing within time, resource and physical constraints;
- A list of projects with elements of sizing (installed capacity, energy output over the planning period), costing (investment costs, lifecycle cost) and profitability assessment for a private entrepreneur. This list of project will be used as an operational investment plan and projects will be prioritised according to agreed criteria, so as to identify the most promising projects for further feasibilities, and start negotiations with possible investors.
- An assessment of the direct, as well as indirect beneficiaries of the projects (through increased access to the electricity service in nearby electrified Development Poles).
- Maps showing the location of various projects, allowing the planner to check for the spatial consistence of different scenario

The very novel feature of the GEOSIM approach is that it gives priority status to villages defined as “Development Poles” : the villages have been given an IPD⁵ score according to a set of criteria detailed in the related Annex. Then the villages with the highest IPD have been selected. The number of villages selected per province has been adapted to the total number of villages in each province. For most provinces, a proportion of 10% of villages has been considered as Development Pole, according to usual practices in other countries. However, for very small provinces with already high electrification rates, a slightly higher proportion has been taken.

Indeed, the whole idea is that over time, the trend is not for population to remain scattered, but to concentrate in areas and settlements with development potential. Hence, these settlements, which tend to be the larger ones, close to roads and where schools and health infrastructure is planned, where there is potential for income generation, should be given priority in terms of electrification.

A first list of Development Poles has been submitted to PDIMEs and slightly adjusted following their comments (some new Development Poles have been added and their actual electrification status has been updated), cf. list of Development Poles in annex.

Development Poles have then been ranked according to the population of their “hinterland”, i.e. the population, which can benefit indirectly from the electrification of the Development Pole, through improved socio-economic services (electrified schools, health centres and economic activities). This ranking has been used to then prioritise mini-grid projects. Other more traditional ranking criterion could have been investment costs, the levelized cost of kWh or the year of expected connection to the national grid for example.

⁵ Indicator for Potential Development, multi-criteria indicator reflecting the quality of socio-economic facilities available within a given village (cf. 2.2).

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

The final number of Development Poles is given in the following table:


Figure 13: Number of Development poles per province

Province	Ratio of DPs selected (%)	Number of DPs kept	Number of rural DPs	Grid electrified rural DPs in 2010	Off-grid electrified rural DPs in 2010	Non electrified rural DPs	Rural DPs outside PAGE
Kandal	10	108	92	40	30	22	3
Koh Kong	30	35	25	6	13	6	13
Preah Vihear	10	21	17	0	10	7	12
Kampong Cham	10	177	159	52	43	64	43
Ratanak Kiri	10	24	19	0	12	7	1
Kampong Thom	10	76	70	17	27	26	32
Banteay Meanchey	10	63	38	9	16	13	11
Takeo	10	112	108	22	31	55	6
Kracheh	10	25	18	5	6	7	2
Pursat	10	50	43	0	25	18	3
Siem Reap	10	91	69	18	21	30	23
Stung Treng	10	13	8	1	3	4	0
Svay Rieng	10	70	62	8	16	38	3
Mondul Kiri	10	9	9	2	4	3	5
Kampong Speu	10	136	112	19	12	81	1
Phnom Penh	10	69	2	2	0	0	0
Pailin	20	16	9	7	2	0	0
Kampong Chhnang	10	56	46	10	7	29	2
Prey Veng	10	114	104	5	27	72	7
Battambang	10	74	55	14	23	18	10
Otdar Meanchey	10	23	19	2	6	11	9
Kampot	10	48	39	9	10	20	0
Preah Sihanouk	10	11	6	5	0	1	0
Kep	20	3	3	1	1	1	0
TOTAL	10,3%	1424	1132	254	345	533	186
			100%	22%	30%	47%	

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 14: Location and electrification status of Development Poles.

The “high accessibility area” delineates remote areas, i.e. the 20% of villages located far from all Development Poles and suitable for decentralization electrification technologies (mini-grids or stand-alones).



2.3 THE THREE PLANNING SCENARII

The three scenarii aim to reach the policy objective for 2020, i.e. all villages would have access to an electricity service, either national grid, mini-grids or stand-alone systems. The three scenarii follow the same methodology, explained below, their only difference is the assumed speed of national grid expansion (as explained below) , in order to consider different situations of fund mobilisation and actual implementation.

The second main policy objective for 2030 (70% households having access to national grid or mini-grids) is reached only in the baseline scenario, but the two others come relatively close to it.

Baseline scenario: in this scenario, the projections made by EDC in terms of number of villages and km of lines are taken for 2015, 2020 and 2030 as achieved. These projections are in line with EAC targets of 80% national grid villages by 2020, and 95% by 2030.

Intermediate scenario: this second scenario assumes that the grid extension rate would be half as fast as in the baseline scenario, i.e. whatever villages would be connected in the baseline scenario by 2015 would now be connected by 2020 only. Likewise, villages connected by 2020 in the baseline scenario would be connected by 2030 instead.

Conservative scenario: the third scenario assumes an even slower grid extension speed because of limited fund availability, one quarter as fast as the baseline scenario, i.e. villages connected by 2015 would be connected by 2030 only.

Then, once the grid extension has been simulated, least-cost comparison of decentralised mini-grids solutions (mini hydro, biomass, and diesel) is performed in order to supply **all Development Poles** not covered by grid extension before **2015**. Please note that some hydro or biomass projects sometimes do not have any Development Pole in their surroundings, in this case the project is still included in the plan, but does not participate in the above mentioned objective. Hydro or biomass projects located too close (less than 2km) to the forecasted national grid in 2015 will be candidates for Independent Power Producer (IPP) projects, rather than isolated mini-grid projects.

The basis of the calculation principle is that villages continue to be supplied by a given local generation source, as long as the levelized kWh cost continues to decline.

If an existing diesel mini-grid is in conflict with a potential hydro or biomass project, then the latter projects are suggested to replace the previous diesel system. However, new diesel projects are not supposed to replace old ones. For all options, levelized kWh is also taken into account.

Finally, stand-alone systems (Solar Battery Charging Stations, PV for community facilities and Solar Home Systems) are considered:

- Solar Battery Charging Stations (BCS) will be installed in each village, which are not electrified by national grid or mini-grid projects by 2020, and where no BCS is currently operating. This will ensure that the political objective of 100% village having electricity supply by 2020 is met.
- Likewise, community PV systems are suggested in all villages, which are not electrified by national grid or mini-grid projects by 2020. Targeted facilities are schools, health centres, commune halls and pagodas.
- Finally, all rich households in these villages will be candidates for SHS. The share of rich households in each village varies from one province to another, as explained in 3.1.1.

Deployment of these stand-alone systems is assumed to happen progressively until 2020.

2.4 REVIEW OF SURVEYS AND DATA COLLECTION

2.4.1 Secondary data collection

A wide range of studies have been reviewed prior to data collection activities, and throughout the project lifetime. Major studies and reports considered include:

- The “Rural Electrification Strategy and Implementation Plan” undertaken by the World Bank to clarify to role of the various stakeholders of rural electrification in Cambodia (2010)
- The “Master Plan for Rural Electrification From Renewable Energy” by the Japanese cooperation (2006)
- Annual reports from EAC and EDC

A detailed list of references used is provided.

The following table summarizes the databases collected and entered into the SREP GIS database.

Given available information on power consumption patterns, socio economic infrastructure (schools, hospitals), population location and income levels, energy expenditures, it was finally not considered necessary to undertake a detailed demand survey. In some instances, a few household level questionnaires were implemented to calibrate and validate demand issues.

2.4.2 Agro-industry and rural industry survey

Following the creation of the nation-wide industry database from various sources of data (mostly PDIME databases), a survey has been conducted in agro-industries and rural industries for two purposes:

- To identify possible clients of rural electrification projects (“Special demands”)
- To identify possible sources of biomass residues for waste-to-energy (biomass) projects

In order to determine on which industries should the surveying efforts focus, data from the industry database has been validated with the following sources:

- PDIME interviews during regional meetings
- Website listing of land concessions from Ministry of Agriculture (MAFF), cross-checked with phone interview with PDIME, and data from MAFF
- Validation of data from previous surveys (REOREC and COGEN 3 projects) through direct phone calls

Candidates for the survey have been chosen as not directly in national grid areas or very close to it, and close to potential mini-grid renewable energy projects whenever possible

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Table 6: Collected databases

Category	Name of data	Format of data	Source
Admin	Province, district and communes boundaries	GIS data	Department of Geography, 2005
Socio-economic	Demographic information	GPS coordinates of villages and population	08 Socio-economic Village database (MoP) linked to a GIS database established in 98
	Health facilities	GPS coordinates, type (health centre, hospital...), name & villages covered	Ministry of Health (MoH)
	Drinking water facilities	GPS coordinates or village, type (pumped, well, pond...)	Data collected during CAP REDEO project, updated with 2008 village database
	Education facilities	GPS coordinates, type (primary, secondary, high school...), name and villages covered, number of students	Ministry of Education Youth and Sports (MoEYS)
	Economic facilities	Location of markets and Micro Finance Institutions (MFIs)	Distance to market & nearest road updated with 2008 village database, location of MFIs collected from ACLEDA and AMRET.
	End-user demand data	Household consumption per class, breakdown of classes, productive use consumption, willingness to pay	CAP REDEO survey, supplemented with EAC, EDC, UNDP and NCDD databooks
	Special demands: SMEs, industries & agro-industries (power demand above 10kW)	List of about 20,000 businesses with location, type of business, capacity of engine, electrification status, number of staff, capital etc.	Some data from Dep. Of Industry (Phnom Penh), but most from Provincial Dep. Of Industry (PDIMES)..
Power infrastructure	HV and MV lines existing and planned	GIS data, voltage (kV) and expected date of completion for planned lines	Existing MV lines from EAC & EDC Planned MV lines from EDC extension plans (provisional results in 13 provinces) Existing and planned HV from EDC
	Substations existing and planned	GPS coordinates, capacity (kVA) and expected date of completion for planned substations	EDC
	Rural Electricity Enterprises	GIS data of licensed REE areas and location of non licensed REE + data on number of customers, installed capacity, energy produced, type of engine, tariff etc.	2010 EAC licensee zones collected in GIS format and additional data taken from EAC annual reports Non licensed REEs collected in 13 provinces from PDIMES
	Electrified areas	List of villages electrified by EDC or REE	Information already included in Socio-economic Village database, and cross checked with feedback from PDIMES
Renewable energy potential	Potential Hydro sites	List of 65 potential hydro sites between 50kW & 2MW, & 90 below 50kW, with GPS coordinates & power output	JICA, MIME, meetings with PDIME and SREP field surveys
	Agro-industries able to produce residues for electricity generation	List of agro-industries, including: rice mills, cassava starch factories, palm oil plant, corn silos, sugarcane mills and piggeries	PDIME data (database and phone calls), SREP field survey. Previous projects (COGEN 3 study (2003), CAP REDEO (2008), REOREC (2005)) Ministry of Agriculture Fisheries and Forestry (MAFF) -
Other	Roads	GIS data with road surface type	JICA / Ministry of Public Works and Transport (MPWT) 2002
	Land mines	GIS data of land mined areas	CMAC
	Bridges on main rivers	GIS of existing & planned bridges	MPWT
	Water bodies	GIS data	JICA 2002
	Forests and protected areas	GIS data	UN World Database on Protected Areas (WDPA)

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Specific criteria for choosing the different types of activities are:

Ice factories: above 1000t production or 8000 bars (@130kg/bar)

Brick kilns: no threshold could be defined because the production figures in the PDIME database are given in different units, not specified

Rice mills:

- All large rice mills with yearly milled rice production above 2,000 t, except in areas already heavily surveyed by COGEN 3 or REOREC (unless the rice mill is exceptionally large, in which case the rice mill has been surveyed again to check for possible recent evolutions)
- Groups of medium sized rice mills (with production between 200 and 2,000 t), totalling at least 2,000 t/year production

Other agro-industries: given the relatively small number of significant agro-industries outside the rice mill category, all identified agro-industry at the time of the survey have been surveyed whenever possible.

MIME and PDIME staff have been trained on the survey questionnaire on real and fake industries, and then sent in teams throughout the country, to interview more than 160 industries. The breakdown is provided below:

Table 7: Number of surveyed industries

Name of province	Activity							
	Rice mill	Ice factory	Brick making	Cassava factory	Cow farm	Pig farm	Sugar cane mill	Palm oil factory
Banteay Meanchey	15		1					
Battambang	23							
Kampong Cham	10	5	2	1				
Kampong Chhnang	6	4						
Kampong Speu	1					1		
Kampong Thom	7							
Kampot	1	2						
Kandal	5	3						
Koh Kong		4	2				1	
Mondul Kiri		2						
Preah Vihear		2						
Prey Veng	8	3	2					
Pursat	8	4	3			1		
Ratanak Kiri					1			
Siem Reap	4	3						
Stung Treng		3	1					
Svay Rieng	1	1	1					
Takeo	7	4						
Preah Sihanouk								1
Siem Riep	1	1						
Kratie		1						
Total	97	42	12	1	1	2	1	1

Data from an additional 85 agro-industries (rice mills, corn silos and piggeries) has been analysed too and taken from previous surveys of the REOREC and COGEN 3 projects. The relevance of such data a few years after the surveys has been checked by calling directly each of the surveyed industries.

The results of the survey in terms of special demand and biomass potential assessment are explained further.

2.4.3 Data collection from EDC

The following data have been collected from EDC:

- Excel table of investments costs and achievements in terms of connected villages and households, for three periods: 2011-2015, 2016-2020 and 2021-2030. All figures are provided with a breakdown by province and by component (MV, LV, transformers, meters etc.)
- GIS data of existing and planned 22kV lines until 2020, with type of line (main line or sub line) and ownership (EDC or REE)

This data has been very helpful in understanding the scale of the grid extension programme, and to determine which areas are likely to remain left out after it has been carried out. However, a few information were still missing in order to simulate our mini-grid projects:

- The list of villages already connected and to be connected in the future
- Some indication of the priority order of the construction of planned lines (which lines are likely to be commissioned before the others)
- Location of future lines for the 2021-2030 period

These missing elements have been thus simulated with the GEOSIM® software. Efforts have been made to fit to EDC estimates in terms of number of households connected and overall budget, at least for the 2011-2020 phase. As these elements were finalised only after submission of the draft report, we note here the major evolutions in assumptions between the draft and final reports:

- Maximum connection rate reached in a given electrified village decreases from 98% to 70%
- Meter cost has been increased to 50 USD
- LV unit cost has been increased to 15000 USD/km
- Transformers costs have been increased to 46 to 154 USD/kVA (depending on size)
- Customer density after 2020 has been reduced to 50 clients/km LV

However, these assumptions taken individually are not always in line with the ones made by EDC, because of the following reasons:

- Customer density taken by EDC for the whole 2011-2030 period remains roughly around 20 clients/km LV, which is found very low compared to other estimates (66 in remote areas by JICA, about 50 by the WB RE Strategy) and feasibility studies carried out by SREP
- Length of MV lines in Excel tables is found to be slightly higher than the actual length calculated from the GIS data.
- On the other hand, unit costs for LV and MV are found low for utility-grade equipments: at 7700 USD/km and 14700 USD/km respectively (all included).

Nevertheless, some difference remain in our results, mostly for the 2021-2030, because of:

- Very different population growth rates: 3.8% for EDC, 1.2% for SREP (suggested by MIME), to be compared with the historical trend of the past 10 years of 1.5%
- Different lengths of MV lines. The SREP simulation assumed that the national grid would densify (connect villages already close to the grid). Apparently, EDC did not follow this approach, as the additional km of MV to be added in the 2021-2030 phase is found very high.

3 DEMAND ASSESSMENT

3.1 DEMAND CATEGORIES

In this chapter, main assumptions for the load forecast are presented at the national level (average values). However, most parameters have been set at different values for each province, to better reflect their particularities. Provincial results are summarised at the end of the present report and detailed in a set of annexes.

In a previous study conducted by IED with MIME on European Commission funding, a number of assumptions were discussed and great depth and agreed upon, also based on surveys. For the purpose of the present study, the assumptions were reviewed and broadly taken on board by the Ministry – hence the repeated reference to this study.

3.1.1 Domestic market segmentation and demand

In the absence of recent income segmentation study at the national level, the following approach has been chosen:

Three main classes of households are defined: poor (including poor classes 1 & 2 according to the definition of IDpoor project by MoP), medium and rich

Proportion of poor households in rural areas of each province has been determined from Commune level figures extracted from NCDD district data books (NCDD, 2009). These estimates are partly derived from findings of IDpoor project in provinces where it has been conducted, and partly from other socio-economic indicators.

Then the shares of medium and rich households have been determined with the following rule: rich household amount to **15%** of non poor households on average. This is the proportion taken in CAP REDEO project in Kampong Cham (CAP REDEO, 2008). As a comparison, this proportion is 12% in Svay Rieng (UNDP, 2008), 20% in Kampong Speu (UNDP, 2008), 19% in Kampong Thom (PDIME, 2010). NB: definition of households classes from one source to another are not the same, as there is no universally accepted definition for them. The result at national level is as follows:

Table 8: Relative weight of classes in year 1

	Poor & very poor households	Medium households	Rich households
National (weighted) average	30%	60%	11%
Poorest province	44%	69%	12%
Richest province	19%	47%	8%

Then assumptions have been made to determine the evolution of household classes over the planning period. Again, data from NCDD district data books in 2004 have been used, and compared to figures for 2009 to determine the average poverty reduction rate per year, and thus extrapolate poverty levels 20 years in the future. Rich and medium classes have then been calculated using the same assumptions (rich accounting for 15% of non poor households).

Table 9: Relative weight of classes in year 20

	Poor & very poor households	Medium households	Rich households
National (weighted) average	13%	74%	13%
Poorest province	33%	82%	14%
Richest province	4%	57%	10%

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Ownership of appliances has been calculated from the CAP REDEO survey and completed with data from the pre-feasibility study in the JICA Master Plan.

Table 10: Ownership of appliances (average number per household)

Appliance	Poor	Medium	Rich	Weighted average ⁶
Lighting	1.87	3.36	4.29	3.01
TV & Video-recorder	0.80	1.90	2.41	1.62
Radio-cassette	0.80	0.90	1.10	0.89
Rice cooker	0.08	0.11	0.13	0.10
Iron	0.00	0.18	0.50	0.16
Fan	0.00	0.77	1.90	0.66
Refrigerator	0.00	0.09	0.26	0.08

Nominal power ratings⁷ are indicated below:

Table 11: Nominal power rating of appliances

Appliance	Power rating (W)
Lighting	16 ⁸
TV & Video-recorder	100
Radio-cassette	20
Rice cooker	300
Iron	800
Fan	100
Refrigerator	150

Consumption load curves of appliances have been designed from CAP REDEO survey and adjusted to match the figures of average consumption per household suggested in the SREP project meetings. Resulting demand of each household class is presented in the following table:

Table 12 : Specific demand of one household for each class

	Poor	Medium	Rich	Weighted average
Peak demand (W)	90	259	470	232
Consumption (kWh/month)	9	39	75	34.1
Consumption with technical losses (kWh/month)	10	43	83	37.9

The peak demand is in line with assumptions currently made by EDC to size its distribution transformers (250 VA per household on average, i.e. about 200 W).

The monthly consumption is slightly lower than JICA and WB Strategy estimates of 50kWh, but constraints on ability to pay show that 34 kWh/month is already difficult to achieve (see 3.4.4). The average consumption per customer including losses was 23kWh in 2008 according to EAC report.

⁶ Average weighted by national average proportion of each household class

⁷ Please note that load curves of a given appliance do not necessarily reach the nominal power rating since these curves show the average power demand of an appliance and it often happens that the appliance is used only in a fraction of households at a given time of the day.

⁸ This is the average power rating found during the CAP REDEO survey.

3.1.2 Social services

Average number of health centres and schools per rural village have been determined from the commune database integrated into GIS (MoP, 2008). The number of facilities per villages indicated in the table below are national averages, the actual numbers used for each province⁹ are provided in the provincial result annexes. The school category covers the following facilities in the database:

- Formal pre-schools
- Primary schools
- Lower secondary schools
- Upper secondary schools
- Private schools

Number of clients for water pumping, and meeting halls has been taken equal to 1 for all villages. However, their specific consumption is proportional to the population of the village. The resulting number of activities, according to the size of each village, is thus:

Table 13: Number social services per village for different population ranges – national average

Population range	Water pumping	Meeting hall/Pagoda	Schools	Health centres
500-1000	1	1	0.42	0.01
1000-1500	1	1	0.73	0.02
1500-2000	1	1	1.09	0.03
2000-2500	1	1	1.46	0.05
>2500	1	1	1.69	0.05

The specific consumption of each of these facilities in the 24h supply scenario are:

Table 14: Specific demand of public services, not including distribution losses

	Water pumping	Meeting hall/Pagoda	Schools	Health centres
Monthly consumption	1200 kWh/1000p	72 kWh/1000p	44 kWh/connection	72 kWh/connection
Peak demand	4000 W/1000p	400 W/1000p	150 W/connection	150 W/connection

3.1.3 Productive uses and small businesses

Average number of small shops and other tourism based activities per rural electrified village have been determined from the commune database (MoP, 2008). This category covers the following activities in the database:

- Bicycle and motorcycle repairs places
- Electronic tool repairs places
- Alcohol refinery places
- Other handicraft places (excluding furniture)
- Small-scale services (hairdresser, phone service, massage, Karaoke...)
- Small-scale food shop businesses (Food, groceries, drink shop...)
- Pharmacies and small drug stores
- Hotels
- Guest houses
- Restaurants

⁹ These have been derived from national averages by using a ratio with number of each activity per 1000 inhabitant.

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Small industries such as furniture handicraft and metal workshops have been taken from the village database (MoP, 2008), under the category “Other machines” (excluding rice threshers) Likewise, battery charging stations have been taken from the village database (MoP, 2008)

In the case of small rice mills (below 45 HP – average 16 HP or 12 kW), the Commune Database 2008 has been found to be more comprehensive than the industry database (52,190 mills vs. 12,349). Therefore the Commune Database has been used specifically for this category of demand, and the average of 16HP (12kW) has been taken as installed capacity. However, these end-users have not been considered in the study, and the number indicated below are therefore provided for information only. The resulting number of activities, according to the size of each village, is thus:

**Table 15: Number of productive uses per village for different population ranges
(national average)**

Population range	Misc. shops and tourism activities	Small industry (carpentry, metal works)	Battery charging	Small rice mills (below 45 HP)
500-1000	1.58	0.43	0.30	0.30
1000-1500	3.67	0.24	0.53	0.53
1500-2000	5.80	0.71	0.85	0.85
2000-2500	7.94	1.07	0.98	0.98
>2500	11.28	1.39	1.31	1.31

Specific demand of these productive uses are taken as follows:

Table 16: Specific demand of productive uses, not including distribution losses


	Misc. shops and tourism activities (hotels, restaurants)	Small industry (small mills, carpentry, metal works)	Battery Charging	Small rice mills (below 45 HP)
Consumption (kWh/month)	146	540	360	312
Peak demand (W)	300	2 000	2000	12000

3.2 HYPOTHESES ON TRENDS

Main assumptions for connection rates and consumption growth rate had been discussed with main power sector stakeholders during the CAP REDEO project. Connection rate assumptions for households have not been changed, as they seem to be confirmed by the figures calculated from the village database, combined with the GIS layer of REE licenses in 2010 from EAC:

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 16: Evolution of average household connection rates in rural areas, with the number of years since the EAC license has been granted¹⁰



The above chart shows a steady increase from 35% to full coverage after 10 years of electrification. For its planning activities, EDC expects 50% connection after 4 years, which is close to the above assumption: 60%. However, the EDC plans expect the connection rate to reach a plateau at about 70%, which appears sensible considering that villages included in the plans are likely to feature a significant proportion of households, which cannot be reached by the grid.

However, consumption growth rates per customer have been slightly reduced to 4% p.a., to fit with current progression calculated from EAC data:

Table 17: Consumption in rural areas (calculated from EAC presentation to SREP kick-off)

Year	Number of consumers in rural areas	Consumption (MWh)	Average consumption per client (kWh/month)	Average geometric annual growth
2006	102400	93587	76.2	3.43%
2008	172000	168177	81.5	

¹⁰ NB: these connection rates may be slightly optimistic, as the actual number of years since electrification may be bigger than the number of years since EAC license (the license may have been granted several years after the REE has started operating)

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

The previous assumption of 7% growth would be closer to the national average, including urban areas:

Table 18 : Nation-wide consumption figures (calculated from EAC annual reports)

Year	Number of consumers	Consumption (MWh)	Average consumption per client (kWh/month)	Average geometric annual growth
2005	306176	858356	233.6	7.12%
2006	358270	1057158	245.9	
2007	415141	1349122	270.8	
2008	487426	1664395	284.6	

Table 19: Growth hypotheses

Years:	1	1-10	10	10-20	20
Connection rates					
Households	35%		70%		70%
Infrastructures and services	80%		100%		100%
Consumption growth rates					
Households		4.00%		0.00%	
Infrastructures and services		4.00%		4.00%	

Villages are considered not scattered, i.e. all households of a village are eligible for connection if the village is electrified.

The population growth rate in rural areas outside Phnom Penh is taken at **1.2% per year as a national average** (actual figures for each province are different). The General Census from 2008 found an average growth rate of 1.5% over the last 10 years, but a new figure of 1.2% has been suggested (MIME 2010). Moreover, some extreme values have been found in some provinces, such as 9.7% in Odtar Meanchey, or 0.46% in Kampong Cham. These figures likely result from migration flows, not demographic growth. Therefore they may not be extrapolated safely for the next 20 years, that is why we decided to divide the distance of each value to the mean (1.2%), by a factor of 4. This results in the same mean value at national level, while still keeping some level of provincial disparities. NB: this average of 1.2% growth rate per year is much lower than then 3.8% taken by EDC, and this will naturally have a significant impact on the planning results.

On average there are **4.95 people per household** in rural areas (Village database, 2010).

Technical losses¹¹ are set equal to **10%**, as suggested by EAC for well designed systems (with total losses, including non-technical, averaging 15% to 20%). Naturally, actual losses may be higher in existing systems. However, the aim of the load forecast here is to focus on new places to electrify.

¹¹ Taking into account distribution losses but not commercial losses, due to faulty meters or illegal connections.

3.3 LARGE POWER USERS (SPECIAL DEMANDS)

Special demands are defined as large industrial users, which could benefit from Rural Electrification projects (either grid or off-grid), thereby increasing the benefits of electrification and usually improving the economic viability of projects. They may be located inside or outside villages.

A dedicated survey has been conducted to assess the potential electrification of large power users in rural areas, mostly large agro-industries, ice factories and brick kilns. In total, about 160 industries have been surveyed. The following chapters deal with the results of this survey in terms of assessment of special demands throughout the country.

e) Number and location of special demands

- Besides surveyed industries, all other industries available in the industry database have been considered as well. A set of screening criteria have been applied to this database, in order to remove unwanted factories:
- They must be still running (the survey revealed quite a number of factories from the PDIME databases, which have been stopped for various reasons)
- They must be located in a rural area (as defined in 2.2.1)
- They must not be already connected to the grid (but the ones connected to mini-grids are accepted). Very few industries fall within this category.
- They must not be one of the potential candidates for captive use biomass projects (
- We must know their geographical coordinates or at least their village
- We must know their peak demand (cf. next chapter)

The resulting number of special demands considered, is thus:

Table 20: Number of activities for different types

Category	Total number in database	Total number considered after screening
Rice mills except small	672 ¹²	429
Ice factories	229	148
Brick kilns	382	308
Palm Oil factories	1	1
Cassava	14	11
Corn	5	3
Piggeries	9	7

Most special demands identified are rice mills, ice factories and brick kilns, and are located in densely populated areas where the grid is already there or coming soon. Therefore, their impact on off-grid projects is relatively small but can still improve their financial viability in a few cases. The following map shows all special demands identified:

¹² NB: the Commune Database 2008 states that there are in total 1800 large rice mills in the country, which is significantly higher than the figure indicated in this table. However, without a clear definition of "large" rice mills given by the Commune Database, it is not possible to determine whether this discrepancy is abnormal or not.

f) Characteristics of special demands

During the field survey, the real peak demand has been estimated (usually lower than installed capacity, as sometimes not all engines are running at the same time, and engines not always deliver their rated capacities), although it is usually hard to define accurately. A simplifying assumption has been made, that the installed capacity indicated in PDIME databases is equivalent to the peak demand (which seems to be generally the case after comparison between survey results and PDIME figures).

All industries have been grouped in categories of similar peak demands. The following table gives the resulting peak demands for the different categories, as well as the cumulated capacity of each category.

Table 21: Peak demands of different categories of special demands

Type	Category	Total considered	Peak demand (kW)			Cumulated peak demand (MW)
			Min	Max	Avg	
Rice mill	Rice mill 1	220	38	71	56	12.2
	Rice mill 2	111	73	101	88	9.8
	Rice mill 3	29	105	128	115	3.3
	Rice mill 4	23	135	165	150	3.4
	Rice mill 5	10	173	210	196	2.0
	Rice mill 6	31	212	270	245	7.6
	Rice mill 7	3	278	315	296	0.9
	Rice mill 8	2	338	375	356	0.7
	Total rice mill	429	38	375	93	40.0
Ice factory	Ice factory 1	80	2	99	59	4.7
	Ice factory 2	53	109	178	124	6.6
	Ice factory 3	9	197	301	254	2.3
	Ice factory 4	6	316	392	350	2.1
	Total ice factory	148	2	392	106	15.7
Brick kiln	Brick kiln 1	285	8	18	12	3.4
	Brick kiln 2	11	23	41	30	0.3
	Brick kiln 3	6	45	60	54	0.3
	Brick kiln 4	5	66	75	71	0.4
	Chhay Eng Brick Kiln	1	127	127	127	0.1
	Total brick kiln	308	8	127	15	4.6
Cassava	Cassava 1	7	11	11	11	0.1
	Cassava 2	4	18	60	32	0.1
	Total cassava	11	11	60	19	0.2
Piggery	Piggery 1	3	36	40	38	0.1
	Piggery 2	4	180	188	184	0.7
	Total piggery	7	36	188	121	0.9
Corn	Corn silo 1	1	75	113	93	0.1
	Corn silo 2	2	240	250	245	0.5
	Total corn silos	3	75	250	194	0.6
Others	MRT Palm Oil	1	784	784	784	0.8
	Total others	1	784	784	784	0.8

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Answers from the surveys allowed detailed assessment of other characteristics of the main types of special demands, beyond the mere peak demand:

- Average load factor during operation hours (%)
- Time of operation (hours in the day)
- Seasonality (months of the year and days of the week)

The summary of average demand characteristics of all industries considered is shown below:

Table 22: Detailed characteristics of special demands


Type	Category	Peak demand (kW)	Avg. load factor during operation hours (%)	Hours of operation per day	Seasonality	
					Days per week	Months per year
Rice mill	Rice mill 1	56	34%	7.0	6.9	9.6
	Rice mill 2	88	34%	6.0	5.8	8.4
	Rice mill 3	115	34%	7.2	5.8	9.8
	Rice mill 4	150	34%	7.7	5.8	10.2
	Rice mill 5	196	34%	7.0	6.8	8.4
	Rice mill 6	245	34%	7.0	6.3	6.5
	Rice mill 7	296	34%	6.0	5.5	6.3
	Rice mill 8	356	34%	10.0	3.0	6.0
	Total rice mill	93			6.4	8.9
Ice factory	Ice factory 1	59	25%	20.0	6.8	10.1
	Ice factory 2	124	25%	22.0	7.0	10.5
	Ice factory 3	254	25%	22.0	7.0	12.0
	Ice factory 4	350	25%	24.0	7.0	12.0
		Total ice factory	106			6.9
Brick kiln	Brick kiln 1	12	31%	9.0	6.7	7.8
	Brick kiln 2	30	31%	6.5	7.0	9.0
	Brick kiln 3	54	31%	8.0	6.0	7.0
	Brick kiln 4	71	31%	8	6.0	7.0
	Chhay Eng Brick Kiln	127	31%	8	7.0	12.0
		Total brick kiln	15			6.7
Cassava	Cassava 1	11	20%	24.0	7.0	3
	Cassava 2	32	20%	24.0	7.0	3
		Total cassava	19			7.0
Piggery	Piggery 1	38	53%	24.0	7.0	12.0
	Piggery 2	184	53%	24.0	7.0	12.0
		Total piggery	121			7.0
Corn	Corn silo 1	93	40%	18.0	7.0	4.0
	Corn silo 2	245	40%	18.0	7.0	4.0
		Total corn silos	194			7.0
	MRT Palm Oil	784	90%	24.0	7.0	12.0

All characteristics mentioned in the table above are direct averages from surveys within each category of industry.

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

The seasonality of rice mills, ice factories and brick kilns is illustrated below:

Figure 18: Seasonality of main special demands throughout the year



All these characteristics have been converted into average daily load curves, and entered into GEOSIM.

Important note on load factors: the load factor indicated in the table above has been calculated from the usual time of engine/genset operation as stated by the respondents (hours per day and days per week), as well as the average monthly consumption of fuel (and electricity if relevant), and the peak demand. To smooth statistical errors linked to the small number of industries surveyed in some categories, averages have sometimes been made over groups of similar industries. In most cases, this figure is found to be very low, even for industries which are supposed to have a constant load close to their peak demand during their time of operation, such as ice factories and rice mills. Two possible explanations may be given:

The schedule of operation provided (hours per day, and days per week) is only indicative, and the industry probably runs for shorter periods of time in reality. This may be especially the case for rice mills, and even more small ones, which do not always manage to get a reliable supply of rice to process (30% of rice millers stated that they do not run regularly throughout the week).

The peak demand, mostly based on installed capacity of engines, may be overestimated. This is caused by oversizing of engines, apparently a regular practice. A survey conducted in large rice mills for the COGEN 3 project found that on average power requirements of rice mills were only **58%** of the installed capacity. Estimating the real peak demand (maximum load of engines or gensets in actual operation) was however outside the scope of the survey, therefore possible errors in estimating this parameter can only be adjusted by using the resulting low load factor in creating our typical daily load curve.

Both factors probably play a role in explaining these results, but their respective importance is hard to assess. If the first one accounts for most of the phenomenon, then it can prove challenging for electricity operators, who will have to size their generation facilities, transformers, conductors etc. according to a very high peak demand, while selling very few kWh to recover their costs.

3.4 RESULTS

3.4.1 Load forecast results per province

These demand figures are related to rural areas only. Even though special demands (large rural power users) have been included in the calculation, their urban equivalents (such as garment factories) were outside the scope of this study and have thus not been considered. Besides, urban domestic customers have a much higher ability to pay, enjoy lower tariffs, and thus have a higher consumption than in rural areas. Therefore, total demand is expected to be significantly higher.

Overall, in 2030, Provinces are expected to represent the same proportion of national demand as in 2010. Over the 20 year period, demand will be multiplied by 3.3, which means that one will be well beyond the “doubling every ten years” rule of thumb. This is explained by the low level from which one is starting, but of course, will only be achievable in reality if the tariffs and connection fees are affordable...

Table 23: Rural demand per province (GWh/year)

Province	Rural Population (2008 census)	Demand in 2011 (GWh/year)	Demand in 2030 (GWh/year)
Banteay Meanchey	533 289	42 814	140 066
Battambang	816 895	62 571	213 577
Kampong Cham	1 707 950	119 892	373 638
Kampong Chhnang	442 484	30 939	98 497
Kampong Speu	691 448	42 378	152 110
Kampong Thom	639 810	44 197	143 862
Kampot	578 698	42 154	135 727
Kandal	1 117 681	93 351	298 842
Koh Kong	112 100	8 809	28 110
Kracheh	284 957	25 301	86 235
Mondul Kiri	53 913	4 003	15 495
Preah Vihear	164 993	10 626	37 225
Prey Veng	1 094 584	69 585	224 284
Pursat	384 968	23 992	78 482
Ratanak Kiri	130 521	9 225	33 963
Siem Reap	738 147	56 665	182 091
Preah Sihanouk	103 924	12 856	42 078
Stung Treng	93 013	6 153	22 499
Svay Rieng	544 871	35 194	111 845
Takeo	949 964	61 404	195 615
Otdar Meanchey	168 347	13 619	58 128
Kep	28 790	2 325	7 559
Pailin	52 059	4 688	24 220
Total	11 433 406	822 741	2 704 148

The following maps illustrate these results at the province and district levels.

Figure 19: Province level demand





Figure 20: District level demand



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

The evolution of power consumption for the same size of village in different provinces is shown on the chart (¹³). The differences are caused mostly by two factors:

- Different specific consumptions (average consumption per customer)
- Different numbers of households and services

Having lower living standards, Preah Vihear has naturally lower demand than other provinces, but the difference is not so significant. This is because we are comparing villages of same size, while actually villages of about 1000 inhabitants in Preah Vihear are much less frequent than in Battambang for example. If we compare the results for villages according to the average population size of each provinces, the chart becomes:

Figure 21: Load forecast for villages of 1000 inhabitants in different provinces





Figure 22: Load forecast for average villages in different provinces, having the average village population in each corresponding province




¹³ The results of the load forecast for different sample villages will be shown in this section. All fictional villages feature 1000 inhabitants in 2008 (last census), but they are located in different provinces, so as to assess regional differences.

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

In the particular case of Otdar Meanchey, demand increases significantly compared to other provinces after year 10, mostly because of relatively higher expected population growth rate. However, in terms of average consumption per customer, the situation is quite different - this chart shows differences between provinces, which are more in line with the differences in living standards.

Figure 23: Average consumption per customer for villages in different provinces with 1000 inhabitants



3.4.2 Family scale rice mills

To assess the impact of including small-scale energy intensive productive uses in the load forecast, we will take as an example the load forecast of a 1000 inhabitant village in Preah Vihear, with 50% of family size rice mills (12kW on average) connected to electricity (4 out of 8).

Figure 24: Comparison of consumptions for a village of 1000 inhabitants in Preah Vihear, with and without small rice mills





Figure 25: Comparison of peak demands for a village of 1000 inhabitants in Preah Vihear, with and without small rice mills



As shown above, the impact of adding the rice mills is rather small on the overall consumption, but much more significant on peak demand. This is caused by the very low load factor of rice mills. The resulting risk and additional investments involved for the electricity operator (in generation and distribution), and very low associated benefits (energy sales) clearly demonstrate that connecting these small rice mills is not in his interest.

Moreover, the question remains whether all these small rice mills would really switch to electricity, as it would require significant investment costs from them and a sufficiently reliable electricity service.

Therefore, small rice mills will not be considered in the load forecast.

3.4.3 Typical daily load curves

Overall, regarding load profiles, one can notice a slight evolution of the shape of the load curve over the planning period. The base load is indeed much higher in proportion during the first year, because of our assumption on connection rates, assuming that non household customers would connect much faster than domestic ones. Therefore, the load factor goes down from **40%** in year 1 to **35%** in year 20, as domestic demand continues to grow.

The following charts show the average daily load curve for a sample village of 1000 inhabitants in Preah Vihear province (the shape does not vary significantly in other provinces).

Of course, what happens in reality will depend on how economic growth will occur in these areas, with industry and services. However, at this point in time, it is difficult to make assumptions other than the ones we have made.




Figure 26: Average daily load curve in year 20 for a village of 1000 inhabitants




Figure 27: Average daily load curve in year 1 for a village of 1000 inhabitants

3.4.4 Discussion on ability to pay and issues for the tariff structure.

Demand in most Cambodian rural areas is usually heavily constrained by the high prices of electricity, i.e. people don't spend on electricity to meet all their needs, but to fit within their allowed budget for the electricity bill. Therefore, the price elasticity is very high, meaning that for example dividing the electricity tariff by two would automatically multiply by two the consumption of households.

Discussions on the ability to pay a certain tariff, or rather the ability to consume a certain amount of electricity, should therefore start from an accurate assessment of the affordable monthly electricity bill.

The UNDP/GERES study in this regard is interesting, as it provides some figures for their four classes of households (based on housing standards) in Kampong Speu and Svay Rieng provinces. There are usually two ways of calculating ability to pay:

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

- Percentage of total income: a share of 10% is usually taken, although it normally includes other forms of energy (not only electricity). Therefore this method tends to overestimate the real ability to pay.
- Substitutable bill: the expenditure on forms of energy deemed substitutable by electricity, such as kerosene, battery lighting and candles are added to have an estimate of the avoided costs after electrification. Usually, households are willing to spend more than the avoided costs, therefore this method tends to underestimate the real ability to pay.

The resulting figures are as follows:

Table 24: Ability to pay figures from UNDP/GERES study

Household class	Poor & very poor	Medium	Rich
10% of household budget (USD)	2.3	4.8	9.8
Substitutable bill (USD)	2.3	2.5	4.4

With the first method and assuming each household class has the same connection rate as the others (which is conservative, as normally richer households have faster access to the electricity service), the average ability to pay would be **4.6 USD/month**.

Other figures given by other sources are:

- JICA Master Plan (2005): **3 to 5 USD/month**
- EAC Annual Report for the year 2008: **9 USD/month** (calculated average including non household customers as well)
- WB Rural Electrification Strategy (2010): **7.5 USD/month**
- SREP survey in villages potentially eligible for hybrid PV/diesel systems: **5 USD/month**

By taking an average of all above figures, to 2010 values, it would amount to **6.4 USD/month**. To meet the expected average consumption per month (34.1 kWh/month), the tariff would need to be about **18.7 UScts/kWh**. This is quite in line with the 15 UScts/kWh given by the WB Strategy, and much lower than the current average in rural areas according to data from EAC Annual report (50 UScts/kWh). Moreover, an average growth of household income of **2.5% per year** will be necessary to keep up with the expected growth in consumption, if we assume the tariff remains the same over the next 10 years.

Therefore, if we are really to reach the expect levels of consumption, in the load forecast which is 34,1 kWh / month / household, clear thought will have to be given to the tariff policy.

Indeed, if average monthly expenditure of 6,4\$ works out to a reasonable 18,7 USc/kWh in the Cambodian context, clearly some households would not be able to afford this.

4 ASSESSMENT OF SUPPLY OPTIONS

Generation on the grid will not be covered in this study, as the share of RE in the total system is relatively small, under 10%. The main focus will be on the sub-transmission (medium voltage) network, as it is the determining factor for electricity access in rural areas.

4.1 NATIONAL GRID

By combining GIS databases of MV lines from EAC, MIME and EDC planning offices, we have produced the resulting map of existing 22kV and 35kV network. All villages within 2km of these existing lines, which are considered as electrified by the 2008 General Population Census, are considered as interconnected with this network. All electrified villages in Phnom Penh and Kep provinces have been considered interconnected as well.

Data for MV extension plans until 2020 has been collected from EDC, which are considered as high priorities under the ongoing grid extension programme, financed by various donors (ADB, AusAID, China Exim Bank and World Bank +/- 200MUSD committed to date, and a total of +/- 300 MUSD under discussion). Coverage rates have been gathered as well, for different time horizons (2020 and 2030).

All villages within 2km of the planned lines for 2020 have been considered as targeted by the grid extension programme, which was roughly consistent with the number of villages indicated in EDC plans, but slightly lower. The missing 564 villages to reach 80% village coverage in 2020 as stated by EDC and EAC have been simulated using the GEOSIM least-cost optimising algorithm: villages connected first are the ones with the highest Net Present Value over 20 years.

Equation 1: Net Present Value formula for grid extension optimisation

$$NPV = \sum_{i=1}^{20} \frac{Benefits(i) - Costs(i)}{(1+r)^i}$$

With:

Benefits: Energy sold multiplied by 23.4 UScts/kWh (total average cost of grid according to World Bank RE strategy)

Costs: Including cost of generation and transmission (13 UScts/kWh), MV extension (20,000 USD/km), LV lines (15,000 USD/km and a density of 70 customers/km LV line before 2020 and 50 customers/km after 2020), transformers (between 46 to 154 USD/kVA, cf. 4.3) and meters (50 USD/meter). All costs are in constant prices (not escalated with inflation).

r: Discount rate, taken at 6%


This algorithm has then been applied to prioritise the grid extension until 2020, in order to understand which villages are likely to be connected by 2015, an important input to determine our off-grid potential as explained in 2.3.

Beyond 2020, further simulations have been done to reach the 2030 planning target (95% of grid connected villages), using the same optimisation algorithm. This approach tends to favour larger and denser settlements located close to the grid, which may not be in line with the backbone extension plans considered as a short term strategy by EDC. However, since this simulation is applied after the main backbones are extended, it is believed to be an acceptable estimate of grid extension behaviour (after extension of backbones, the utility typically tries to densify its network with profitability in mind). The following maps present:

- Map of the existing 22 kV lines;
- Proposed MV line extensions by EDC;
- Short term transmission and sub-transmission plans;

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 29: Proposed MV line extensions by EDC



4.2 OFF-GRID AREAS

As the national grid is expanding quickly, the definition of grid and off-grid areas where mini grid and stand alone options make economic sense in order to avoid leaving out population for a long time, evolves over time. In fact, villages mini grids progressively become “grid connected” as they become integrated in the larger national network. It is therefore important to ensure that the construction standards are compatible and that that remotely located generation can become IPPs. Therefore the definition changes according to the period, as detailed in the following sub-chapters.

The following definition has been agreed as a starting point for the national grid: grid areas are electrified areas which are connected to MV lines (mostly 22kV, but in few cases 35kV) of any of the following networks:

- Phnom Penh, Kandal, Takeo and Kampong Speu (interconnected with Vietnam through high voltage lines)
- Battambang, Sisophon, Siem Reap (each interconnected through high voltage lines from Thailand)
- All border lines with Thailand, Vietnam and Laos. Although not technically “national” grids, these areas belong to much larger networks and therefore behave as if integrated in the national grid from a planning perspective.
- The REE license zones belonging to the interconnected network in 2010 (128 out of 244) are shown on the map below, along with the existing transmission infrastructure

Two short term developments are expected by 2015:


- **The national transmission (HV) network** will interconnect the 3 major networks mentioned in the previous chapter, while expanding the national grid to other provincial towns.
- **The sub-transmission (MV) network** will expand significantly as well, as a result of the ongoing EDC grid extension programme.

As a result, most areas with MV lines will merge into the national interconnected grid (either interconnected to neighbouring countries, or interconnected with other power systems in Cambodia), as shown on the map.

In the longer term, it is understood that Preah Vihear, the last remaining isolated provincial town, will be interconnected with Kampong Thom by 2020.

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 31: Map of "grid" areas in 2010



4.3 MINI-GRID SUPPLY OPTIONS

4.3.1 Principles

This chapter will provide mostly the methodology of mini-grid potential assessment, as well as the main results. More detailed results are available in chapter 5.

The study of off-grid potential focuses on projects ranging from 50kW to 2MW. These projects typically feature a distribution mini-grid and a generation source: either minihydro, biomass (gasification, biogas or cogeneration), or hybrid PV/diesel.

The mini-grid consists of MV (22kV) lines connecting different villages, with LV lines inside each village supplying all customers. The extent of the mini-grid is automatically calculated by the GEOSIM algorithm, starting with the closest Development Pole to the power source, and expanding progressively to nearby villages, until the levelized cost of kWh stops decreasing.

Candidate villages to mini-grid projects are the ones, which are not connected to the national grid by 2015. This time span of 5 years is deemed reasonable, considering the time required to make such projects profitable, and taking into account uncertainties regarding grid extension. All projects are further ranked according to the expected impact on local socio-economic development.

Table 25: Cost of transformers

Capacity (kVA)	Cost (USD)
30	2 935
50	3 339
100	4 787
160	6 377
250	8 260
315	9 499
400	10 630
500	12 430
630	15 145
800	16 770
1000	19 888
1250	23 162
1500	26 440
800x2	33 540
1500+315	35 939
2000	38 117

Step-down (three-phase) transformers are sized according to the forecasted demand in each village 5 years ahead. Their cost has been determined in consultation with local suppliers in Phnom Penh; step-up transformers at the generation site are taken as 10% more expensive than step-down transformers of equivalent capacity.

Length of LV lines inside each village is determined with a ratio per customer: **70** customers/km LV line. This parameter is critical in sizing and costing of projects, and naturally depends a lot on the configuration of villages. As a reference, the JICA Master Plan study (2005) assumes a ratio of 66 for off-grid hydro projects. The average LV unit cost is taken at **7,750 USD/km** (EAC, 2010).

Medium voltage lines (22kV) are used to transmit power between different villages. Their path and length is automatically calculated by GEOSIM, using an advanced least-cost path algorithm following roads and avoiding obstacles (forests, rivers, lakes etc.). Moreover, some additional length of MV lines is needed inside villages too. A ratio of **10%** is taken between the MV line length required

inside a given village and the calculated length of LV lines. An average unit cost of **10,000 USD/km** is taken (EAC, 2010).


SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Most customers will use single phase meters, with an estimated cost of **50 USD (including service line)**. The few productive uses using three phase meters will incur a cost of **300 USD**. These costs are included in the overall project costs, as a first assessment of economic costs. However, the customer usually pays at least part of these upfront costs to the operator, therefore the burden may not be on the operator.

According to EAC regulation on depreciation, an economic lifetime of 30 years is taken for all equipments, except transformers with 25 years. Operation and maintenance costs of all distribution equipments is taken at **1%** of investments costs per year.

The 3 main generation technologies studied to power these mini-grids (minihydro, biomass and hybrid PV/Diesel) are detailed below.

4.3.2 Mini Hydropower



The first step of the assessment consisted in compiling recent studies on hydro potential in Cambodia including:

- **2006: Master Plan of Rural Electrification from Renewable Energy (JICA):** 145 sites identified from map survey, 66 sites screened, about 28 sites visited and pre-sized, 3 pre FS from 45 to 180 kW
- **2006: Identification of Technically Suitable Micro Hydropower Site in Cambodia for the Purpose of Energy Services (UNIDO):** 5 sites visited and one kept for feasibility study and implementation (still pending)
- **REAP:** 6 pre FS 0.65-4MW
- **2006: KEPCO Master Plan for EDC:** 14 sites above 24 MW (outside the scope of the project)
- **2005: Hydro Master Plan (JICA):** 29 sites above 24 MW (ditto)
- **2003: Pre-Investment Study of Community Scale Hydro Projects (NZ Ministry of Foreign Affaires & Trade & Meritec, 2003).** 45 locations identified by desk screening in nine provinces. 6 locations were selected as priority communities for site and socio-economic survey. Pre-F/S for 10 schemes.
- **1995: Review and Assessment of Water Resources for Hydropower and Identification of Priority Projects (Chao Praya Engineering Consortium, Vienna)**
- **1971: Inventory of Promising Tributary Projects in the Lower Mekong Basin (Mekong Secretariat, Bangkok)**

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

After analysis, it was decided to start from the long list of JICA sites (145), which is currently the most comprehensive list for the targeted power range, and then to supplement it with other sources, such as MIME, UNIDO, Meritec, as well as SREP field visits on about 10 sites.

A first list has been presented to MIME and PDIME officials during 4 regional meetings in April 2010, in order to have their comments on the list of potential, and also add new ones.

After combining these different sources, and applying screening criteria, the resulting list of potential hydro projects features **65** sites. Please refer to the annexes for a detailed explanation of the method used to create this list. In particular, as we are addressing the issue of off grid electrification, we had to combine basically a reasonably costed site located close to demand – population. In the context of Cambodia, this combination has proven rather difficult.

Since the hydropower sites come from different sources, their sizing assumptions (installed capacity) may differ from one another. For example, JICA sites (the majority of sites) have been sized with isolated rural electrification projects in mind, therefore they tend to have much lower capacities than MERITEC estimates, which are usually sized at the mean annual flow. Whenever two estimates of installed capacity were available for the same site, preference has been given to JICA sizing when assessing potential for mini-grid projects, and to the MERITEC one when assessing potential for injection on a larger grid. The 65 sites have a total installed capacity of 17 MW.

After a first round of simulation in GEOSIM, it has been found some of the 65 sites were competing for the same demand and some didn't have any significant demand nearby. Therefore, only the best sites have been kept, on the basis of the lowest levelized cost of kWh. Sites removed in this way may be candidates for IPP project, provided demand is sufficient and generation & transmissions costs are acceptable for the operator. Final number of sites for each scenarii is given below:

Table 26: Mini-hydro projects for each scenarii

	Baseline scenario	Intermediate scenario	Conservative scenario
Number of projects kept	33	35	38
Cumulated installed capacity (kW)	6 449	6 639	7 309

Installed capacity is not the only important characteristics of a potential mini hydro project. The GEOSIM model also requires information on the guaranteed capacity (dry season output in kW) and the yearly energy production (in MWh). Therefore, formula had to be used to define these missing parameters. Whenever estimates of investment costs were not available, the following unit costs for hydropower plant have been applied, taken from the two main sources:


- **JICA:** average cost of 4300 USD/kW, for systems around 50kW
- **Meritec:** average cost of 1947 USD/kW, for systems around 2MW

Values for sites between 50kW and 2MW have then been interpolated using the following power law:

Equation 2 Hydro unit cost formula


$$UnitCost(USD/kW) = 9963 \times Capacity(kW)^{-0.2148}$$

Figure 32: Evolution of unit costs with installed capacity



According to EAC regulation on depreciation, an economic lifetime of **30 years** is taken for all hydropower equipments. Operation and maintenance costs of all distribution equipments is taken at **2%** of investments costs per year (in line with assumptions from JICA Master Plan). From these assumptions, the raw generation cost of hydropower projects can be calculated, using the Levelized Cost of Energy (LCOE) approach, with a 6% discount rate and constant prices:


Figure 33: Raw hydro project generation costs



Naturally, the cost of transmission, distribution, taxes and the profit margin for the operator will have to be added to estimate the real tariff to the end-user, but this already provides an indication of the competitiveness of this solution for off-grid and grid connected purposes. NB: This calculation also assumes that all power generated can be sold, which is not always the case in both grid and off-grid cases, as it will be explained in the planning scenarii results (see chapter 5). Moreover, the cost in isolated mini-grid mode is usually much higher than this, as the seasonality of hydro supply makes a diesel genset backup mandatory (simulated by GEOSIM on a case by case basis, depending on the characteristics of the hydro site and its nearby demand).

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 34: Map of identified hydro potential projects



4.3.3 Biomass mini grids options

Projects falling under the biomass family may be very different from each other and are usually defined by the three following characteristics:

Type of biomass resources: three main categories of biomass resources exist:

- Natural resources (indigenous trees, bushes...)
- Energy plantations (fast growing trees, oil and sugar producing crops)
- Agricultural and agro-industrial residues (all residues resulting from harvesting or transformation of agricultural products, e.g. rice husks, saw dust, wood chips, animal manure...)

It has been decided to focus on agro-industrial residues for several reasons, and more specifically on rice husks and bagasse from sugarcane as a first step (the final planning report may include some other more recent agro-industries under development, such as palm factories, piggeries and cassava starch factories).

Technology used to convert the biomass resources into electricity: again, three technologies have been considered:

- Biogas (anaerobic fermentation): To date, there are very few large agro-industries in the country having the quantity of humid waste required for biogas. There are only about 5 pig farms which could be potentials for such units in the Medium term.
- Cogeneration (combined production of heat and power from a boiler): again requires fairly large units, which also need the heat. Until recently, relevant agro-industries (large rice mills, sugar production) were not large enough to offer such opportunities. However, a few (5 to 10) such investments are being prepared in Cambodia, mostly sugarcane mills and rice mills.
- Gasification: usually uses the same types of residues than cogeneration, but it is more suitable whenever power output is less than 1MW and when heat is not so much needed by the agro-industry (which is usually the case for medium sized rice mills). This technology currently offers more potential – some 90 rice mills of suitable size have been identified and SME Cambodia has been selling and installing gasifiers which have a fairly good track record, however mostly for captive use until now.


Figure 35: Workers shoveling rice husks coming out of a rice mill




SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Business model: two main types of models associating agro-industries with rural electrification may be considered:

“Captive use projects”: projects where biomass facility is in the agro-industry compound, and a part of the generated electricity/steam is consumed by the agro-industry (captive use), the rest being supplied either to a mini-grid or the national grid or both. For example, rice mills typically consume only 30% of the husk for their own consumption and hence the balance could be used to sell to a local (diesel) REE, bearing very high production costs.



“Clusters”: projects where agro-industrial residues are purchased and transported from several medium sized agro-industries, which individually wouldn't have the critical size for a single biomass project.



Please see refer to the annexes for a detailed review of these different elements, and the reasons for the choices among all the possibilities. After combining the above three main characteristics, four main types of projects have emerged:

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Table 27: 4 main types of biomass projects

	Residue	Technology	Business model	Production range
A	Rice husk	Gasifier with dual fuel genset	Cluster	Each industry between 200 and 2,000 t rice/year, total of 2,000 t rice/year for the cluster
B	Rice husk	Gasifier with dual fuel genset	Captive	2,000-10,000 t rice/year
C	Rice husk	Cogeneration	Captive	>10,000 t rice/year
D	Bagasse	Cogeneration	Captive	All sugarcane mills

As shown in the table below, the survey conducted under SREP provided rather optimistic perspectives for at least the two first types of projects. Regarding the second type of project, there also will probably be an important potential, but in the medium term: the agro industrial sector is made of SMEs in Cambodia and large agro-industries are still at the inception stage. Willingness of small rice millers to sell excess power or act as REEs was found not to be an issue, since the proposed business model for their category would be to sell directly rice husks to a dedicated gasifier purchasing from several rice mills.

Table 28: Results of the SREP survey on small and medium rice mills

Production range	Type of project	Surveyed by SREP	Knowledge of biomass technology	Interest in technology	Already equipped with biomass	Willing to sell excess power	Willing to act as REE	Excess husk availability (avg of % total residues)
200-2000 t rice/year	Clusters of rice mill (A)	69	84%	85%	10%	36%	19%	46%
>2000 t rice/year	Medium rice mill (B)	27	100%	96%	7%	72%	72%	73%

We have assumed that the cogeneration projects, with installed capacities often in the range of several tens of megawatts, would provide 500kW to 2MW for local mini-grid electrification, the rest being used for own consumption or selling to the grid (located close to the agro-industry in all cases). This excess capacity for rural electrification has been sized depending on actual forecasted demand in the vicinity of the power plant, and thus depends on the scenario.

For the detailed methodology and assumptions made to create the list of potential biomass projects in GEOSIM is explained in annexes. The resulting number of projects and installed capacity for each scenario is:

Table 29: Number of identified potential projects

	Type of project	Baseline scenario		Intermediate scenario		Conservative scenario	
		Number of projects	Cumulated installed capacity (kW)	Number of projects	Cumulated installed capacity (MW)	Number of projects	Cumulated installed capacity (kW)
A	Rice cluster	12	2096	20	3544	28	4728
B	Rice captive gasifier	2	321	7	1488	10	2078
C	Rice captive cogeneration	6	4200	6	4350	6	4150
D	Sugarcane	5	3700	5	4450	5	5250
	Total	25	10317	38	13832	49	16207

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans


Please note that the above projects will definitely not be carried out for rural electrification purposes only. Many more projects would be possible as pure IPP projects (direct injection on the national grid), as it already happens in a few cases, where the REE runs its gasifier in the day and purchases power from the grid at night time when demand is too low for the gasifier to run properly. Total number of biomass projects including IPP is about **120**.

The following map shows all biomass potentials identified (conservative scenario), as well as some others not considered in the rural electrification plan, but which could be of interest for direct injection to the grid.

However, these projects will not emerge unless there are considerable policy evolutions and a clear regulatory and incentives framework provided: to date, there has been no systematic work done on small scale independent power production and the framework for grid connection, and power purchase agreements depending on the technology, firm / non firm power, seasonality etc... It is obvious that large agro industry will limit co-generation to captive use unless it is attractive enough to sell excess power to the national grid.

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 36: Map of identified biomass projects (conservative scenario)



4.3.4 Diesel mini grids

Capacity (kW)	Total cost (USD)	Unit cost (USD/kW)
5	1 200	240
10	3 000	300
20	9 000	450
30	10 100	337
40	11 824	296
50	13 549	271
60	15 273	255
70	16 573	237
80	17 456	218
90	18 339	204
100	19 221	192
150	23 636	158
200	28 050	140
250	32 464	130
300	36 878	123
400	45 707	114
500	57 000	114
600	68 400	114
700	79 800	114
800	91 200	114
900	102 600	114
1000	114 000	114
1200	136 800	114
1500	171 000	114

As a conservative move, the simulations have been run assuming that all new diesel mini-grid projects would be purely diesel based. However, potential for hybrid PV/diesel will be discussed briefly in the next chapter.

For all new diesel projects, it is assumed that 2 generators are operated to ensure 24h supply: one during evening peak demand, and another during the day, when demand is lower. The average lifetime of gensets is taken at **5 years**, although the current practice for REEs seems to largely exceed this value, resulting in drastically reduced efficiency. Average specific fuel consumption is thus assumed to be **0.35 L/kWh**.

Unit costs vary between **115 and 450 USD/kW**, depending on the installed capacity.




Table 30: Cost of diesel gensets

The above costs are found slightly higher than quotations given by suppliers in Phnom Penh. However, these quotations are mostly for second-hand material, and therefore should not be used as a reference for sustainable projects.

Operation and maintenance costs of all distribution equipments is taken at **5%** of investments costs per year.

The number of sites and capacity for each scenarii is given below:

Table 31: Diesel projects for each scenarii

	Baseline scenario	Intermediate scenario	Conservative scenario
Number of projects	150	233	289
Cumulated installed capacity (kW)	21 663	34 701	46 833

The number of diesel projects is significantly higher than biomass and hydro projects, thereby justifying the need for innovative solutions to make them more economically and environmentally sustainable, such as hybridisation with PV.

4.3.5 Hybrid PV/Diesel

International experience now shows that with the dropping of PV panel prices and the increase in reliability of technology, the PV production cost, with financing available over 15 years, could be between 20 and 70 UScents/kWh:

- The lowest range being for large (3 MW and above) units feeding into the grid without any battery storage
- Mid range being for smaller capacities and feeding into a diesel grid typically, still without storage
- The most costly being for very small units and with up to 100% battery storage, the PV power being produced during the day, stored and then consumed in the night time.

Most new diesel mini-grid projects proposed under the rural electrification plan belong to the third category. Therefore, the cost are expected to be slightly high, even compared to diesel standards. However, some sites may still prove competitive, for example is sufficient demand exists during the day (several mobile phone antennas and other productive uses), and if adequate sources of financing are available. Besides, with economic development and further activities, load factors will improve, and direct injection of PV without battery storage should prove to become an option. Although careful optimisation will need to be carried out on a case by case basis (cf. the 3 feasibility studies undertaken as part of SREP activities), we will provide here an estimate of the potential market size in Cambodia using the following assumptions:

- PV productivity: 5.3 kWh/m²/day, 80% overall conversion efficiency¹⁴
- Lifetime of equipments: 20 years for panels and electronics, 5 years for batteries
- Unit costs: 3.3 USD/Wp for panels, 1.0 USD/Wp for inverters, 1.0 USD/Wp for battery charge controllers, 140 USD/kWh for batteries
- Installation and contingencies: 10% investment costs
- Discount rate: 6% (excluding inflation, calculation is done in constant prices). This means that access to soft loans is possible.

This results in the following levelized costs:

- Project with 100% battery storage (no demand during the day): **42 UScts/kWh**
- Project with 50% battery storage: **34 UScts/kWh**
- Project with 0% battery storage: **27 UScts/kWh**

These figures are to be compared with diesel generation costs, using the assumptions detailed in the previous chapter. Since the unit costs vary with the installed capacity, the generation costs are slightly different between small and large scale:

- Small-scale projects (~20 kW): **39 UScts/kWh**
- Large-scale projects (>400 kW): **36 UScts/kWh**

However, investment costs of diesel are marginal in the cost of kWh. The real parameters are the diesel specific consumption (taken here as 0.35 L/kWh on average) and the diesel price (1 USD/L). If we assume that small-scale projects use very inefficient second-hand gensets consuming 0.4 L/kWh, while large-scale projects go down to 0.27 L/kWh, the range of generation costs becomes:

¹⁴ Taking into account losses in the inverter, batteries, and the panels at high temperature.

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Table 32: Diesel generation costs for different capacities of diesel gensets, and associated competitive PV/hybrid option

Capacity (kW)	Unit cost (USD/kW)	Specific consumption (L/kWh)	Diesel generation cost (UScts/kWh)	Competitive PV/Hybrid option
20	450	0.40	44	100% storage (42 UScts/kWh)
30	337	0.38	42	
40	296	0.37	40	
50	271	0.36	39	50% storage (34 UScts/kWh)
60	255	0.35	38	
70	237	0.35	37	
80	218	0.34	36	
90	204	0.33	35	
100	192	0.33	35	
150	158	0.31	33	0% storage (27 UScts/kWh)
200	140	0.30	31	
250	130	0.29	30	
300	123	0.28	29	
400	114	0.27	28	

The above table reveals that projects below 30 kW can be equipped with 100% storage systems, projects between 30 and 100 kW can have a maximum of 50% storage, and projects above 100 kW would need to work with no storage at all. This is relatively consistent with the daily load patterns, as small-scale projects tend to have demand only in the evening (thereby requiring 100% storage of PV power, to be delivered at night), while larger projects can include daytime productive uses absorbing directly PV power without going through a battery system.

As a first estimate, 20% is suggested as a reasonable penetration rate of PV, i.e. for a 100 kW diesel system, 20 kWp would be installed. This is to minimise power distribution stability issues, and ensure enough power can be absorbed at the time of PV production. The results in terms of sizing and investment costs are detailed in the planning results (chapter 5).




Figure 37: Historical evolution of PV panel unit prices for the past decade

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

In the longer term, it can be expected that, given the depth of the market of diesel operators, and further cost reduction at the global stage, as well as rising fuel prices, even projects where the suggested PV option is difficult to implement may become eligible for hybridisation.

Therefore, sensitivities have been carried out on diesel fuel prices (increased to 1.3 USD/L) and PV panel unit costs (decreased to 2.2 USD/Wp). The 0% storage solution would then decrease to about 20 UScts/kWh, making it significantly cheaper than any diesel project. As seen in the table below, even large-scale projects would become competitive with a 100% storage PV/diesel hybrid.

Table 33: Diesel generation costs and associated competitive PV/hybrid option with higher diesel price and lower PV unit costs

Capacity (kW)	Unit cost (USD/kW)	Specific consumption (L/kWh)	Diesel generation cost (UScts/kWh)	Competitive PV/Hybrid option
20	450	0.40	56	100% storage (35 UScts/kWh)
30	337	0.38	53	
40	296	0.37	51	
50	271	0.36	49	
60	255	0.35	48	
70	237	0.35	47	
80	218	0.34	46	
90	204	0.33	46	
100	192	0.33	45	
150	158	0.31	42	
200	140	0.30	41	
250	130	0.29	39	
300	123	0.28	38	
400	114	0.27	36	

The overall conclusion is that there is a significant potential for PV/diesel hybrids in Cambodia but as a prerequisite, there definitely is a need for:

- pilot projects to demonstrate the technical feasibility of projects in a Cambodian context, particularly in consideration for the most appropriate electronics;
- Capacity building on the technology.

An appropriate policy and financial support framework is definitely required, ensuring that:

- Tax and duty issues do not unduly increase project costs;
- Long term soft loan financing with a part of grants is available, whether provided by the Rural Electrification fund or commercial banks, which is far from being the case today due to lack of understanding of the technology and limited credit worthiness of the project sponsors;
- The regulator encourages these schemes through appropriate regulatory frameworks and PPAs.

4.4 STAND-ALONE SYSTEMS

The main components of the approach are:

- Solar Battery Charging Stations (BCS) will be installed in each village, which are not electrified by national grid or mini-grid projects by 2020, and where no BCS is currently operating. This will ensure that the political objective of 100% village having electricity supply by 2020 is met.
- Likewise, community PV systems are suggested in all villages, which are not electrified by national grid or mini-grid projects by 2020. Targeted facilities are schools, health centres, commune halls¹⁵ and pagodas.
- Finally, all rich households in these villages will be candidates for Solar Home Systems (SHS). The share of rich households in each village varies from one province to another, as explained in 3.1.1.

Level of services suggested are:

- Community PV
 - Schools & Health Centres: **700 Wp**
 - Pagoda and commune hall: **200 Wp**
- Solar BCS: equivalent of **40 Wp/customer**
- SHS: 100 Wp

Regarding investment costs, the following assumptions have been made (inclusive of transport and installation):


- **3 USD/Wp** for Solar BCS, plus an additional 30 USD per customer for the battery itself
- **4 USD/Wp** for SHS and community PV systems

Deployment of these stand-alone systems is assumed to happen progressively until 2020. Pico-hydro systems could be added, but they are very site specific, and usually cannot be identified from a map study given that the smallest scale available in Cambodia is 1:50,000. Therefore, extensive field surveys would be required to identify suitable places. Nevertheless, a map of sites found to be smaller than 50kW after the JICA study is shown below:

¹⁵ As the location of each commune village was not available from the GIS database, it has been assumed that the commune hall is located in the largest village of each commune (in terms of population).

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 38: Location of possible picohydro projects



5 RESULTS OF THE THREE PLANNING SCENARI

5.1 REMINDER OF OBJECTIVES AND APPROACH, SENSITIVITY ANALYSIS

The three scenarii aim to reach the policy objective for 2020, i.e. all villages would have access to an electricity service, either national grid, mini-grids or stand-alone systems. The three scenarii follow the same methodology, explained below, their only difference is the assumed speed of national grid expansion (as explained below).

The second main policy objective for 2030 (70% households having access to national grid or mini-grids) is reached only in the baseline scenario, but the two others come relatively close to it.

Step 1: grid expansion

The scenarii differ on the speed at which the national grid will expand to rural areas making different assumptions in terms of achievements by 2015, 2020 and 2030, in order to consider different situations of fund mobilisation and actual implementation.

- **Baseline scenario:** the projections made by EDC in terms of number of villages and km of lines are taken for 2015, 2020 and 2030 as achieved. These projections are in line with EAC targets of 80% national grid villages by 2020, and 95% by 2030.
- **Intermediate scenario:** this second scenario assumes that the grid extension rate would be half as fast as in the baseline scenario, i.e. whatever villages would be connected in the baseline scenario by 2015 would now be connected by 2020 only. Likewise, villages connected by 2020 in the baseline scenario would be connected by 2030 instead.
- **Conservative scenario:** the third scenario assumes an even slower grid extension speed because of limited fund availability, one quarter as fast as the baseline scenario, i.e. villages connected by 2015 would be connected by 2030 only.

Step 2 : off grid households and villages

Least-cost comparison of decentralised mini-grids solutions (mini hydro, biomass, and diesel) is performed in order to supply **all Development Poles** not covered by grid extension before **2015**.

Finally, stand-alone systems are considered:

- Solar Battery Charging Stations (BCS) to ensure that the political objective of 100% village having electricity supply by 2020 is met
- Community PV systems (schools, health centres, commune halls and pagodas) for all non electrified villages
- All rich households in non electrified (grid or mini grid) villages will be candidates for Solar Home Systems (SHS)

Demand

In the baseline scenario, which has the maximum number of grid connected villages, rural demand as per our simulations will amount to 2,310 GWh/year in 2030, compared to 21,000 GWh/year for the whole country including urban and large industrial customers (Power Sector Development Plan). This is slightly above 10% of total demand, hence it is obvious that rural demand will not be constrained by energy production.


Peak demand for rural grid customers amounts to about 873 MW in 2030, but most of this demand is expected to happen in the evening, contrary to the current peak on the grid, which is mostly in the afternoon (linked to AC use). Therefore, rural electrification being much smaller in volume, its impact on total installed capacity will be negligible.

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Therefore, we have not conducted any sensitivity analysis to demand, which does not mean that this should not be refined when moving to the more detailed assessment of off grid / mini grid options, on the contrary, as the level of demand and placed energy impacts significantly the kWh cost.

The following charts display the evolution of rural demand on the grid, with a breakdown of villages already connected to the grid, and the ones connected after year 2011.

Figure 39: Rural demand grid connected villages – energy and peak load.



5.2 BASELINE SCENARIO

5.2.1 Key results

g) Share of grid and off grid

Grid extension has the lion's share of rural electrification efforts, in a very clear "explosion" from 2010. Second and third solutions are Solar Battery Charging Stations and new diesel mini-grids (possibly hybrid PV/diesel):

- In 2010, National grid covers 7% of total HH and 10% of villages, and only 11% HH and 57% villages are covered by all technologies. Regarding village coverage, stand alone and mini grid options play a very important role;
- By 2030, 100% villages are covered, of which 95% through the national grid; and 67%¹⁶ HH of which almost the totality by the national grid.

The graph below clearly shows this dramatic rise in the share of the national grid, which is further detailed in the table.

h) Financing requirements


This of course now raises the question as to whether the required funds will be available to reach the grid objectives and whether it will be physically possible. Indeed, the investment requirements amount to:

- By 2015:
 - **143MUSD for MV (107MUSD according to EDC)**, which will essentially have to be EDC borrowings or RGC allocations, as REEs can contribute but only marginally to the effort;
 - **184MUSD for distribution (222MUSD according to EDC)**, necessary to connect HH in the villages. It does not seem likely that REEs alone would be mobilise these funds, so the question of developing a financing mechanism to support REE borrowings is essential (long term, low interest) - and the REF could definitely be an option. EDC currently is not willing to borrow for distribution, but only to implement grants allocated.
 - **72MUSD requirement for mini grids**. At present, there is no public mechanism to finance this, as the REF has but this on hold. It seems very ambitious to imagine that the private sector could mobilise this amount in the coming 5 years. Besides, longer term issues such as integration with the national grid as IPPs once the national grid arrives, still need to be resolved.
 - **19MUSD will have to be mobilised for stand alone** (essentially PV) options during this first period.
 - Therefore, **418 MUSD worth of rural electrification investments** have to be executed during the coming 5 years, in order to meet the RGC targets
- Over the 20 year period to 2030, the targets are no less ambitious, with about 1 BIUSD having to be mobilised over 20 years to reach the target of 100% village coverage and 70% HH connections, the detailed breakdown of which is provided in the following table.

¹⁶ The estimate of the draft rural electrification plans of 88% was based on the optimistic assumption that all electrified village would reach a connection rate of 98% of households. This has been slightly decreased to a more reasonable 70%, in line with EDC assumptions and field surveys carried out by SREP.

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 40: Evolution of village coverage for different technologies



Coverage for rural areas		2010	2015	2020	2030
Connections	National grid	6,9%	29,1%	47,4%	66,2%
	Hydro mini-grid	0,0%	0,6%	0,3%	0,1%
	Biomass mini-grid	0,0%	0,4%	0,3%	0,0%
	Existing diesel mini-grid	4,4%	1,9%	1,4%	0,6%
	New diesel mini-grid	0,0%	1,9%	1,2%	0,1%
	Solar home systems	0,0%	0,7%	1,4%	0,2%
	Total percentage of rural households	11%	34%	52%	67%
Village coverage	National grid	10,9%	46,1%	78,3%	94,8%
	Hydro mini-grid	0,0%	1,5%	0,6%	0,2%
	Biomass mini-grid	0,0%	1,2%	0,7%	0,1%
	Existing diesel mini-grid	11,9%	5,4%	2,7%	0,9%
	New diesel mini-grid	0,0%	5,1%	1,9%	0,1%
	Existing battery charging stations	34,7%	14,3%	6,8%	1,3%
	Solar battery charging stations	0,0%	4,5%	9,0%	2,6%
	Total percentage of rural villages	57%	78%	100%	100%


Investment costs in rural areas ('000 USD)	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	143 429	118 203	83 282
Distribution (transformers, LV, meters)	183 994	158 735	203 490
Subtotal grid extension	327 423	276 938	286 772
Hydro mini-grid	31 492	861	233
Biomass mini-grid	16 363	581	171
New diesel mini-grid	23 906	2 382	392
Subtotal mini-grid projects	71 761	3 824	796
Solar home systems	6 698	8 272	0
Community PV	2 190	2 190	0
Solar battery charging stations	10 368	10 564	0
Subtotal stand-alone systems	19 255	21 025	0
Total	418 440	301 787	287 568

Table 34 : Investment costs for all technologies in rural areas (baseline scenario, in thousands of USD)

The situation status map in 2015, illustrates the point made above which is that there will still be substantial investment required in diesel mini grids and solar battery charging stations. As can be seen on the map, some of these investments will be located in remote areas of the North or North Eastern Cambodia, but most will still be in the south and south East, where there is a lot of population and where the grid will not have reached. Indeed, MV lines will also be expanding North West, as EDC's policy is to set up a back bone infrastructure and not necessarily to focus only on the very dense areas. The proximity of the proposed mini-grid projects with the national grid still represents a serious issue, as it may be perceived as an unbearable risk by potential project developers.

The grid extension map provides insight on the different phases of grid extension. The first phase from 2011 to 2020 follows EDC's objective of providing a back bone infrastructure, the second phase from 2021 to 2030 tries to densify the network (connect villages close to the backbone).

Figure 42 : 2030 Map of grid extension (baseline scenario)



i) **Comparison of all technology economics over the planning period to 2030**

Though the number of non national grid villages is marginal percentage wise, the investment figures in mini grids is far from negligible as we have seen, and the following table does show that we are facing a situation where :

- about 1000 villages have to be covered by mini grids over the next 5 years
- about as many villages to be equipped with solar battery charging stations over the next 10 years
- and 2000 odd community PV systems have to be installed over the next 10 years

How realistic this is a real question, all the more so given the related investment requirements.

Cost per village is also interesting to compare: though the fact that the investment cost of a “hydro” village is about double that of a “grid” village may seem worrying at the outset, it is not at all so, as for grid villages, this is the average cost, and the hydro options typically are for the remoter locations, which are at the tail end of the grid and with a much higher marginal cost. As for biomass, even though they are usually located much closer to the national grid, and do have slightly higher investment costs per village, the long term kWh cost proves to be rather on par with the grid because of low O&M costs.

Interesting to analyse is the cost per household, which remains high for off grid options as unfortunately those remote villages tend to be little populated.

A generation and transmission cost of grid electricity of 13 USCts/kWh has been taken (for grid connection), and all calculations have been made with a 6% discount rate. ⁽¹⁷⁾. All off grid options compare favourably to diesel (at +/- 38 USc) and it must be born in mind that in the GEOSIM scenarios, a scenario of explosion of fossil fuel prices has not been simulated; and that further, the cost of PV for instance is expected to decrease.

		No villages	000 HH	Invest (MUSD)	Cost/ village USD	Cost /HH USD	kWh (USDc)
Grid		10 572	1 838	891	84 292	485	21.0
Mini-grids	Hydro	193	15	33	168 842	2 244	26.3
	Biomass	157	9	17	109 012	1 853	24.2
	Diesel	643	47	27	41 495	565	38.4
Stand-alone	Solar BCS	1 138	131	20,9	18 393	160	36.3
	Community PV	1 994	-	4,4	2 196	-	-
	SHS	-	37	15,0	-	400	39.7

¹⁷ The numbers are not meant to be added up. The number of villages and households served by all technologies is higher than the total number of villages and households in Cambodia, as some villages and households may very well start being connected to a mini-grid or stand-alone project, and then become connected to the national grid later on.

Figure 43: Evolution of household connection rates for mini-grid technologies




Figure 44: Yearly investment for all technologies in rural areas





Figure 45: Yearly investment for mini-grid and stand-alone technologies in rural areas



5.2.2 Detailed analysis for grid expansion component

Important note: All the numbers and investments in this chapter are provided for the new villages and households to be connected in rural areas.


Table 35: Summary of results for grid extension in the baseline scenario

Phase	Villages connected	HHs ('000)	MV line length (km)	MV line per village (km)	Invest. In MV (MUSUSD)	Invest. In distrib. (MUSUSD)	Total invest. (MUSUSD)	Cost per village (USD)	Cost per HH (USD)
2011-2015	4 431	570	7 171	1,6	153,8	184,0	327,4	73 894	575
2016-2020	4 054	539	5 910	1,5	101,9	158,7	277	68 312	514
2021-2030	2 087	729	4 164	2,0	87,5	203,5	287	137 409	393
2011-2030	10 572	1 838	17 246	1,6	343,1	546,2	891	84 292	485

a) Analysis of investment costs

We highlight here once again that the cost of investment in distribution is in total nearly twice as much as in MV over the period – hence the cost of HH connection over and above village connectivity must be transparently addressed.

Figure 46: Total grid investment costs with detailed breakdown and comparison with EDC estimates (baseline scenario, in millions of USD)



The opposite figure shows investment costs in millions of USD, with breakdown by type of equipment. When compared with EDC figures (taken from their estimated budget for the grid extension programme, cf. 2.4.3), the amounts in the first phase (2011-2020) are rather similar, while there are significant differences in the second phase (2021-2030). This may be explained by several factors:

- EDC took into account a cost increase over the next 20 years, while figures provided by SREP are in constant price
- Population growth rate assumptions are very different: 3.8% on average for EDC, 1.2% for SREP
- In the SREP simulation, investment cost per households decreases significantly in the second period, because of grid densification¹⁸.

¹⁸ Villages next to existing backbone lines will be connected and villages already connected will increase their number of customers.

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Nevertheless, planning 10 to 20 years ahead is obviously a very delicate exercise, and the results have much less importance than then ones of the first phase.


The difference in terms of investment costs per households is much lower as shown below:

Table 36 : Household investment cost with detailed breakdown and comparison with EDC estimates (baseline scenario, in millions of USD/connection)

	2011-2020		2021-2030		SREP hypotheses
	SREP	EDC	SREP	EDC	
Metering	50	65	50	60	50 USD/meter
LV lines	150	271	200	252	15000 USD/km, 100 cust/km before 2020, 50 cust/km after
Transformers	109	67	29	63	46 to 154 USD/kVA
MV lines	236	163	114	142	20000 USD/km
Total (MUSD)	545	566	393	517	


b) Length of MV lines added and geographical location

Figure 47: Length of MV lines added (baseline scenario)



7200 km of MV lines are to be added during the first 5 years (8000 km according to EDC), then brought down to 5900 during the next five years, and remaining at 4200 during the last 10 years. It clearly appears that under this baseline scenario, the MV backbone extension effort in the first years is substantial, with almost 1,500 km of new lines to build every year until 2015.

Most remote villages targeted by EDC until 2020 are connected here at the end of the 2011-2020 period, because of the least-cost prioritisation done by GEOSIM, which explains why there is suddenly more MV lines added in 2020. However, the actual practice may be slightly different, with long MV backbone lines coming first, depending on political choices rather than techno-economic optimisation.



The breakdown of length of MV lines added per province is obviously consistent with the most populated provinces, except Kandal.

Figure 48: Breakdown of MV line length added per province (baseline scenario)

5.2.3 Detailed remarks for off grid areas

Given the optimistic grid extension assumptions, the share of mini-grid projects is very small, as most Development Poles are connected to the national grid by 2015. Moreover, this share decreases after 2015, as the grid extends further and thus interconnects with mini-grid projects. The baseline scenario is below the targets of the WB RE strategy for mini-grid projects, since their assumptions for grid extensions were significantly more conservative than EDC: the World Bank estimates 15 and 10% HH covered by mini grids in 2020 and 2030, while in the baseline scenario we reach only 3 and 1% !

This small market for mini-grid projects faces another issue: proximity with the national grid. For the few remaining projects, which can happen at the margin of national grid expansion efforts, most of them are located close to the grid.

Table 37 : Distance of proposed mini-grid projects to the national grid (baseline scenario)

Technology	Distance to existing MV in 2010 (km)	Distance to forecasted MV in 2015 (km)
Diesel	17.9	10.5
Hydro	26.5	16.9
Biomass ¹⁹	14.9	7.2
All mini-grids	19.1	11.4

While this proximity is a challenge for isolated mini-grid projects, it actually represents an advantage for IPP projects, i.e. projects aiming at injecting power directly into the national grid and which can compete with its bulk generation cost. This is the case for some biomass and hydro projects (cf. chapter 4.3 for more details).

Nonetheless, it will definitely remain a challenge to achieve the required 208 mini grids by 2015 and to mobilise the related investments. After 2015, no mini-grid projects are proposed given the grid expansion, but some investment costs remain, mostly to expand the service in areas already electrified by one the mini-grid technologies (extending LV lines, upgrading transformers, adding new meters etc.). However, cost of replacement generation equipment (e.g. gensets) is not taken into account here. Overall, the investment figures are much higher in the WB strategy which totals 198MUSD to 2030, instead of 76MUSD for SREP.

Table 38 : Mini grid investments: number, capacity and investment cost. (baseline scenario, in thousands of USD)

Mini-grid projects in rural areas by 2015	Number of projects	Total Installed capacity (kW)
Hydro mini-grid	33	6 449
Biomass mini-grid	25	10 317
New diesel mini-grid	150	21 663
Total	208	38 429

Investment costs in rural areas ('000 USD)	2011-2015	2016-2020	2021-2030
Hydro mini-grid	31 492	861	233
Biomass mini-grid	16 363	581	171
New diesel mini-grid	23 906	2 382	392
Total mini-grid projects	71 761	3 824	796

¹⁹ Except cogeneration projects, which are by design interconnected with the national grid.

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

As seen above, the number of diesel projects largely exceeds the number of projects for other technologies. Investment costs for new diesel projects have been calculated assuming they would not be hybridised with PV. As a first estimate, existing diesel projects are not considered for hybridisation, because most of them are supposed to be connected to the national grid very soon. Following assumptions detailed in chapter 4.3.5, the additional PV capacity and related investment costs required to hybridise these new projects are detailed below:

Table 39: Installed capacity and investment costs for hybrid PV/diesel in the baseline scenario (investment costs include panels, electronics and batteries only, diesel gensets are excluded)

Capacity range (kW)	Proposed solution	Baseline		
		Number of projects	PV installed capacity (kWp)	Investment cost ('000 USD)
<30	100% storage	7	37	237
30-100	50% storage	43	523	2 934
>100	0% storage	100	3 773	17 846
Total		150	4 333	21 017

Finally, stand-alone systems consist essentially of PV-based technologies. Estimates given by WB RE strategy aim at 178,000 SHS to be installed, while the numbers provided by SREP are much lower at 37,000. An additional 2,000 community PV are to be installed, as well as solar battery charging stations in more than 1,100 villages.

Table 40: Stand alone systems : Village coverage rates, number of systems and investment costs

Coverage for rural areas	2010	2015	2020	2030
Existing battery charging stations	34,7%	14,3%	6,8%	1,3%
Solar battery charging stations	0,0%	4,5%	9,0%	2,6%
Total percentage of rural villages	57%	78%	100%	100%

Stand-alone systems	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	16 744	20 679	0
Community PV (new villages)	997	997	0
Solar battery charging stations (new villages)	569	455	0

Investment costs in rural areas ('000 USD)	2011-2015	2016-2020	2021-2030
Solar home systems	6 698	8 272	0
Community PV	2 190	2 190	0
Solar battery charging stations	10 368	10 564	0
Total stand-alone systems	19 255	21 025	0

5.3 SENSITIVITY ANALYSIS: INTERMEDIATE AND CONSERVATIVE SCENARIOS

5.3.1 Village and household coverage trends and by technology

Overall, the ultimate target of covering 100% of the villages are met in all three scenarios. However, the target of 70% households is met in the baseline scenario only, while the two others come slightly lower.

Reaching the 70% target in the conservative scenario is a difficult undertaking, because this would mean many more mini-grid projects would be needed in villages which are not Development Poles, i.e. with low socio-economic potential and thus very low expected profitabilities. Besides, as explained in the previous chapter, most of these projects would happen very close, or even under the planned national grid, which is usually a serious issue for any sensible project developer. Another solution to reach the 70% target in the intermediate and conservative scenarios, would be to increase the connection rate inside already electrified villages, but this would require direct subsidies as the remaining 30% of households in rural villages are usually located far from the village centre and/or have very low capability to pay (the average share of poor and very poor households according to NCDD data was around 30% in 2009).


As illustrated in the following graph, the contrast between the three scenarios also lies in the speed at which the targets are met, looking objectively into the difficulty of mobilising the funds as required in the baseline scenario.

In the baseline scenario, in 2030, only 1% of households have mini-grid connections, against 4% in the intermediate and 9% in the conservative scenario.

Regarding village coverage in 2030, 1% are mini-grid in the baseline scenario against 6% in the intermediate scenario and 15% in the conservative scenario.

The baseline and intermediate scenarios are coherent with the WB RE strategy targets of 45% grid equivalent HH connections in 2020, while the conservative scenario is slightly lower.

Figure 49: Trend of village and household coverage rates to 2030, 3 scenarios



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Table 41: Household Coverage rates achieved by all technologies in rural areas only

BASELINE SCENARIO		2010	2015	2020	2030
Connections	National grid	6,9%	29,1%	47,4%	66,2%
	Hydro mini-grid	0,0%	0,6%	0,3%	0,1%
	Biomass mini-grid	0,0%	0,4%	0,3%	0,0%
	Existing diesel mini-grid	4,4%	1,9%	1,4%	0,6%
	New diesel mini-grid	0,0%	1,9%	1,2%	0,1%
	Solar home systems	0,0%	0,7%	1,4%	0,2%
	Total percentage of rural households	11%	34%	52%	67%
Village coverage	National grid	10,9%	46,1%	78,3%	94,8%
	Hydro mini-grid	0,0%	1,5%	0,6%	0,2%
	Biomass mini-grid	0,0%	1,2%	0,7%	0,1%
	Existing diesel mini-grid	11,9%	5,4%	2,7%	0,9%
	New diesel mini-grid	0,0%	5,1%	1,9%	0,1%
	Existing battery charging stations	34,7%	14,3%	6,8%	1,3%
	Solar battery charging stations	0,0%	4,5%	9,0%	2,6%
	Total percentage of rural villages	57%	78%	100%	100%

INTERMEDIATE SCENARIO		2010	2015	2020	2030
Connections	National grid	6,9%	21,4%	35,5%	55,1%
	Hydro mini-grid	0,0%	0,6%	0,7%	0,4%
	Biomass mini-grid	0,0%	0,5%	0,5%	0,3%
	Existing diesel mini-grid	4,4%	2,8%	2,6%	1,9%
	New diesel mini-grid	0,0%	2,9%	2,8%	1,3%
	Solar home systems	0,0%	1,4%	3,0%	1,6%
	Total percentage of rural households	11%	30%	45%	61%
Village coverage	National grid	10,9%	28,4%	46,1%	78,3%
	Hydro mini-grid	0,0%	1,8%	1,5%	0,6%
	Biomass mini-grid	0,0%	1,5%	1,2%	0,6%
	Existing diesel mini-grid	11,9%	7,3%	5,4%	2,7%
	New diesel mini-grid	0,0%	7,6%	5,6%	1,8%
	Existing battery charging stations	34,7%	20,8%	14,4%	7,0%
	Solar battery charging stations	0,0%	13,0%	26,0%	9,1%
	Total percentage of rural villages	57%	80%	100%	100%

CONSERVATIVE SCENARIO		2010	2015	2020	2030
Connections	National grid	6,9%	16,3%	25,8%	41,0%
	Hydro mini-grid	0,0%	0,7%	0,9%	0,9%
	Biomass mini-grid	0,0%	0,6%	0,7%	0,5%
	Existing diesel mini-grid	4,4%	4,2%	4,3%	3,9%
	New diesel mini-grid	0,0%	3,9%	4,6%	3,5%
	Solar home systems	0,0%	2,0%	4,3%	3,3%
	Total percentage of rural households	11%	28%	41%	53%
Village coverage	National grid	10,9%	19,7%	28,4%	46,1%
	Hydro mini-grid	0,0%	1,8%	1,8%	1,6%
	Biomass mini-grid	0,0%	1,6%	1,4%	1,1%
	Existing diesel mini-grid	11,9%	9,8%	8,4%	6,4%
	New diesel mini-grid	0,0%	9,6%	8,6%	6,0%
	Existing battery charging stations	34,7%	23,6%	20,0%	13,8%
	Solar battery charging stations	0,0%	15,7%	31,4%	25,1%
	Total percentage of rural villages	57%	82%	100%	100%

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 50: Share of national and off grid connections for HH to 2030_3 scenarios







Figure 51: Evolution of village coverage for different technologies




5.3.2 Regarding investment costs:

- The global investment cost (including national grid, mini-grid and stand-alone systems) is 680 MUSD in the conservative scenario as compared to 880 and 1000 in the other two scenarios, which is an important difference. However, though all villages are covered in all three cases, only 50% instead of 70% HH are covered by grid equivalent supply in the conservative scenario.
- The requirements for grid investment reduce from 890MUSD to 420MUSD in which the requirement for MV investments reduces from 344MUSD to 143MUSD, thus bringing the responsibilities of EDC in terms of MV back bone financing and construction to very manageable levels.
- For the first 5 years regarding the grid requirements,
 - The conservative scenario staggers grid investments to a very manageable 123MUSD (50MUSD for MV) ,
 - down from an ambitious 327 MUSD (143 for MV) in the baseline scenario and
 - from 200MUSD (84 for MV) in the intermediate scenario
- However, in order to still reach the village and household coverage targets, the consequence is that globally mini-grid and stand-alone investment requirements rise tremendously:
 - In the baseline scenario to 2030, 76MUSD are required for mini grids and 40MUSD for stand alone options;
 - In the intermediate scenario, these figures increase to 101MUSD and 96MUSD;
 - They reach 124MUSD and 131 MUSD for the conservative scenario.
- These figures show the depth of the potential off grid market and of private sector investment, as for the time being, there is no public financing of off grid options envisaged other than a bulk procurement of some 14 000 SHS by the REF. However, for the private sector to mobilise on this segment, a tremendous amount of work still is required by way of developing the legal framework, business and financing models. In order to meet targets for 2015, it is already doubtful in any of the three scenarios that the required financing for mini grid and stand alone options could be mobilised:
 - 72MUSD for mini grids and 19MUSD for stand alone systems are needed for the first 5 years in the baseline scenario
 - 91MUSD and 46MUSD in the intermediate scenario
 - Culminating to 109MUSD for mini-grids and 62MUSD for stand alone systems till 2015 for the conservative scenario....

Hence, by no means is the conservative scenario “conservative” with regards to fund mobilisation from the private sector, or more broadly for off grid solutions bearing in mind the mobilisation to date is albeit marginal.

Figure 52: Breakdown of investments by technology – 3 scenarios



In case the proposed new diesel projects are hybridised with PV, the additional costs range between 21 to 45 MUSD as shown below:

Table 42: Installed capacity and investment costs for hybrid PV/diesel in three scenarios (investment costs include panels, electronics and batteries only, diesel gensets are excluded)

Capacity range (kW)	Proposed solution	Baseline			Intermediate			Conservative		
		Number of projects	PV installed capacity (kWp)	Investment cost ('000 USD)	Number of projects	PV installed capacity (kWp)	Investment cost ('000 USD)	Number of projects	PV installed capacity (kWp)	Investment cost ('000 USD)
<30	100% storage	7	37	237	9	40	258	10	46	296
30-100	50% storage	43	523	2 934	67	780	4 375	77	928	5 204
>100	0% storage	100	3 773	17 846	160	6 120	28 948	205	8 392	39 696
Total		150	4 333	21 017	236	6 940	33 581	292	9 366	45 195

5.3.3 Length of MV lines added per year


The MV extension efforts are much smoother in the intermediate scenario than in the baseline scenario, but the first phase (2011-2020) remains more intensive than the second one. Most remote villages targeted by EDC until 2020 are connected here at the end of the 2011-2020 period, because of the least-cost prioritisation done by GEOSIM, which explains why there is suddenly more MV lines added in 2020. However, the actual practice may be slightly different, with long MV backbone lines coming first, depending on political choices rather than techno-economic optimisation.

In the conservative scenario, the chart illustrates that efforts are constant over the planning period.

Km of MV lines added	2011-2015	2016-2020	2021-2030	TOTAL
Baseline scenario	7 171	5 910	4 164	17 246
Intermediate scenario	4 214	2 957	5 910	13 082
Conservative scenario	2 489	1 725	2 957	7 171

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 53 : Breakdown of investments by technology – Details by scenario



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Table 43: Detailed grid & off grid investment costs, 3 periods & 3 scenarios (in '000 of USD)

BASELINE SCENARIO

Investment costs in rural areas ('000 USD)	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	143 429	118 203	83 282
Distribution (transformers, LV, meters)	183 994	158 735	203 490
Subtotal grid extension	327 423	276 938	286 772
Hydro mini-grid	31 492	861	233
Biomass mini-grid	16 363	581	171
New diesel mini-grid	23 906	2 382	392
Subtotal mini-grid projects	71 761	3 824	796
Solar home systems	6 698	8 272	0
Community PV	2 190	2 190	0
Solar battery charging stations	10 368	10 564	0
Subtotal stand-alone systems	19 255	21 025	0
Total	418 440	301 787	287 568

INTERMEDIATE SCENARIO

Investment costs in rural areas ('000 USD)	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	84 286	59 143	118 203
Distribution (transformers, LV, meters)	116 008	113 812	191 409
Subtotal grid extension	200 294	172 955	309 612
Hydro mini-grid	34 204	1 194	813
Biomass mini-grid	19 810	870	482
New diesel mini-grid	37 302	5 134	1 779
Subtotal mini-grid projects	91 317	7 199	3 074
Solar home systems	14 438	17 937	0
Community PV	4 779	4 779	0
Solar battery charging stations	26 792	27 293	0
Subtotal stand-alone systems	46 009	50 009	0
Total	337 620	230 163	312 685

CONSERVATIVE SCENARIO

Investment costs in rural areas ('000 USD)	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	49 785	34 501	59 143
Distribution (transformers, LV, meters)	73 163	73 722	133 119
Subtotal grid extension	122 948	108 223	192 261
Hydro mini-grid	37 604	1 327	1 067
Biomass mini-grid	22 679	1 115	718
New diesel mini-grid	48 429	7 558	3 398
Subtotal mini-grid projects	108 713	10 000	5 184
Solar home systems	20 442	25 323	1 143
Community PV	6 295	6 295	0
Solar battery charging stations	35 546	36 207	0
Subtotal stand-alone systems	62 283	67 825	1 143
Total	293 944	186 048	198 588

5.3.4 Investment costs per household and per village

As shown below, investment costs per village are relatively similar in the three scenarii. They are slightly higher in the conservative scenario, because this scenario follows only the beginning of the EDC extension plan, with a large share of backbone extension and little densification.

Table 44: Investment costs for grid extension per household and village, 3 periods & 3 scenarios

Phase	Baseline scenario		Intermediate scenario		Conservative scenario	
	Cost per village (USD)	Cost per HH (USD)	Cost per village (USD)	Cost per HH (USD)	Cost per village (USD)	Cost per HH (USD)
2011-2015	73 894	575	90 836	533	110 664	500
2016-2020	68 312	514	77 698	419	98 924	383
2021-2030	137 409	393	76 372	435	86 371	351
2011-2030	84 292	485	80 479	455	95 561	394

In the conservative scenario, the cost per household is overall cheaper than in the baseline scenario: 394USD / HH against 485. This is because the coverage rate is much lower in the conservative scenario, and hence the focus is on the more populated settlements.

More generally, investment costs for all technologies (not only national grid but also mini-grids and stand-alones) are also slightly lower in the conservative scenario for the same reasons:




Table 45: Investment costs for all technologies per household, 3 periods & 3 scenarios (in USD per household)

Phase	Baseline	Intermediate	Conservative
2011-2015	697	701	687
2016-2020	573	503	477
2021-2030	453	504	382
2011-2030	572	565	508

The below show the length of MV lines which are to be added every year, with the corresponding average length per new village connected.

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 54: Length of MV lines added




5.3.5 Twice as many mini grid projects in the conservative scenario

In line with the investment analysis above, the following tables show that being conservative regarding grid extension during the first years because of financial constraints, while still aiming at achieving the same village connection rates implies that we reach 376 projects mini grid projects required over the 20 years instead of 208; total capacity installed increases from 38 MW to 70MW. It must also be noted here that diesel based mini grids, in all three scenarios account for about 3/4 of all the mini grids. This is due to the site specific nature of hydro power production and biomass based power generation. It also calls upon the planner to seriously consider all options for reducing the cost of diesel based mini grids power generation, through all forms of possible hybrids including solar PV.

Table 46: Number of mini-grids and capacity by technology for the 3 scenarios

Mini-grid projects in rural areas by 2015	Baseline		Intermediate		Conservative	
	Number of projects	Total Installed capacity (kW)	Number of projects	Total Installed capacity (kW)	Number of projects	Total Installed capacity (kW)
Hydro mini-grid	33	6 449	35	6 639	38	7 309
Biomass mini-grid	25	10 317	38	13 832	49	16 207
New diesel mini-grid	150	21 663	233	34 701	289	46 833
Total	208	38 429	306	55 171	376	70 348

Figure 55: Number of mini grids projects, all scenarios



Logically, investment costs also follow the same trend in terms of total numbers, with a very high effort during the first period in order to meet the 2015 target. Again, as already discussed, this does not seem to be realistic in terms of private sector mobilisation, and one should probably develop yet another scenario staggering this off grid investment requirement.

Table 47: Investment costs for mini-grid technologies (in '000 of USD)

BASELINE	2011-2015	2016-2020	2021-2030	2011-2030
Hydro mini-grid	31 492	861	233	32 586
Biomass mini-grid	16 363	581	171	17 115
New diesel mini-grid	23 906	2 382	392	26 681
Total mini-grid projects	71 761	3 824	796	76 382

INTERMEDIATE	2011-2015	2016-2020	2021-2030	2011-2030
Hydro mini-grid	34 204	1 194	813	36 212
Biomass mini-grid	19 810	870	482	21 162
New diesel mini-grid	37 302	5 134	1 779	44 216
Total mini-grid projects	91 317	7 199	3 074	101 589

CONSERVATIVE	2011-2015	2016-2020	2021-2030	2011-2030
Hydro mini-grid	37 604	1 327	1 067	39 998
Biomass mini-grid	22 679	1 115	718	24 513
New diesel mini-grid	48 429	7 558	3 398	59 385
Total mini-grid projects	108 713	10 000	5 184	123 896

5.3.6 Stand alone systems

Stand alone systems include battery charging stations (BCS), community PV and Solar Home Systems (SHS). Existing battery charging stations account for 35% of village coverage to date and then reduces over time to reach 4% in the baseline scenario, 16% in the intermediate scenario and 39% in the conservative scenario.

Given the intermediate targets fixed by the RGC, all these stand alone systems are modelled to be installed before 2020, and the investment amount over the coming 10 years is far from negligible for SHS, PV BCS and Community PV combined: 40 MUSD in the baseline scenario, 96 MUSD in the intermediate scenario and 130 MUSD in the conservative scenario. How realistic this is remains an open question. It must also be born in mind that SREP figures for potential SHS is just a potential figure covering all the rich, non served households.

Figure 56: Number of standalone systems, all scenarios




Figure 57: Number of standalone systems, all scenarios




Table 48: Number of standalone systems to install, all scenarios

BASELINE SCENARIO	2011-2015	2016-2020
Solar home systems (new kits)	16 744	20 679
Community PV (new villages)	997	997
Solar battery charging stations (new villages)	569	455

INTERMEDIATE SCENARIO	2011-2015	2016-2020
Solar home systems (new kits)	36 094	44 842
Community PV (new villages)	2 539	2 539
Solar battery charging stations (new villages)	1635	1308

CONSERVATIVE SCENARIO	2011-2015	2016-2020
Solar home systems (new kits)	51 105	63 308
Community PV (new villages)	3 238	3 237
Solar battery charging stations (new villages)	1980	1584

Table 49: Breakdown of investments in standalone systems, all scenarios (in '000 USD)


BASELINE SCENARIO	2011-2015	2016-2020
Solar home systems (new kits)	6 698	8 272
Community PV (new villages)	2 190	2 190
Solar battery charging stations (new villages)	10368	10564

INTERMEDIATE SCENARIO	2011-2015	2016-2020
Solar home systems (new kits)	14 438	17 937
Community PV (new villages)	4 779	4 779
Solar battery charging stations (new villages)	26792	27293

CONSERVATIVE SCENARIO	2011-2015	2016-2020
Solar home systems (new kits)	20 442	25 323
Community PV (new villages)	6 295	6 295
Solar battery charging stations (new villages)	35546	36207


SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 60: 2030 Map of mini-grid projects (baseline scenario)




SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 61 : 2030 Map of mini-grid projects (intermediate scenario)




SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 63: 2030 Map of candidates for stand-alone systems (baseline scenario)




SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 64: 2030 Map of candidates for stand-alone systems (intermediate scenario)



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Figure 65: 2030 Map of candidates for stand-alone systems (conservative scenario)



6 SUMMARY PROVINCIAL RESULTS FOR THE BASELINE SCENARIO

6.1 INTRODUCTION

In this chapter, detailed results province by province will be presented for the baseline scenario only. Please note that separate provincial brochures give further details on each province and for the three scenarios.

Results for each province are presented in separate sections, containing:

- A map showing the planned EDC lines for 2020²⁰, as well as current REE and EDC license zones, and the proposed mini-grid projects (hydro, biomass, diesel). Candidate villages for stand-alone systems are represented as well.
- Various tables, providing indications on:
 - Household and village coverage rate for different time horizons (2010, 2015, 2020 and 2030), with the breakdown per technology
 - Additional length of MV lines and demand for grid extension
 - Number of mini-grid projects and cumulated installed capacity. Please note that only mini-grid projects, with the powerhouse inside the province are included in this table. However, some villages and households of the province may be electrified by a cross-border project, with the powerhouse located in another province.
 - Number of stand-alone systems to be installed for different phases
 - Total investment costs per phase and per technology. NB: in this table, investment costs for mini-grid projects have been split by village. Therefore, cross-border projects may still result in investment costs in this province. For example, with a project costing 300,000 USD and supplying 2 villages in province A and 1 village in province B, 200,000 USD of investment will be affected to province A, and 100,000 USD will be affected to province B.

6.2 PROVINCIAL DISTRIBUTION OF INVESTMENTS UNTIL 2015

Investment costs per province for the 2011-2015 phase are summarized in the following table:

Table 50: Investment cost for the 2011-2015 phase by province and technology in the baseline scenario ('000 USD)

Province	National grid	Hydro mini-grid	Biomass mini-grid	New diesel mini-grid	Solar home systems	Community PV	Solar BCS	Total
Banteay Meanchey	8 845	0	899	113	111	47	133	10 148
Battambang	10 479	1 381	2 761	113	198	72	242	15 247
Kampong Cham	27 533	1 031	998	661	705	186	1 119	32 231
Kampong Chhnang	4 610	3 054	262	2 344	349	134	377	11 130
Kampong Speu	1 889	1 570	59	6 336	297	109	699	10 959
Kampong Thom	11 299	2 074	1 107	851	325	129	635	16 420
Kampot	8 053	0	237	947	633	124	854	10 848
Kandal	9 906	0	2 142	0	561	154	933	13 696
Kep	392	0	0	0	0	0	0	392
Koh Kong	594	1 925	2 147	291	33	19	76	5 084

²⁰ Although we have done some simulation until and before 2020 using the GEOSIM® grid extension module, this was only necessary to determine the potential for mini-grid projects, and therefore maps show only the official grid extension lines in order to be consistent with the plans made by EDC.

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Province	National grid	Hydro mini-grid	Biomass mini-grid	New diesel mini-grid	Solar home systems	Community PV	Solar BCS	Total
Kracheh	5 237	172	199	345	172	84	270	6 478
Mondul Kiri	0	4 931	0	220	26	25	45	5 247
Otdar Meanchey	740	0	1 837	1 192	174	80	307	4 330
Pailin	581	455	312	0	12	6	23	1 388
Preah Sihanouk	988	1 152	0	0	12	2	0	2 154
Preah Vihear	220	543	0	699	286	182	390	2 320
Prey Veng	17 963	0	0	1 208	946	237	1 308	21 663
Pursat	5 902	1 860	0	1 245	218	89	301	9 614
Ratanak Kiri	105	5 677	0	746	102	51	382	7 062
Siem Reap	11 657	2 933	969	1 931	212	68	264	18 034
Stung Treng	404	2 736	2 434	57	94	70	235	6 029
Svay Rieng	5 243	0	0	3 763	983	249	1 341	11 579
Takeo	10 789	0	0	846	249	74	434	12 392
Total	132 640	31 492	16 363	23 060	6 449	2 116	9 934	222 054

The following table splits the 23 provinces into 4 groups for each technology and for the total investment, using the k-means statistical method.


Table 51 Classification of provinces into 4 groups by investment costs in each technology (1-green means highest investment, 4-red means lowest)

Province	National grid	Hydro mini-grid	Biomass mini-grid	New diesel mini-grid	Stand-alone systems	Total
Banteay Meanchey	3	4	3	4	4	3
Battambang	3	3	1	4	3	2
Kampong Cham	1	3	3	3	2	1
Kampong Chhnang	4	2	4	3	3	3
Kampong Speu	4	3	4	1	3	3
Kampong Thom	3	3	3	3	3	2
Kampot	3	4	4	3	2	3
Kandal	3	4	2	4	2	3
Kep	4	4	4	4	4	4
Koh Kong	4	3	2	4	4	4
Kracheh	4	4	4	4	3	4
Mondul Kiri	4	1	4	4	4	4
Otdar Meanchey	4	4	2	3	3	4
Pailin	4	4	4	4	4	4
Preah Sihanouk	4	3	4	4	4	4
Preah Vihear	4	4	4	3	3	4
Prey Veng	2	4	4	3	1	2
Pursat	3	3	4	3	3	3
Ratanak Kiri	4	1	4	3	3	4
Siem Reap	3	2	3	3	3	2
Stung Treng	4	2	1	4	3	4
Svay Rieng	4	4	4	2	1	3
Takeo	3	4	4	3	3	3

The above table leads to the following remarks:

- Highly populated provinces such as Kampong Cham, Battambang, Prey Veng and Siem Reap naturally require the highest total investment costs. Kampong Thom is an exception to this rule, with relatively high investment costs for all technologies and a low population
- Grid expansion efforts are highest in the provinces around the existing main systems, i.e. Phnom Penh system (Kandal, Takeo, Prey Veng, Kampot) and the Western System (Banteay Meanchey, Battambang, Siem Reap). Pursat and Kampong Thom also enjoy significant investments in backbone infrastructure, being located between these two large systems due to be interconnected. Some remote provinces such as Mondul Kiri, Rattanak Kiri and Preah Vihear are also supposed to build very long MV lines, but due to the least-cost optimisation algorithm used to prioritise the lines until 2020, most of them have been assumed for the 2016-2020 period, which is not included in the above table. This may not happen this way in reality, as there may be a political will to extend the grid much sooner in these provinces, even if not profitable (but of course provided transmission lines do reach them).
- Hydro potential investments focus on the North-Eastern province (Rattanak Kiri, Mondul Kiri, Stung Treng), while the theoretical technical potential in the West and South-Western part (Battambang, Pursat, Kampot, Koh Kong), is kept in check by the quick development of the national grid
- Biomass investments are naturally higher where large cogeneration projects have been identified, e.g. Battambang, Otdar Meanchey, Stung Treng, Kandal and Koh Kong. These large projects tend to distort the actual representation in terms of number of projects, which should give the preference to North-Western provinces around the Tonle Sap lake (Battambang, Banteay Meanchey, Siem Reap).
- Most proposed diesel projects are in provinces where grid investment are relatively modest, which seems sensible. But a closer look at maps reveals that they are never really far from the planned MV lines (cf. comments in 5.2.3), therefore attention will need to be paid to this risk factor for potential investors.
- Finally, investments in stand-alone systems is unexpectedly higher in provinces with high population and decent national grid coverage (existing and planned). On the other hand, remote provinces such as Mondul Kiri, Rattanak Kiri or Koh Kong are not in the top provinces in terms of stand-alone systems. This may be explained by the plain population factor, and the fact that even in province with very high levels of national grid coverage, many villages, although located “under the lines”, may still remain unelectrified until 2020.

6.3 BANTEAY MEANCHEY



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	4.4%	26.2%	52.3%	68.6%
	Hydro mini-grid	0.0%	0.0%	0.0%	0.0%
	Biomass mini-grid	0.0%	1.0%	0.0%	0.0%
	Existing diesel mini-grid	6.6%	3.0%	0.5%	0.3%
	New diesel mini-grid	0.0%	0.2%	0.0%	0.0%
	Solar home systems	0.0%	0.2%	0.5%	0.1%
	Total rural connections	11%	31%	53%	69%
Village coverage	National grid	6.1%	44.5%	93.8%	98.8%
	Hydro mini-grid	0.0%	0.0%	0.0%	0.0%
	Biomass mini-grid	0.0%	1.9%	0.0%	0.0%
	Existing diesel mini-grid	16.5%	7.5%	0.9%	0.3%
	New diesel mini-grid	0.0%	0.7%	0.0%	0.0%
	Existing battery charging stations	37.4%	18.7%	3.1%	0.7%
	Solar battery charging stations	0.0%	1.1%	2.3%	0.2%
	Total rural villages	60%	74%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	442	386	68
Grid demand of newly connected villages (GWh/year)	22	17	3

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	0	0
Biomass mini-grid	5	606
New diesel mini-grid	2	96
Total	7	702

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)

	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	278	346	0
Community PV (new villages)	16	15	0
Solar battery charging stations (new villages)	7	5	0


Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	8,845	7,729	1,355
Distribution (transformers, LV, meters)	8,886	9,961	5,799
Subtotal grid extension	17,732	17,690	7,154
Hydro mini-grid	0	0	0
Biomass mini-grid	899	24	0
New diesel mini-grid	113	2	0
Subtotal mini-grid projects	1,012	27	0
Solar home systems	111	138	4
Community PV	47	47	0
Solar battery charging stations	133	136	0
Subtotal stand-alone systems	291	321	4
Total	19,035	18,038	7,158

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

6.4 BATTAMBANG



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	9.4%	37.6%	53.7%	67.9%
	Hydro mini-grid	0.0%	0.2%	0.3%	0.3%
	Biomass mini-grid	0.0%	0.8%	0.7%	0.0%
	Existing diesel mini-grid	7.1%	2.4%	1.8%	0.5%
	New diesel mini-grid	0.0%	0.2%	0.0%	0.0%
	Solar home systems	0.0%	0.3%	0.6%	0.2%
	Total rural connections	17%	41%	57%	69%
Village coverage	National grid	18.9%	65.1%	86.5%	94.4%
	Hydro mini-grid	0.0%	1.7%	1.7%	1.4%
	Biomass mini-grid	0.0%	3.0%	1.7%	0.0%
	Existing diesel mini-grid	20.2%	6.1%	2.6%	0.8%
	New diesel mini-grid	0.0%	0.3%	0.0%	0.0%
	Existing battery charging stations	33.0%	10.0%	4.1%	1.5%
	Solar battery charging stations	0.0%	1.8%	3.5%	2.0%
	Total rural villages	72%	88%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	524	217	225
Grid demand of newly connected villages (GWh/year)	47	8	11

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	2	420
Biomass mini-grid	4	2,878
New diesel mini-grid	1	101
Total	7	3,399

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)

	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	496	638	0
Community PV (new villages)	25	25	0
Solar battery charging stations (new villages)	12	9	0


Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	10,479	4,348	4,493
Distribution (transformers, LV, meters)	15,767	9,220	11,172
Subtotal grid extension	26,247	13,567	15,665
Hydro mini-grid	1,381	34	31
Biomass mini-grid	2,761	107	33
New diesel mini-grid	113	19	0
Subtotal mini-grid projects	4,255	160	63
Solar home systems	198	255	0
Community PV	72	72	0
Solar battery charging stations	242	248	0
Subtotal stand-alone systems	513	575	0
Total	31,014	14,302	15,729

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

6.5 KAMPONG CHAM



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	7.4%	36.3%	53.0%	68.4%
	Hydro mini-grid	0.0%	0.1%	0.0%	0.0%
	Biomass mini-grid	0.0%	0.2%	0.2%	0.0%
	Existing diesel mini-grid	5.1%	1.1%	0.9%	0.1%
	New diesel mini-grid	0.0%	0.4%	0.1%	0.0%
	Solar home systems	0.0%	0.5%	1.0%	0.1%
	Total rural connections	12%	39%	55%	69%
Village coverage	National grid	12.5%	62.9%	85.7%	98.0%
	Hydro mini-grid	0.0%	0.4%	0.0%	0.0%
	Biomass mini-grid	0.0%	0.7%	0.6%	0.1%
	Existing diesel mini-grid	15.1%	4.2%	2.1%	0.3%
	New diesel mini-grid	0.0%	1.0%	0.1%	0.0%
	Existing battery charging stations	31.9%	8.3%	4.2%	0.2%
	Solar battery charging stations	0.0%	3.7%	7.3%	1.4%
	Total rural villages	59%	81%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	1,377	476	328
Grid demand of newly connected villages (GWh/year)	103	17	21

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	0	0
Biomass mini-grid	1	800
New diesel mini-grid	5	617
Total	6	1,417

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)


	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	1,762	2,129	0
Community PV (new villages)	96	97	0
Solar battery charging stations (new villages)	62	49	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	27,533	9,519	6,560
Distribution (transformers, LV, meters)	35,840	18,700	21,770
Subtotal grid extension	63,373	28,219	28,330
Hydro mini-grid	1,031	0	0
Biomass mini-grid	998	49	14
New diesel mini-grid	661	19	5
Subtotal mini-grid projects	2,689	69	19
Solar home systems	705	852	0
Community PV	186	186	0
Solar battery charging stations	1,119	1,136	0
Subtotal stand-alone systems	2,009	2,173	0
Total	68,071	30,461	28,349

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

6.6 KAMPONG CHHNANG



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	3.4%	18.8%	39.1%	66.0%
	Hydro mini-grid	0.0%	1.6%	0.6%	0.1%
	Biomass mini-grid	0.0%	0.3%	0.2%	0.0%
	Existing diesel mini-grid	2.5%	1.4%	0.8%	0.0%
	New diesel mini-grid	0.0%	5.1%	5.0%	0.0%
	Solar home systems	0.0%	0.9%	1.9%	0.1%
	Total rural connections	6%	28%	48%	66%
Village coverage	National grid	8.7%	37.5%	74.3%	98.1%
	Hydro mini-grid	0.0%	4.3%	0.9%	0.2%
	Biomass mini-grid	0.0%	0.8%	0.2%	0.0%
	Existing diesel mini-grid	8.5%	4.5%	1.7%	0.0%
	New diesel mini-grid	0.0%	8.1%	4.2%	0.0%
	Existing battery charging stations	43.8%	21.1%	11.3%	1.3%
	Solar battery charging stations	0.0%	3.7%	7.4%	0.4%
	Total rural villages	61%	80%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	230	273	324
Grid demand of newly connected villages (GWh/year)	12	12	17

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	1	815
Biomass mini-grid	1	191
New diesel mini-grid	10	2,342
Total	12	3,348

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)


	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	872	1,080	0
Community PV (new villages)	50	49	0
Solar battery charging stations (new villages)	20	16	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	4,610	5,468	6,478
Distribution (transformers, LV, meters)	5,414	6,709	12,191
Subtotal grid extension	10,024	12,177	18,669
Hydro mini-grid	3,054	52	13
Biomass mini-grid	262	14	1
New diesel mini-grid	2,344	297	17
Subtotal mini-grid projects	5,660	363	30
Solar home systems	349	432	0
Community PV	134	134	0
Solar battery charging stations	377	384	0
Subtotal stand-alone systems	860	950	0
Total	16,543	13,489	18,700

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

6.7 KAMPONG SPEU



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	3.2%	9.0%	41.8%	66.1%
	Hydro mini-grid	0.0%	0.7%	1.1%	0.0%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	0.3%	0.7%	0.3%	0.1%
	New diesel mini-grid	0.0%	7.6%	1.5%	0.0%
	Solar home systems	0.0%	0.5%	1.1%	0.4%
	Total rural connections	4%	19%	46%	67%
Village coverage	National grid	6.0%	13.9%	85.7%	95.7%
	Hydro mini-grid	0.0%	0.7%	0.7%	0.1%
	Biomass mini-grid	0.0%	0.1%	0.0%	0.0%
	Existing diesel mini-grid	2.4%	2.3%	0.5%	0.1%
	New diesel mini-grid	0.0%	17.2%	2.1%	0.0%
	Existing battery charging stations	28.6%	17.6%	3.1%	1.1%
	Solar battery charging stations	0.0%	3.9%	7.8%	3.1%
	Total rural villages	37%	56%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	94	1,043	186
Grid demand of newly connected villages (GWh/year)	6	37	10

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	1	241
Biomass mini-grid	1	650
New diesel mini-grid	48	5,369
Total	50	6,261

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)


	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	742	937	0
Community PV (new villages)	70	71	0
Solar battery charging stations (new villages)	51	40	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	1,889	20,862	3,725
Distribution (transformers, LV, meters)	3,279	20,874	12,390
Subtotal grid extension	5,168	41,736	16,116
Hydro mini-grid	1,570	97	24
Biomass mini-grid	59	0	0
New diesel mini-grid	6,336	325	43
Subtotal mini-grid projects	7,966	422	67
Solar home systems	297	375	45
Community PV	109	109	0
Solar battery charging stations	699	712	0
Subtotal stand-alone systems	1,105	1,196	45
Total	14,238	43,354	16,227

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

6.8 KAMPONG THOM



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	0.0%	26.0%	46.6%	66.1%
	Hydro mini-grid	0.0%	1.2%	0.5%	0.0%
	Biomass mini-grid	0.0%	0.4%	0.4%	0.0%
	Existing diesel mini-grid	6.6%	1.1%	0.7%	0.7%
	New diesel mini-grid	0.0%	1.3%	0.2%	0.0%
	Solar home systems	0.0%	0.6%	1.2%	0.4%
	Total rural connections	7%	31%	50%	67%
Village coverage	National grid	0.0%	50.5%	82.4%	94.0%
	Hydro mini-grid	0.0%	3.2%	1.1%	0.0%
	Biomass mini-grid	0.0%	1.4%	0.6%	0.0%
	Existing diesel mini-grid	17.3%	3.9%	1.5%	1.0%
	New diesel mini-grid	0.0%	3.4%	0.4%	0.0%
	Existing battery charging stations	30.5%	10.6%	4.9%	1.7%
	Solar battery charging stations	0.0%	4.5%	9.1%	3.4%
	Total rural villages	48%	78%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	565	314	199
Grid demand of newly connected villages (GWh/year)	36	13	9

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	2	400
Biomass mini-grid	1	700
New diesel mini-grid	6	810
Total	9	1,910

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)


	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	813	1,006	0
Community PV (new villages)	50	50	0
Solar battery charging stations (new villages)	33	26	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	11,299	6,279	3,987
Distribution (transformers, LV, meters)	13,395	9,058	9,669
Subtotal grid extension	24,694	15,337	13,656
Hydro mini-grid	2,074	100	11
Biomass mini-grid	1,107	34	5
New diesel mini-grid	851	47	2
Subtotal mini-grid projects	4,031	181	17
Solar home systems	325	402	3
Community PV	129	129	0
Solar battery charging stations	635	646	0
Subtotal stand-alone systems	1,089	1,177	3
Total	29,815	16,695	13,676

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

6.9 KAMPOT



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	6.2%	33.9%	46.0%	67.7%
	Hydro mini-grid	0.0%	0.0%	0.0%	0.0%
	Biomass mini-grid	0.0%	0.2%	0.3%	0.0%
	Existing diesel mini-grid	0.9%	0.3%	0.4%	0.0%
	New diesel mini-grid	0.0%	1.7%	2.3%	0.0%
	Solar home systems	0.0%	1.3%	2.6%	0.0%
	Total rural connections	7%	37%	52%	68%
Village coverage	National grid	15.3%	66.0%	68.6%	99.8%
	Hydro mini-grid	0.0%	0.0%	0.0%	0.0%
	Biomass mini-grid	0.0%	0.7%	0.7%	0.0%
	Existing diesel mini-grid	3.7%	1.3%	1.1%	0.0%
	New diesel mini-grid	0.0%	4.4%	4.4%	0.0%
	Existing battery charging stations	42.3%	14.2%	13.3%	0.0%
	Solar battery charging stations	0.0%	6.0%	12.0%	0.2%
	Total rural villages	61%	92%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	403	7	281
Grid demand of newly connected villages (GWh/year)	31	0	19

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	0	0
Biomass mini-grid	1	158
New diesel mini-grid	3	829
Total	4	987

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)


	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	1,582	1,908	0
Community PV (new villages)	58	58	0
Solar battery charging stations (new villages)	28	22	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	8,053	143	5,629
Distribution (transformers, LV, meters)	10,778	3,850	12,884
Subtotal grid extension	18,831	3,992	18,513
Hydro mini-grid	0	0	0
Biomass mini-grid	237	22	3
New diesel mini-grid	947	152	26
Subtotal mini-grid projects	1,184	173	29
Solar home systems	633	763	0
Community PV	124	124	0
Solar battery charging stations	854	870	0
Subtotal stand-alone systems	1,611	1,757	0
Total	21,626	5,923	18,542

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

6.10 KANDAL



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	19.6%	45.5%	55.6%	68.1%
	Hydro mini-grid	0.0%	0.0%	0.0%	0.0%
	Biomass mini-grid	0.0%	0.5%	0.6%	0.0%
	Existing diesel mini-grid	7.0%	1.2%	1.5%	0.0%
	New diesel mini-grid	0.0%	0.0%	0.0%	0.0%
	Solar home systems	0.0%	0.6%	1.2%	0.0%
	Total rural connections	27%	48%	59%	68%
Village coverage	National grid	24.5%	59.2%	68.9%	97.5%
	Hydro mini-grid	0.0%	0.0%	0.0%	0.0%
	Biomass mini-grid	0.0%	4.4%	3.2%	0.3%
	Existing diesel mini-grid	15.8%	5.6%	5.6%	0.1%
	New diesel mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing battery charging stations	27.4%	9.4%	7.6%	0.0%
	Solar battery charging stations	0.0%	7.3%	14.7%	2.1%
	Total rural villages	68%	86%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	495	65	278
Grid demand of newly connected villages (GWh/year)	61	2	21

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	0	0
Biomass mini-grid	3	1,045
New diesel mini-grid	0	0
Total	3	1,045

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)


	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	1,402	1,701	0
Community PV (new villages)	110	109	0
Solar battery charging stations (new villages)	72	58	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	9,906	1,295	5,556
Distribution (transformers, LV, meters)	17,885	7,156	16,514
Subtotal grid extension	27,791	8,450	22,070
Hydro mini-grid	0	0	0
Biomass mini-grid	2,142	97	39
New diesel mini-grid	0	0	0
Subtotal mini-grid projects	2,142	97	39
Solar home systems	561	680	0
Community PV	154	154	0
Solar battery charging stations	933	950	0
Subtotal stand-alone systems	1,648	1,785	0
Total	31,581	10,332	22,109

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

6.11 KOH KONG



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	4.4%	22.5%	30.6%	49.6%
	Hydro mini-grid	0.0%	2.7%	3.9%	3.3%
	Biomass mini-grid	0.0%	4.2%	3.6%	0.6%
	Existing diesel mini-grid	27.4%	15.4%	17.1%	10.9%
	New diesel mini-grid	0.0%	2.0%	1.5%	0.9%
	Solar home systems	0.0%	0.4%	0.9%	0.9%
	Total rural connections	32%	47%	58%	66%
Village coverage	National grid	0.9%	17.8%	28.0%	50.5%
	Hydro mini-grid	0.0%	12.1%	12.1%	9.3%
	Biomass mini-grid	0.0%	14.0%	9.3%	1.9%
	Existing diesel mini-grid	57.9%	33.6%	30.8%	21.5%
	New diesel mini-grid	0.0%	6.5%	3.7%	1.9%
	Existing battery charging stations	12.1%	2.8%	2.8%	2.8%
	Solar battery charging stations	0.0%	6.5%	13.1%	12.1%
	Total rural villages	71%	93%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	30	37	95
Grid demand of newly connected villages (GWh/year)	4	2	5

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	3	203
Biomass mini-grid	1	750
New diesel mini-grid	4	316
Total	8	1,269

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)


	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	82	101	29
Community PV (new villages)	8	9	0
Solar battery charging stations (new villages)	7	6	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	594	744	1,905
Distribution (transformers, LV, meters)	905	554	1,903
Subtotal grid extension	1,499	1,298	3,809
Hydro mini-grid	1,925	47	31
Biomass mini-grid	2,147	45	26
New diesel mini-grid	291	25	7
Subtotal mini-grid projects	4,362	117	64
Solar home systems	33	40	18
Community PV	19	19	0
Solar battery charging stations	76	77	0
Subtotal stand-alone systems	128	136	18
Total	5,989	1,552	3,890

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

6.12 KRACHEH



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	4.8%	34.2%	49.2%	64.9%
	Hydro mini-grid	0.0%	0.1%	0.2%	0.2%
	Biomass mini-grid	0.0%	0.3%	0.5%	0.0%
	Existing diesel mini-grid	2.9%	1.3%	1.8%	0.7%
	New diesel mini-grid	0.0%	1.0%	0.0%	0.0%
	Solar home systems	0.0%	0.7%	1.5%	0.5%
	Total rural connections	8%	38%	53%	66%
Village coverage	National grid	9.5%	63.6%	72.3%	90.5%
	Hydro mini-grid	0.0%	0.4%	0.4%	0.4%
	Biomass mini-grid	0.0%	0.4%	0.4%	0.0%
	Existing diesel mini-grid	12.6%	5.2%	3.9%	0.9%
	New diesel mini-grid	0.0%	2.6%	0.0%	0.0%
	Existing battery charging stations	43.7%	13.0%	10.4%	3.0%
	Solar battery charging stations	0.0%	6.3%	12.6%	5.2%
	Total rural villages	66%	92%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	262	79	192
Grid demand of newly connected villages (GWh/year)	20	3	7

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	1	200
Biomass mini-grid	1	300
New diesel mini-grid	1	307
Total	3	807

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)


	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	430	548	0
Community PV (new villages)	26	27	0
Solar battery charging stations (new villages)	15	12	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	5,237	1,574	3,846
Distribution (transformers, LV, meters)	5,855	2,802	5,330
Subtotal grid extension	11,092	4,376	9,176
Hydro mini-grid	172	7	4
Biomass mini-grid	199	20	4
New diesel mini-grid	345	53	0
Subtotal mini-grid projects	715	79	8
Solar home systems	172	219	3
Community PV	84	84	0
Solar battery charging stations	270	276	0
Subtotal stand-alone systems	526	579	3
Total	12,333	5,034	9,187

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

6.13 MONDUL KIRI



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	6.6%	7.1%	38.3%	57.4%
	Hydro mini-grid	0.0%	12.9%	2.5%	0.5%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	16.9%	15.3%	9.5%	5.2%
	New diesel mini-grid	0.0%	1.8%	0.0%	0.0%
	Solar home systems	0.0%	0.5%	1.0%	1.2%
	Total rural connections	23%	38%	51%	64%
Village coverage	National grid	10.1%	10.1%	65.2%	71.9%
	Hydro mini-grid	0.0%	32.6%	4.5%	1.1%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	43.8%	23.6%	13.5%	10.1%
	New diesel mini-grid	0.0%	3.4%	0.0%	0.0%
	Existing battery charging stations	25.8%	16.9%	9.0%	9.0%
	Solar battery charging stations	0.0%	3.9%	7.9%	7.9%
	Total rural villages	80%	90%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	0	253	26
Grid demand of newly connected villages (GWh/year)	0	4	2

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	6	981
Biomass mini-grid	0	0
New diesel mini-grid	2	134
Total	8	1,115

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)


	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	66	92	79
Community PV (new villages)	8	7	0
Solar battery charging stations (new villages)	4	3	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	0	5,052	519
Distribution (transformers, LV, meters)	30	2,633	1,244
Subtotal grid extension	30	7,685	1,763
Hydro mini-grid	4,931	118	11
Biomass mini-grid	0	0	0
New diesel mini-grid	220	7	0
Subtotal mini-grid projects	5,150	125	11
Solar home systems	26	37	32
Community PV	25	25	0
Solar battery charging stations	45	46	0
Subtotal stand-alone systems	96	108	32
Total	5,276	7,918	1,806

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

6.14 PREAH VIHEAR



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	0.0%	1.6%	17.9%	35.8%
	Hydro mini-grid	0.0%	0.8%	0.0%	0.0%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	4.5%	6.7%	5.4%	6.9%
	New diesel mini-grid	0.0%	3.5%	3.2%	3.0%
	Solar home systems	0.0%	1.9%	4.2%	3.5%
	Total rural connections	4%	14%	31%	49%
Village coverage	National grid	0.0%	2.5%	37.9%	51.5%
	Hydro mini-grid	0.0%	1.5%	0.0%	0.0%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	8.6%	7.6%	3.5%	3.5%
	New diesel mini-grid	0.0%	8.6%	6.1%	4.0%
	Existing battery charging stations	42.9%	38.4%	29.3%	21.2%
	Solar battery charging stations	0.0%	11.6%	23.2%	19.7%
	Total rural villages	52%	70%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	11	223	90
Grid demand of newly connected villages (GWh/year)	0	6	3

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	1	73
Biomass mini-grid	0	0
New diesel mini-grid	8	807
Total	9	880

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)


	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	716	961	0
Community PV (new villages)	52	52	0
Solar battery charging stations (new villages)	23	18	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	220	4,467	1,801
Distribution (transformers, LV, meters)	221	2,905	3,386
Subtotal grid extension	441	7,372	5,188
Hydro mini-grid	543	22	0
Biomass mini-grid	0	0	0
New diesel mini-grid	699	114	66
Subtotal mini-grid projects	1,242	135	66
Solar home systems	286	384	44
Community PV	182	182	0
Solar battery charging stations	390	400	0
Subtotal stand-alone systems	858	966	44
Total	2,541	8,474	5,298

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

6.15 PREY VENG



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	0.9%	27.6%	45.7%	67.8%
	Hydro mini-grid	0.0%	0.0%	0.0%	0.0%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	2.8%	0.7%	0.6%	0.0%
	New diesel mini-grid	0.0%	1.2%	1.2%	0.0%
	Solar home systems	0.0%	0.9%	2.0%	0.0%
	Total rural connections	4%	30%	50%	68%
Village coverage	National grid	1.7%	49.1%	77.4%	99.5%
	Hydro mini-grid	0.0%	0.0%	0.0%	0.0%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	6.5%	2.1%	1.0%	0.0%
	New diesel mini-grid	0.0%	2.7%	2.1%	0.0%
	Existing battery charging stations	49.8%	18.4%	9.2%	0.2%
	Solar battery charging stations	0.0%	5.2%	10.3%	0.4%
	Total rural villages	58%	77%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	898	333	407
Grid demand of newly connected villages (GWh/year)	55	15	27

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	0	0
Biomass mini-grid	0	0
New diesel mini-grid	7	1,141
Total	7	1,141

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)

	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	2,364	2,802	0
Community PV (new villages)	110	109	0
Solar battery charging stations (new villages)	58	46	0


Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	17,963	6,658	8,142
Distribution (transformers, LV, meters)	21,859	13,458	21,801
Subtotal grid extension	39,822	20,116	29,943
Hydro mini-grid	0	0	0
Biomass mini-grid	0	0	0
New diesel mini-grid	1,208	180	29
Subtotal mini-grid projects	1,208	180	29
Solar home systems	946	1,121	0
Community PV	237	237	0
Solar battery charging stations	1,308	1,327	0
Subtotal stand-alone systems	2,491	2,685	0
Total	43,521	22,981	29,972

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

6.16 PURSAT



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	1.7%	20.0%	46.7%	64.4%
	Hydro mini-grid	0.0%	1.2%	1.0%	0.0%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	8.2%	4.9%	0.3%	0.4%
	New diesel mini-grid	0.0%	2.9%	0.3%	0.0%
	Solar home systems	0.0%	0.7%	1.4%	0.6%
	Total rural connections	10%	30%	50%	65%
Village coverage	National grid	3.0%	32.3%	82.5%	92.2%
	Hydro mini-grid	0.0%	1.5%	1.1%	0.0%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	21.2%	13.9%	0.6%	0.6%
	New diesel mini-grid	0.0%	7.6%	0.6%	0.0%
	Existing battery charging stations	37.2%	20.6%	8.7%	4.1%
	Solar battery charging stations	0.0%	3.2%	6.5%	3.0%
	Total rural villages	61%	79%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	295	330	124
Grid demand of newly connected villages (GWh/year)	13	14	4

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	2	449
Biomass mini-grid	0	0
New diesel mini-grid	5	971
Total	7	1,420

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)


	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	544	671	0
Community PV (new villages)	35	35	0
Solar battery charging stations (new villages)	15	12	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	5,902	6,606	2,490
Distribution (transformers, LV, meters)	5,220	7,026	5,262
Subtotal grid extension	11,122	13,632	7,751
Hydro mini-grid	1,860	49	8
Biomass mini-grid	0	0	0
New diesel mini-grid	1,245	52	5
Subtotal mini-grid projects	3,105	101	13
Solar home systems	218	268	1
Community PV	89	89	0
Solar battery charging stations	301	306	0
Subtotal stand-alone systems	608	664	1
Total	14,834	14,396	7,766

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

6.17 RATTANAK KIRI



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	1.8%	3.9%	29.8%	50.5%
	Hydro mini-grid	0.0%	7.0%	3.9%	1.8%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	7.1%	10.4%	6.7%	7.0%
	New diesel mini-grid	0.0%	3.2%	0.3%	0.0%
	Solar home systems	0.0%	0.8%	1.8%	1.6%
	Total rural connections	9%	25%	42%	61%
Village coverage	National grid	3.0%	3.9%	56.2%	66.5%
	Hydro mini-grid	0.0%	15.9%	5.6%	2.1%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	35.6%	29.2%	13.7%	10.7%
	New diesel mini-grid	0.0%	6.4%	0.4%	0.0%
	Existing battery charging stations	8.6%	3.4%	2.1%	1.7%
	Solar battery charging stations	0.0%	10.9%	21.9%	18.9%
	Total rural villages	47%	70%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	5	368	90
Grid demand of newly connected villages (GWh/year)	0	8	3

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	3	1,216
Biomass mini-grid	0	0
New diesel mini-grid	5	520
Total	8	1,737

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)


	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	254	347	53
Community PV (new villages)	28	28	0
Solar battery charging stations (new villages)	26	20	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	105	7,357	1,793
Distribution (transformers, LV, meters)	152	4,397	3,045
Subtotal grid extension	256	11,755	4,838
Hydro mini-grid	5,677	194	78
Biomass mini-grid	0	0	0
New diesel mini-grid	746	39	3
Subtotal mini-grid projects	6,423	234	81
Solar home systems	102	139	62
Community PV	51	51	0
Solar battery charging stations	382	393	0
Subtotal stand-alone systems	535	584	62
Total	7,214	12,572	4,981

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

6.18 SIEM REAP



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	5.1%	24.9%	47.5%	68.4%
	Hydro mini-grid	0.0%	0.8%	0.3%	0.1%
	Biomass mini-grid	0.0%	0.7%	0.6%	0.0%
	Existing diesel mini-grid	2.3%	2.0%	2.3%	0.1%
	New diesel mini-grid	0.0%	2.6%	1.4%	0.0%
	Solar home systems	0.0%	0.3%	0.7%	0.1%
	Total rural connections	7%	31%	53%	69%
Village coverage	National grid	9.4%	46.6%	85.7%	98.6%
	Hydro mini-grid	0.0%	1.3%	0.5%	0.1%
	Biomass mini-grid	0.0%	1.3%	0.8%	0.0%
	Existing diesel mini-grid	5.7%	3.6%	3.2%	0.1%
	New diesel mini-grid	0.0%	6.2%	2.3%	0.0%
	Existing battery charging stations	47.2%	17.7%	4.3%	0.5%
	Solar battery charging stations	0.0%	1.6%	3.2%	0.7%
	Total rural villages	62%	78%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	583	589	164
Grid demand of newly connected villages (GWh/year)	27	19	16

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	1	800
Biomass mini-grid	4	789
New diesel mini-grid	11	1 673
Total	16	3 262

Grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)


	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	530	677	0
Community PV (new villages)	32	32	0
Solar battery charging stations (new villages)	14	11	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	11,657	11,772	3,282
Distribution (transformers, LV, meters)	11,269	12,413	11,740
Subtotal grid extension	22,926	24,185	15,023
Hydro mini-grid	2,933	44	6
Biomass mini-grid	969	52	11
New diesel mini-grid	1,931	166	27
Subtotal mini-grid projects	5,833	263	45
Solar home systems	212	271	5
Community PV	68	68	0
Solar battery charging stations	264	269	0
Subtotal stand-alone systems	544	608	5
Total	29,303	25,056	15,073

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

6.19 PREAH SIHANOUK



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	22.1%	44.1%	55.2%	67.9%
	Hydro mini-grid	0.0%	1.9%	1.9%	0.0%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	9.8%	4.2%	4.2%	2.0%
	New diesel mini-grid	0.0%	0.0%	0.0%	0.0%
	Solar home systems	0.0%	0.1%	0.2%	0.0%
	Total rural connections	32%	50%	62%	70%
Village coverage	National grid	44.2%	83.2%	87.4%	94.7%
	Hydro mini-grid	0.0%	4.2%	3.2%	0.0%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	31.6%	11.6%	8.4%	5.3%
	New diesel mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing battery charging stations	15.8%	1.1%	1.1%	0.0%
	Solar battery charging stations	0.0%	0.0%	0.0%	0.0%
	Total rural villages	92%	100%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	49	11	41
Grid demand of newly connected villages (GWh/year)	6	0	2

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	4	310
Biomass mini-grid	0	0
New diesel mini-grid	0	0
Total	4	310

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)


	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	30	38	0
Community PV (new villages)	0	1	0
Solar battery charging stations (new villages)	0	0	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	988	216	821
Distribution (transformers, LV, meters)	1,794	810	1,498
Subtotal grid extension	2,782	1,026	2,319
Hydro mini-grid	1,152	11	4
Biomass mini-grid	0	0	0
New diesel mini-grid	0	0	0
Subtotal mini-grid projects	1,152	11	4
Solar home systems	12	15	0
Community PV	2	2	0
Solar battery charging stations	0	0	0
Subtotal stand-alone systems	14	17	0
Total	3,949	1,054	2,323

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

6.20 STUNG TRENG



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	3.7%	7.4%	25.2%	47.3%
	Hydro mini-grid	0.0%	6.1%	2.4%	0.0%
	Biomass mini-grid	0.0%	3.5%	1.1%	1.4%
	Existing diesel mini-grid	5.8%	9.3%	9.3%	7.1%
	New diesel mini-grid	0.0%	0.5%	0.8%	0.0%
	Solar home systems	0.0%	1.2%	2.4%	1.7%
	Total rural connections	10%	28%	41%	58%
Village coverage	National grid	4.9%	10.6%	44.7%	64.2%
	Hydro mini-grid	0.0%	12.2%	0.8%	0.0%
	Biomass mini-grid	0.0%	13.8%	3.3%	3.3%
	Existing diesel mini-grid	31.7%	26.0%	17.9%	10.6%
	New diesel mini-grid	0.0%	0.8%	0.8%	0.0%
	Existing battery charging stations	23.6%	14.6%	11.4%	7.3%
	Solar battery charging stations	0.0%	10.6%	21.1%	14.6%
	Total rural villages	60%	89%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	20	164	91
Grid demand of newly connected villages (GWh/year)	0	3	4

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	6	341
Biomass mini-grid	1	650
New diesel mini-grid	1	57
Total	8	1,048

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)


	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	235	299	0
Community PV (new villages)	20	20	0
Solar battery charging stations (new villages)	13	10	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	404	3,276	1,826
Distribution (transformers, LV, meters)	303	1,752	2,427
Subtotal grid extension	707	5,028	4,253
Hydro mini-grid	2,736	70	13
Biomass mini-grid	2,434	30	13
New diesel mini-grid	57	12	6
Subtotal mini-grid projects	5,226	112	32
Solar home systems	94	120	27
Community PV	70	70	0
Solar battery charging stations	235	241	0
Subtotal stand-alone systems	399	430	27
Total	6,332	5,570	4,311

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

6.21 SVAY RIENG



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	6.7%	20.3%	31.4%	62.9%
	Hydro mini-grid	0.0%	0.0%	0.0%	0.0%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	1.7%	0.2%	0.3%	0.0%
	New diesel mini-grid	0.0%	6.3%	7.4%	0.0%
	Solar home systems	0.0%	2.0%	4.1%	0.1%
	Total rural connections	8%	29%	43%	63%
Village coverage	National grid	9.9%	32.2%	48.3%	98.2%
	Hydro mini-grid	0.0%	0.0%	0.0%	0.0%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	4.3%	0.9%	0.7%	0.0%
	New diesel mini-grid	0.0%	13.9%	11.4%	0.0%
	Existing battery charging stations	40.5%	22.0%	18.6%	0.3%
	Solar battery charging stations	0.0%	10.5%	21.0%	1.5%
	Total rural villages	55%	79%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	262	134	591
Grid demand of newly connected villages (GWh/year)	14	5	29

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	0	0
Biomass mini-grid	0	0
New diesel mini-grid	18	3,631
Total	18	3,631

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)


	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	2,458	2,957	0
Community PV (new villages)	134	134	0
Solar battery charging stations (new villages)	71	57	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	5,243	2,674	11,823
Distribution (transformers, LV, meters)	5,859	4,261	20,067
Subtotal grid extension	11,102	6,934	31,890
Hydro mini-grid	0	0	0
Biomass mini-grid	0	0	0
New diesel mini-grid	3,763	529	116
Subtotal mini-grid projects	3,763	529	116
Solar home systems	983	1,183	8
Community PV	249	249	0
Solar battery charging stations	1,341	1,360	0
Subtotal stand-alone systems	2,573	2,792	8
Total	17,438	10,255	32,013

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

6.22 TAKEO



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	9.1%	33.1%	53.2%	68.7%
	Hydro mini-grid	0.0%	0.0%	0.0%	0.0%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	1.4%	0.4%	0.3%	0.1%
	New diesel mini-grid	0.0%	0.9%	0.7%	0.1%
	Solar home systems	0.0%	0.3%	0.7%	0.1%
	Total rural connections	11%	35%	55%	69%
Village coverage	National grid	15.9%	58.1%	91.9%	98.1%
	Hydro mini-grid	0.0%	0.0%	0.0%	0.0%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	3.9%	1.8%	0.7%	0.2%
	New diesel mini-grid	0.0%	2.4%	1.0%	0.2%
	Existing battery charging stations	28.8%	9.7%	2.1%	0.3%
	Solar battery charging stations	0.0%	2.1%	4.3%	1.3%
	Total rural villages	49%	74%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	539	328	138
Grid demand of newly connected villages (GWh/year)	41	16	8

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	0	0
Biomass mini-grid	0	0
New diesel mini-grid	8	975
Total	8	975

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)

	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	622	760	0
Community PV (new villages)	35	35	0
Solar battery charging stations (new villages)	24	19	0


Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	10,789	6,560	2,752
Distribution (transformers, LV, meters)	16,409	12,725	9,762
Subtotal grid extension	27,199	19,285	12,514
Hydro mini-grid	0	0	0
Biomass mini-grid	0	0	0
New diesel mini-grid	846	106	12
Subtotal mini-grid projects	846	106	12
Solar home systems	249	304	0
Community PV	74	74	0
Solar battery charging stations	434	441	0
Subtotal stand-alone systems	756	819	0
Total	28,801	20,210	12,526

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

6.23 OTDAR MEANCHEY



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	4.3%	11.0%	34.3%	63.1%
	Hydro mini-grid	0.0%	0.0%	0.0%	0.0%
	Biomass mini-grid	0.0%	1.4%	2.0%	0.0%
	Existing diesel mini-grid	5.4%	7.3%	2.6%	0.6%
	New diesel mini-grid	0.0%	5.2%	2.1%	0.0%
	Solar home systems	0.0%	1.0%	2.0%	0.6%
	Total rural connections	10%	26%	43%	64%
Village coverage	National grid	4.1%	13.7%	59.8%	87.2%
	Hydro mini-grid	0.0%	0.0%	0.0%	0.0%
	Biomass mini-grid	0.0%	3.2%	2.7%	0.0%
	Existing diesel mini-grid	17.8%	15.5%	5.0%	1.4%
	New diesel mini-grid	0.0%	11.0%	3.7%	0.0%
	Existing battery charging stations	35.6%	23.3%	12.3%	2.7%
	Solar battery charging stations	0.0%	8.2%	16.4%	8.7%
	Total rural villages	58%	75%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	37	252	197
Grid demand of newly connected villages (GWh/year)	2	10	10

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	0	0
Biomass mini-grid	1	800
New diesel mini-grid	5	967
Total	6	1 767

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)


	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	436	638	0
Community PV (new villages)	32	31	0
Solar battery charging stations (new villages)	18	14	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	740	5,036	3,945
Distribution (transformers, LV, meters)	1,163	5,663	9,507
Subtotal grid extension	1,903	10,699	13,451
Hydro mini-grid	0	0	0
Biomass mini-grid	1,837	82	16
New diesel mini-grid	1,192	240	27
Subtotal mini-grid projects	3,030	323	43
Solar home systems	174	255	0
Community PV	80	80	0
Solar battery charging stations	307	321	0
Subtotal stand-alone systems	561	656	0
Total	5,494	11,677	13,494

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

6.24 KEP



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	15.2%	44.3%	60.9%	70.0%
	Hydro mini-grid	0.0%	0.0%	0.0%	0.0%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	0.0%	0.0%	0.0%	0.0%
	New diesel mini-grid	0.0%	0.0%	0.0%	0.0%
	Solar home systems	0.0%	0.0%	0.0%	0.0%
	Total rural connections	15%	44%	61%	70%
Village coverage	National grid	50.0%	100.0%	100.0%	100.0%
	Hydro mini-grid	0.0%	0.0%	0.0%	0.0%
	Biomass mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing diesel mini-grid	0.0%	0.0%	0.0%	0.0%
	New diesel mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing battery charging stations	35.7%	0.0%	0.0%	0.0%
	Solar battery charging stations	0.0%	0.0%	0.0%	0.0%
	Total rural villages	86%	100%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	20	0	0
Grid demand of newly connected villages (GWh/year)	1	0	0

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	0	0
Biomass mini-grid	0	0
New diesel mini-grid	0	0
Total	0	0

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)


	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	0	0	0
Community PV (new villages)	0	0	0
Solar battery charging stations (new villages)	0	0	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	392	0	0
Distribution (transformers, LV, meters)	578	284	234
Subtotal grid extension	970	284	234
Hydro mini-grid	0	0	0
Biomass mini-grid	0	0	0
New diesel mini-grid	0	0	0
Subtotal mini-grid projects	0	0	0
Solar home systems	0	0	0
Community PV	0	0	0
Solar battery charging stations	0	0	0
Subtotal stand-alone systems	0	0	0
Total	970	284	234

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

6.25 PAILIN



SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

		2010	2015	2020	2030
Connections	National grid	27.2%	38.1%	47.2%	69.1%
	Hydro mini-grid	0.0%	0.7%	0.0%	0.0%
	Biomass mini-grid	0.0%	0.6%	0.7%	0.0%
	Existing diesel mini-grid	6.2%	8.1%	10.5%	0.2%
	New diesel mini-grid	0.0%	0.0%	0.0%	0.0%
	Solar home systems	0.0%	0.2%	0.5%	0.0%
	Total rural connections	33%	48%	59%	69%
Village coverage	National grid	47.1%	63.2%	72.1%	98.5%
	Hydro mini-grid	0.0%	1.5%	0.0%	0.0%
	Biomass mini-grid	0.0%	2.9%	2.9%	0.0%
	Existing diesel mini-grid	23.5%	17.6%	17.6%	1.5%
	New diesel mini-grid	0.0%	0.0%	0.0%	0.0%
	Existing battery charging stations	8.8%	2.9%	1.5%	0.0%
	Solar battery charging stations	0.0%	2.9%	5.9%	0.0%
	Total rural villages	79%	91%	100%	100%

Coverage rates achieved in rural areas under the baseline scenario (percentage)

Grid extension in rural areas	2011-2015	2016-2020	2021-2030
MV lines for grid extension (km)	29	28	28
Grid demand of newly connected villages (GWh/year)	1	0	4

Grid extension figures in rural areas under the baseline scenario

	Projects	Total Installed capacity (kW)
Hydro mini-grid	0	0
Biomass mini-grid	0	0
New diesel mini-grid	0	0
Total	0	0

Mini-grid projects in rural areas to be installed by 2015 under the baseline scenario (only for projects, with the power source inside the province boundaries)

	2011-2015	2016-2020	2021-2030
Solar home systems (new kits)	30	43	0
Community PV (new villages)	2	3	0
Solar battery charging stations (new villages)	2	2	0

Stand-alone systems in rural areas under the baseline scenario

	2011-2015	2016-2020	2021-2030
Sub-transmission network (MV lines)	581	570	555
Distribution (transformers, LV, meters)	681	781	2,791
Subtotal grid extension	1,261	1,350	3,346
Hydro mini-grid	455	15	0
Biomass mini-grid	312	4	8
New diesel mini-grid	0	0	0
Subtotal mini-grid projects	767	19	8
Solar home systems	12	17	5
Community PV	6	6	0
Solar battery charging stations	23	24	0
Subtotal stand-alone systems	41	47	5
Total	2,069	1,417	3,359

Investment schedule under the baseline scenario (in thousands of USD, investment costs for projects covering several provinces have been split proportionally to the number of villages in each province)

7 CONCLUSIONS

In order to meet the following policy objectives, three scenarii have been defined:

Policy objectives:

- 100% village coverage by 2020 (including national grid, mini-grid and stand-alone systems)
- 70% households connected to grid-quality services by 2030 (mini grids and national grid only)

The three scenarii differ only by the rate at which the national grid will expand:

Baseline scenario:

In line with grid extension data from EDC and recent targets set by EAC:

- 80% villages to have **national grid connection** by 2020, remaining in mini-grids
- 95% villages to have **national grid connection** by 2030, remaining in mini-grids

Until 2015, this plan implies an additional 4400 grid connected villages, an expenditure of 327 MUSD and also construction, which means that the funds would have to be secured latest by end 2013, to leave time for engineering, tendering, construction. To date, it is understood that about 200 MUSD have been committed (not signed) for the next 5 years in grants and loans by international cooperation agencies

Until 2030, this implies a total of 891 MUSD in investments (MUSD, in 2010 prices)

	2011-2015	2016-2020	2021-2030
Grid extension (total)	327 423	276 938	286 772
<i>Incl. distribution (transformers, LV, meters)</i>	183 994	158 735	203 490

Intermediate scenario (half of grid extension rate compared to baseline scenario):

Only half (2200) new villages are achieved in 2015, which implies fund mobilisation of 200 MUSD, and a national village connection rate of 28%.

Continuing on this trend, by 2020 46% village grid connection is achieved (100% including all types of electricity services following policy objectives). In 2030 the household connection rate for grid-equivalent supplies is 55% (slightly below the 70% target), and villages connected remain at 78%, below the recent 95% national target.

This implies a total of 683 MUSD in investments (MUSD, in 2010 prices)

	2011-2015	2016-2020	2021-2030
Grid extension (total)	200 294	172 955	309 612
<i>Incl. distribution (transformers, LV, meters)</i>	116 008	113 812	191 409

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Conservative scenario (half of grid extension rate compared to intermediate scenario):

Only a quarter (1100) new villages are achieved in 2015, which implies fund mobilisation of 123 MUSD, and a national village connection rate of 20%

By 2020, 28% village grid connection is achieved (the rest of villages are supplied with either mini-grid projects or stand-alone systems), and in 2030, the household connection rate for grid-equivalent supplies is 42%, and villages connected remain at 46%, well under the 95% target.

This implies a total of 423 MUSD in investments (MUSD, in 2010 prices)

	2011-2015	2016-2020	2021-2030
Grid extension (total)	122 948	108 223	192 261
<i>Incl. distribution (transformers, LV, meters)</i>	<i>73 163</i>	<i>73 722</i>	<i>133 119</i>

After the grid extension has been simulated in each scenario, mini-grid projects using mini-hydro, biomass (rice gasification, rice cogeneration of sugarcane cogeneration) and diesel projects have been sized and optimised. The following tables summarise the results for the baseline scenario. In the intermediate and conservative scenarios, as the grid will be extended at a slower rate, the number of projects and investment requirements for mini grid and stand alone options will be much higher.

Mini-grid projects in rural areas by 2015 – baseline scenario	Number of projects	Total Installed capacity (kW)
Hydro mini-grid	33	6 449
Biomass mini-grid	25	10 317
New diesel mini-grid	150	21 663
Total	208	38 429

Investment costs in rural areas ('000 USD) – baseline scenario	2011-2015	2016-2020	2021-2030
Hydro mini-grid	31 492	861	233
Biomass mini-grid	16 363	581	171
New diesel mini-grid	23 906	2 382	392
Total mini-grid projects	71 761	3 824	796

Regarding mini-hydro projects, most potential sites are located in mountainous areas (mostly mountains in the Cardamoms Range and North-Eastern provinces), where there is little or no population, so they would probably be more suited to IPP and grid injection approaches, wherever the national grid is not too far and can absorb the power. However, given that a number of large hydro projects are being constructed and commissioned, it is doubtful that it would make any sense to develop such small hydro IPPs. In conclusion, there is very little mini hydro potential making economic sense for mini grids – where population is located. Smaller systems than the ones we studied (less than 50kW) may still offer some interest in mountainous regions, but this would be more considered as stand-alone systems rather than grid-quality electricity, considering issues with seasonality and overall reliability of these pico turbines.

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

For biomass mini-grid projects, three routes have been explored: biogas, cogeneration and gasification. To date, there are very few large agro-industries in the country having the quantity of humid waste required for biogas. There are only about 5 pig farms which could be potentials for such units in the medium term. Cogeneration (combined production of heat and power) again requires fairly large units, which also need the heat. Until recently, relevant agro-industries (large rice mills, sugar production) were not large enough to offer such opportunities. However, a few (5 to 10) such investments are being prepared in Cambodia. We have assumed that these multi megawatt deals would provide 500kW to 2MW for local mini grid electrification, the rest being used for own consumption or selling to the grid. Smaller scale gasifiers offer more potential, and SME Cambodia has been selling and installing gasifiers which have a fairly good track record. The rice mills typically consumes only 30% of the husk for own consumption and hence the balance could be used to sell to the local REE, which runs on diesel. However, agro-industries being usually located in areas already covered by the grid (or soon to be connected), these projects usually offer only short term opportunities for off-grid electrification, unless the regulatory framework evolves to allow easier injection of power on the national grid for such small-scale projects (which may prove competitive). The overall situation of the agro-industry sector and thus opportunities for biomass projects is expected to evolve very quickly over the next few years in Cambodia, as new policies aim to foster a modern, high added value and export based industry. Therefore the above conclusions might have to be revised significantly after a few years, depending on the effectiveness of such changes.

Diesel grids and potential for PV injection: Considering limitations in hydro and biomass projects, new diesel mini-grid projects had to be designed, in order to supply all the remaining villages identified as “Development Poles” or “growth centres”, and which require grid-quality service by 2015. All simulations have been performed assuming that these new projects would be indeed purely diesel based, although using slightly more modern and efficient equipments. However, international experience now shows that with the dropping of PV panel prices and the increase in reliability of technology, the PV production cost, with financing available over 15 years, could be between 20 and 70 UScents/kWh:

- The lowest range being for large units feeding into the grid without any battery storage
- Mid range being for smaller capacities and feeding into a diesel grid typically, still without storage
- The most costly being for very small units and with up to 100% battery storage, the PV power being produced during the day, stored and then consumed in the night time.

Unfortunately, most new diesel mini-grid projects proposed under the rural electrification plan belong to the third category. Therefore, the costs are expected to be slightly high, but still competitive with current diesel generation costs under most circumstances.

Capacity range (kW)	Proposed solution	Baseline		
		Number of projects	PV installed capacity (kWp)	Investment cost ('000 USD)
<30	100% storage	7	37	237
30-100	50% storage	43	523	2 934
>100	0% storage	100	3 773	17 846
	Total	150	4 333	21 017

In the longer term, it can be expected that, given the depth of the market of diesel operators (between 150 and 289 new projects depending on the scenario), and further cost reduction at the global stage, even projects currently comparing unfavourably with diesel may eventually become a better option.

SREP: Sustainable Rural Electrification Plans for Cambodia: National level plans

Solar Battery charging stations and Solar Home Systems for isolated settlements and clusters:

Finally, for each of the scenarios, in order to reach the government village coverage targets by 2020, Solar Battery Charging stations and PV services for community facilities have been assumed. The depth of the market for such stand-alone systems looks rather significant, even under the most optimistic grid extension scenario, with 2,000 community PV to be installed, as well as solar battery charging stations in more than 1,100 villages. Although not mandatory to reach policy targets, the market for SHS has been assessed at 37,000 to 114,000 depending on the scenario.

A few key policy issues:

Though the present report is definitely not a regulatory study, it clearly highlights that the policy targets of the Cambodian government will be impossible to reach without an appropriate and conducive regulatory and incentives framework, covering at least the following key areas:

- Streamlining issues of interface with EDC regarding distribution, the price of bulk sale from EDC to the distribution licensees and the tariff at which the distributor will then sell to the end users;
- Issues of captive power generation for own use, and then terms and conditions of sale of excess power to the national grid or to a distribution company: if the framework is too complex or the power purchase agreement not favourable enough to the investor, then there will be no economic incentive for the private sector to invest for rural electrification;
- Specific attention should be paid to taxation and duties issues, to ensure that such innovative projects are not unduly burdened, especially during the first years;
- Long term financing mechanisms will have to be put in place, which is not the practice of local commercial banks – and the REF is not yet involved in these activities. Soft loans, long term, with appropriate grace periods are an absolute requirement ;
- Appropriate facilitation, in terms of capacity building, project identification and development is also a need;
- Finally, the load forecast has been done making the assumption that the average household demand is 34,1kWh /month, with an average bill of 6,4\$/month. Though on average today, households may be able to afford this, it is only an average, and further, going into remoter areas of Cambodia, affordability will be lower: clearly, a national tariff policy will have to be thought through, if the current very ambitious household connection targets are to be met.

Updating:

Finally, it is important to highlight that the results presented in this report are only a reflection of the situation during the first quarter of 2011, data which was made available and possible to collect within a time frame of a few months in 2010, of the assumptions discussed and validated with MIME, in collaboration with EAC, EDC and REF. The Geosim tool which was used to produce these simulations has been installed at MIME and in a few Provincial offices; MIME staff was extensively trained to use the planning tool. As the situation and scenarios evolve, MIME is equipped to update the national and provincial plans for rural electrification of Cambodia.